

# Emission Sources - Maximum Allowable Emission Rates

Permit Number 20504

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

## Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
Operating Scenario 1 – Natural Gas				
4	Boiler 4 (5)	NO <sub>x</sub>	0.63	2.76
		CO	2.33	10.21
		VOC	0.34	1.49
		PM	0.47	2.07
		PM <sub>10</sub>	0.47	2.07
		PM <sub>2.5</sub>	0.47	2.07
		SO <sub>2</sub>	0.04	0.16
5	Boiler 5 (5)	NO <sub>x</sub>	0.63	2.76
		CO	2.33	10.21
		VOC	0.34	1.49
		PM	0.47	2.07
		PM <sub>10</sub>	0.47	2.07
		PM <sub>2.5</sub>	0.47	2.07
		SO <sub>2</sub>	0.04	0.16
6	Boiler 6 (5)	NO <sub>x</sub>	0.63	2.76
		CO	2.33	10.21
		VOC	0.34	1.49
		PM	0.47	2.07
		PM <sub>10</sub>	0.47	2.07
		PM <sub>2.5</sub>	0.47	2.07
		SO <sub>2</sub>	0.04	0.16
Operating Scenario 1 – Fuel Oil				
4	Boiler 4 (5)	NO <sub>x</sub>	8.91	0.36
		CO	4.91	0.2

Emission Sources - Maximum Allowable Emission Rates

		VOC	0.13	0.01
		PM	1.12	0.04
		PM <sub>10</sub>	0.56	0.02
		PM <sub>2.5</sub>	0.13	0.01
		SO <sub>2</sub>	0.09	<0.01
5	Boiler 5 (5)	NO <sub>x</sub>	8.91	0.36
		CO	4.91	0.2
		VOC	0.13	0.01
		PM	1.12	0.04
		PM <sub>10</sub>	0.56	0.02
		PM <sub>2.5</sub>	0.13	0.01
		SO <sub>2</sub>	0.09	<0.01
6	Boiler 6 (5)	NO <sub>x</sub>	8.91	0.36
		CO	4.91	0.2
		VOC	0.13	0.01
		PM	1.12	0.04
		PM <sub>10</sub>	0.56	0.02
		PM <sub>2.5</sub>	0.13	0.01
		SO <sub>2</sub>	0.09	<0.01

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) NO<sub>x</sub> - total oxides of nitrogen
- CO - carbon monoxide
- VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
- PM - total particulate matter, suspended in the atmosphere, including PM<sub>10</sub> and PM<sub>2.5</sub>
- PM<sub>10</sub> - total particulate matter equal to or less than 10 microns in diameter, including PM<sub>2.5</sub>
- PM<sub>2.5</sub> - particulate matter equal to or less than 2.5 microns in diameter
- SO<sub>2</sub> - sulfur dioxide
- NH<sub>3</sub> - ammonia
- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) Planned maintenance, startup and shutdown (MSS) for all pollutants are authorized even if not specifically identified as MSS.

Date: May 18, 2020