

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

23608

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source		Air Contaminant		<u>Emission Rates *</u>	
	Name (2)	Name (3)	lb/hr	TPY		
1	BUILDING/HVAC	1,1,1 trichloroethane			10.3	24.3
				hexane	1.1	2.5
				potassium hydroxide	0.04	0.1
				ammonia	0.23	0.54
				VOC	0.87	1.9
2	VULCANIZER	potassium hydroxide		hexane	6.9	22.3
				potassium hydroxide	0.01	0.02
				ammonia	0.04	0.1
				VOC	2.43	5.3

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources use area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in General Rule 101.1

* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

Hrs/day 16 Days/week 6 Weeks/year 49 or Hrs/year _____

Dated _____