


Trainings ▾

Calibrate

with Mechanically Actuated Injector


Note : Calibration is performed per Maintenance Procedures at 6000 Hours.

This procedure requires special equipment and **must** be done at a Cummins® Authorized Repair Location.



with Electronically Actuated Injector

Calibration is **not** required for the Modular Common Rail Fuel System.



Replace

with Mechanically Actuated Injector

This procedure requires special equipment. Contact a Cummins® Authorized Repair Location.



with Electronically Actuated Injector

This procedure requires special equipment. Contact a Cummins® Authorized Repair Location.

Replacement is recommended for electronically actuated injectors at engine half life to rebuild.

Half life to rebuild varies by application. Contact a Cummins® Distributor if interval is **not** immediately available.

This recommendation applies **only** to Cummins® Dual Fuel Kit equipped engines.

