

Trainings ▾

Specifications

For performance and fuel rate values, refer to the engine data sheet or the fuel pump code for the particular model involved.

Maximum fuel supply restriction at the lift pump inlet:

With clean prefilter element(s)	100 mm Hg [4.0 in Hg]
---------------------------------	-----------------------

With dirty prefilter element(s)	203 mm Hg [8.0 in Hg]
---------------------------------	-----------------------

Maximum fuel drain restriction:

Includes fuel cooler	508 mm Hg [20.0 in Hg]
----------------------	------------------------

Minimum allowable fuel tank vent capability:

With back pressure less than or equal to 64 mm Hg [2.5 in Hg]	425 liters/hr [15 cu ft/hr]
---	-----------------------------

Maximum fuel filter restriction:

Maximum pressure drop across filters	34.4 kPa [5.0 psi]
--------------------------------------	--------------------

Minimum pressure at injection pump inlet:

At idle	172.3 kPa [25.0 psi]
---------	----------------------

At rated speed	241.3 kPa [35.0 psi]
----------------	----------------------

All QST30 engines built before January 3, 2000, have a two letter fuel pump timing code on the engine dataplate instead of a numerical fuel pump timing value. The following table contains all two letter fuel pump timing codes and their corresponding nominal value in degrees.

Use the following procedures for assistance in timing the QST30 fuel pumps:

- Refer to Procedure 005-012 in Section 5. (</qs3/pubsys2/xml/en/procedures/57/57-005-012-tr.html>)

The following table is for engines built before January 3, 2000.

Fuel Pump Timing Codes	
Timing Code	Degrees (nominal) (Tolerance +/- 0.5 degrees)
JP	23.0
KB	7.5
KD	11.0
KE	24.5
KI	17.5
KJ	9.0
KM	18.5
KO	22.0
KP	0.5
KT	23.5
KX	20.5
KZ	19.5
LP	13.5
LQ	15.5
LR	11.5

Last Modified: 08-Nov-2013
