

Trainings ▾

General Information

⚠ CAUTION ⚠

Failure to follow the correct shutdown procedure can result in damage to power cylinder components and the turbocharger, if equipped, and shorten the turbocharger life.

For engines with shielded exhaust manifold and turbochargers, allow the engine(s) to idle for 10 to 12 minutes before shutting off after full load operation.

Otherwise, allow the engine(s) to idle 3 to 5 minutes before shutting off after full load operation. This process allows the cool down of pistons, cylinders, bearings and turbocharger components.

For engines equipped with an engine control module (ECM), turn the keyswitch off for a minimum of 100 seconds before attempting to restart the engine or attempting to disconnect the continuous (unswitched) battery power supply. If 100 seconds have **not** passed, corruption to ECM information, fault codes and internal engine damage can occur.

Turn the ignition switch to the OFF position. If the engine does **not** shut down, contact a Cummins® authorized repair location.

