

Trainings ▾

Worksheet

[illegible]

Fuel Temperature	Correction for Flow Rate
Less than 7°C [45°F]	Flow meter not accurate
7 to 13°C [45 to 55°F]	Subtract 2% from flow rate reading
13.0 to 20.0°C [55 to 68°F]	Subtract 1% from flow rate reading
20.0 to 29°C [68 to 85°F]	No Correction
29 to 42°C [85 to 108°F]	Add 1% to flow rate reading
42 to 56°C [108 to 132°F]	Add 2% to flow rate reading
Above 56°C [132°F]	Flow meter not accurate.

Pressure Conversions
25 mm H ₂ O [1 in H ₂ O] = 1.87 mm Hg [0.074 in Hg] = 0.249 kPa [0.036 psi]
25 mm Hg [1 in Hg] = 0.039 mm H ₂ O [13.514 in H ₂ O] = 3.386 kPa [0.491 psi]
6.895 kPa [1 psi] = 51.715 mm Hg [2.036 in Hg] = 0.080 mm H ₂ O [27.7 in H ₂ O]

This Page Can Be Copied for Your Convenience.