

Trainings ▾

General Information

Cooling systems perform best with distilled or deionized water. If distilled or deionized water is **not** available, the quality of the water used **must** meet all the requirements listed in Table 1 below. Excessive levels of calcium and magnesium contribute to scaling problems. Excessive levels of chloride and sulfate cause cooling system corrosion.

If water quality is unknown, water test results can be obtained from local water utility departments or can be tested with:

- Cummins Filtration Monitor-C™ laboratory testing, Part Number CC2700 or CC2706
- Cummins Filtration Water-Chek™ test strips, Part Number CC2609, used to determine harness, pH, and chloride concentration in water.

Test data **must** show the following elements. The element levels **must not** exceed the published limits for use in cooling systems.

Table 1 - Maximum Element Level Allowable in Water	
Element	Maximum Level Allowable
Calcium + Magnesium (Hardness)	170 ppm (as CaCO ₃)
Chloride	40 ppm (as Cl)
Sulfate	100 ppm (as SO ₄)
Total Dissolved Solids	340 ppm
pH	5.5 to 9.0 (min/max)