

Fault Code: 1312


Customer - Defined Fault Code 2

 Printable Version

Overview

Codes	Reason	Effect
Fault Code: 1312 PID(P): SPN: FMI: Lamp: Shutdown/Warning SRT:	Customer-defined Fault Code 2.	Trim dependent generator set will possibly not take any action, or it will possibly shut down.

©Cummins Inc



19802649

Generator Set ECM Card Cage

Circuit Description

Component Location

Refer to Troubleshooting Fault Code t05-1312. (/qs3/pubsys2/xml/en/procedures/01/01-t05-1312.html)

Last Modified: 08-May-2012
