

Fault Code: 1315


Customer - Defined LonWorks Fault Code 3

 Printable Version

Overview

Codes	Reason	Effect
Fault Code: 1315 PID(P): SPN: FMI: Lamp: Shutdown/Warning SRT:	Customer-defined LonWorks Fault Code 3.	Trim dependent generator set will possibly not take any action, or it will possibly shut down.

©Cummins Inc



19802649

Generator Set ECM Card Cage

Circuit Description

Component Location

Refer to Troubleshooting Fault Code t05-1315. (/qs3/pubsys2/xml/en/procedures/01/01-t05-1315.html)

Last Modified: 08-May-2012
