

Fault Code: 1351


LonWorks Network Board - Missing

 Printable Version

Overview

Codes	Reason	Effect
Fault Code: 1351 PID(P): SPN: FMI: Lamp: Shutdown SRT:	The LonWorks Network board is missing.	The generator set will not be able to communicate with other devices on the LonWorks Network.

©Cummins Inc



19802792

Generator Set ECM LonWorks Network Board

Circuit Description

Once the software has been loaded into the ECM, the software will do a hardware check to make sure that all necessary cards are installed for the application.

This fault code is used by the ECM to tell the operator that the LonWorks Network board (slot 4) is missing.

Component Location

Refer to Section E for location of the ECM card cage and the LonWorks Network board (slot 4).

Shoptalk

The possible failure mode is that the LonWorks Network board has lost its independent power supply.

Refer to Troubleshooting Fault Code t05-1351 (</qs3/pubsys2/xml/en/procedures/01/01-t05-1351.html>)

Last Modified: 29-Jul-2010
