


Fault Code: 1457

Generator Synchronizing to Electric Bus Failed - Condition Exists

 Printable Version

Overview

Codes	Reason	Effect
Fault Code: 1457 PID(P): SPN: FMI: Lamp: Warning SRT:	Generator synchronizing to electric bus failed.	Generator will continue to run, but will not pick up load.



Generator Circuit

Circuit Description

The generator set picks up the electrical load from the bus. For the generator to connect to a bus (other than a dead bus), it **must** match, with a threshold, the voltage and frequency of the bus. The generator set can **not** connect to the bus while voltage and frequency are outside the threshold; otherwise, damage could occur to the generator set.

This fault code is used by the engine control module (ECM) to tell the operator that the generator set failed to synchronize to the electrical bus.

Component Location

Reference Section E for location of the ECM card cage.

Reference customer/facility/installation documentation for the location of the generator set circuit breaker and interface with the electrical bus.

Shoptalk

Check the governor for correct setup.

Check the synchronizing parameters for correct setup.

Check the fuel system for problems that can cause instability.

Refer to Troubleshooting Fault Code t05-1457. (</qs3/pubsys2/xml/en/procedures/01/01-t05-1457.html>)

Last Modified: 08-May-2012
