

Fault Code: 1464


Generator Set Load Dump

 Printable Version

Overview

Codes	Reason	Effect
Fault Code: 1464 PCODE(P): SPN: FMI: Lamp: None SRT:	The generator announces to the LonWorks network that a 'load dump' has occurred.	No action is taken by the ECM.

©Cummins Inc



19802649

Generator Set ECM Card Cage

Circuit Description

Component Location

Refer to Troubleshooting Fault Code t05-1464 (/qs3/pubsys2/xml/en/procedures/01/01-t05-1464.html)

Last Modified: 29-Jul-2010
