

Fault Code: 1468


LonWorks Network-Lost Communication

 Printable Version

Overview

Codes	Reason	Effect
Fault Code: 1468 PID(P): SPN: FMI: Lamp: Warning SRT:	Loss of communication from the LonWorks Network.	No action taken by ECM.

©Cummins Inc



LonWorks Network Circuit

Circuit Description

If a LonWorks Network is installed, the ECM checks communication to make sure it is operating correctly. The ECM uses the LonWorks Network to inform other controllers on the LonWorks Network about generator set operation, performance, setup, and diagnostics. The ECM monitors the LonWorks Network, no communication with the LonWorks Network will trip Fault Code 1468, caused by shorts or open circuits.

Component Location

Refer to Section E for location of the LonWorks board.

Shoptalk

Refer to the LonWorks Network publications for more specific troubleshooting methods.

Refer to Troubleshooting Fault Code t05-1468 (</qs3/pubsys2/xml/en/procedures/01/01-t05-1468.html>)

Last Modified: 29-Jul-2010
