

Engine Protection Override Switch Does Not Inhibit Shutdown

Symptoms

- Check the SDU410 unit shutdown override LED lights when shutdown override switch is activated at the SDU410 connector.

How To Use This Tree

This symptom tree can be used to troubleshoot a malfunction. Start by performing Step 1 troubleshooting. Step 2 will ask a series of questions and will provide a list of troubleshooting steps to perform, depending on the symptom.

Shoptalk

The SDU410 input signals are switches. These switches are normally open and closed to activate a shutdown.

Try closing a shutdown switch on the SDU410 unit. If the engine still shuts down (with shutdown override still active), then the SDU410 has malfunctioned. Reference the appropriate troubleshooting tree in Section TT of this manual.

Troubleshooting Summary

STEPS		SPECIFICATIONS
STEP 1.	Check the customer interface box	
	STEP 1A. Check the customer interface box logic unit LED illumination.	Are any alarms active or LEDs illuminated?
	STEP 1B. Check the SDU410 power supply wire for +24-VDC.	Less than +24-VDC?
STEP 2.	Check the customer interface box wiring	
	STEP 2A. Check the engine protection override relay signal and return wires for an open.	Less than 10 ohms?

STEP 1. Check the customer interface box

STEP 1A. Check the customer interface box logic unit LED illumination.

Conditions :

- Check the DCU410 unit for alarms and LED illumination.

Action	Specification/Repair	Next Step
Check for alarms and LED illumination on the DCU410 unit.	Are any alarms active or LEDs illuminated? YES	Contact a Cummins® Authorized Repair Location
	Are any alarms active or LEDs illuminated? NO	1B

STEP 1B. Check the DCU410 power supply wire for +24-VDC.

Conditions :

- Open the customer interface box

Action	Specification/Repair	Next Step
Check the voltage at the shutdown unit supply 24-VDC at the SDU410 unit. • Place one test lead on the shutdown unit supply 24-VDC supply wire at the SDU410 unit. • Place the other test lead on the shutdown unit return wire at the SDU410 unit. Refer to the appropriate circuit diagram or wiring diagram for connection pin identification.	Less than +24-VDC? YES Repair : Check the batteries. Refer to the OEM service manual or contact a Cummins® Authorized Repair Location.	Repair complete
	Less than +24-VDC? NO	2A

STEP 2. Check the customer interface box wiring

STEP 2A. Check the engine protection override relay signal and return wires for an open.

Conditions :

- Open the customer interface box
- Disconnect the engine protection override relay signal and return wires at the SDU410 unit.

Action	Specification/Repair	Next Step
Check the engine protection override relay signal and return wires for an open.	Less than 10 ohms? YES	Repair complete
• Place one test lead on the engine protection override relay signal wire at the SDU410 unit. • Place the other test lead on the engine protection override relay signal wire at the relay contact. • Place one test lead on the engine protection override relay return wire at the SDU410 unit. • Place the other test lead on the engine protection override relay return wire at the relay contact. Refer to the appropriate circuit diagram or wiring diagram for connection pin identification.	Less than 10 ohms? NO Repair : Replace the wire. Refer to Procedure 015-023 (Customer Interface Box) in Section 15. (/qs3/pubsys2/xml/en/procedures/116/116-015-023.html) Replace the relay. Contact a Cummins® Authorized Repair Location for replacement of the customer interface box relay.	Contact a Cummins® Authorized Repair Location

