



# Technical Service Bulletin

Technical Service Bulletin: tsb101553

Released Date: 14-Dec-2004

Fuel Shutoff Valve Solenoid Resistance Specification

## Fuel Shutoff Valve Solenoid Resistance Specification

### Warranty Statement

The information in this document has no effect on present warranty coverage or repair practices, nor does it authorize TRP or Campaign actions.

### Contents

The purpose of this Service/Parts Topic is to notify the field of a change in electrical resistance specifications for the fuel shutoff valve solenoid. The new resistance specifications are more accurate than the old specifications. The new specifications are listed in the table below.

#### Revised Fuel System Shutoff Valve Solenoid Specifications

| Voltage | Resistance Minimum (Ohms) | Resistance Maximum (Ohms) |
|---------|---------------------------|---------------------------|
| 6 VDC   | 1                         | 5                         |
| 12 VDC  | 6                         | 15                        |
| 24 VDC  | 24                        | 50                        |
| 32 VDC  | 42                        | 80                        |
| 36 VDC  | 46                        | 87                        |
| 48 VDC  | 92                        | 145                       |
| 74 VDC  | 315                       | 375                       |
| 115 VAC | 645                       | 735                       |

In all cases the solenoid terminals **must** be thoroughly cleaned before the measurement is taken. In the case of the single pole solenoids, it is recommended to scrape paint off another portion of the solenoid cast iron housing. Good contact pressure with the multimeter terminals is recommended as well as a stable measurement on the display before the reading is compared against the specifications.

Procedure 005-043 (Fuel Shutoff Valve) is being updated to reflect the new specifications.

# Related Procedures

---

|                                                                   |                                                                           |
|-------------------------------------------------------------------|---------------------------------------------------------------------------|
| 09-005-043<br>(/qs3/pubsys2/xml/en/procedures/09/09-005-043.html) | Fuel Shutoff Valve<br>(/qs3/pubsys2/xml/en/procedures/09/09-005-043.html) |
|-------------------------------------------------------------------|---------------------------------------------------------------------------|

---

**Last Modified: 14-Dec-2004**

---