



Technical Service Bulletin: TSB160114

Released Date: 26-Dec-2016

Implementation of Corrosion Resistor Coolant Filter for Industrial Applications.

Implementation of Corrosion Resistor Coolant Filter for Industrial Applications.

Warranty Statement

The information in this document has no effect on present warranty coverage or repair practices, nor does it authorize TRP or Campaign actions.

Contents

Product Affected

- NTA-855-C (Industrial applications **only**.)

Description of Change

This document announces the implementation of Corrosion Resistor Coolant Filter.

Reason for Change

The new corrosion resistor coolant filter will:

- Filter out debris.
- Prevent pitting, corrosion, rust, and coolant deposits on engine components.
- Help maintain correct coolant concentration by releasing supplemental coolant additives (SCA).

Service Instructions

- Corrosion resistor coolant filter, Part number 4058965, **must** be installed at next scheduled maintenance interval for coolant filter and all subsequent intervals.
- Corrosion resistor coolant filter, Part Number 4058965, **must** be replaced every 300 hours or 6 months. See NTA-855-C Operation and Maintenance Manual. Reference Maintenance Procedure for Every 300 Hours or 6 Months in Section 5.
- The coolant shutoff valves **must** be in the open position during engine operation. See Figure 1 below.
- For removal and installation information, reference Procedure 008-006. See link below.

Note :

<https://quickserve.cummins.com/qs3/pubsys2/xml/en/procedures/106/106-008-006-tr-csa.html?q=106-008-006-tr>
(<https://quickserve.cummins.com/qs3/pubsys2/xml/en/procedures/106/106-008-006-tr-csa.html?q=106-008-006-tr>)



Figure 1, Coolant Shutoff Valve in Open Position.

Service Parts Availability

Service parts are available. See Table 1 for part numbers.

Table 1, Service Parts

Part Description	New Part Number
Corrosion, Resistor	4058965

Production Status

Table 2, Production Information

Product	Engine Serial Number (ESN) First	Build Date*	Engine Plant
NTA-855-C	25418016	26 May 16	KCL-INDIA, LTD

*Engine build date can be found on the engine data plate

Document History

Date	Details
2016-10-20	Module Created

Date	Details
2016-12-16	Changed corrosion resistor coolant filter maintenance interval from 250 to 300 hours. Removed Operation and Maintenance Manual bulletin number.

Last Modified: 26-Dec-2016
