



Technical Service Bulletin

Technical Service Bulletin: TSB130148

Released Date: 15-Oct-2013

Next Generation CENSE™ Fault Code List Changes

Next Generation CENSE™ Fault Code List Changes

Warranty Statement

The information in this document has no effect on present warranty coverage or repair practices, nor does it authorize TRP or Campaign actions.

Contents

This document announces the changes to the CENSE™ fault code list that will be implemented as part of the Next Generation - CENSE™ CM2330 module launch.

There will be seventeen new fault code numbers that will replace existing ones used by the CENSE™ CM530 module. The old number are found in the Cummins® Description box of the table below.

Note : For CENSE™, the lamp information displayed in INSITE™ electronic service tool is original equipment manufacturer (OEM) dependent and may **not** reflect the actual lamp configuration of a given application.

Next Generation CENSE™ CM2330 - Fault Code Information Update

New Fault Code Number	Lamp	Lamp Device	Cummins® Description
5511	Amber	Warning	(CENSE™ Fault Code 126) Intake Manifold 2 Pressure - Data Valid But Above Normal Operating Range - Moderately Severe Level
5512	None	None	(CENSE™ Fault Code 127) Intake Manifold 2 Pressure - Data Valid But Below Normal Operating Range - Moderately Severe Level

Next Generation CENSE™ CM2330 - Fault Code Information Update			
New Fault Code Number	Lamp	Lamp Device	Cummins® Description
5513	None	None	(CENSE™ Fault Code 128) Intake Manifold 2 Pressure Sensor Circuit - Voltage Above Normal or Shorted to High Source
5514	None	None	(CENSE™ Fault Code 129) Intake Manifold 2 Pressure Sensor Circuit - Voltage Below Normal or Shorted to Low Source
5515	Red	Stop / Shutdown	(CENSE™ Fault Code 2144) Exhaust Gas Temperature Cylinder 17 (A9) - Data Valid But Above Normal Operating Range - Most Severe Level
5516	Red	Stop / Shutdown	(CENSE™ Fault Code 489) AXG Speed Low Error
5517	None	None	(CENSE™ Fault Code 616) Turbocharger 1 Compressor Intake Temperature - Data Valid But Above Normal Operating Range - Moderately Severe Level
5518	Red	Stop / Shutdown	(CENSE™ Fault Code 651) Exhaust Gas Temperature Cylinder 2 (B1) - Data Valid But Above Normal Operating Range - Most Severe Level

Next Generation CENSE™ CM2330 - Fault Code Information Update			
New Fault Code Number	Lamp	Lamp Device	Cummins® Description
5519	Red	Stop / Shutdown	(CENSE™ Fault Code 652) Exhaust Gas Temperature Cylinder 4 (B2) - Data Valid But Above Normal Operating Range - Most Severe Level
5521	Red	Stop / Shutdown	(CENSE™ Fault Code 653) Exhaust Gas Temperature Cylinder 6 (B3) - Data Valid But Above Normal Operating Range - Most Severe Level
5522	Red	Stop / Shutdown	(CENSE™ Fault Code 654) Exhaust Gas Temperature Cylinder 8 (B4) - Data Valid But Above Normal Operating Range - Most Severe Level
5523	Red	Stop / Shutdown	(CENSE™ Fault Code 655) Exhaust Gas Temperature Cylinder 10 (B5) - Data Valid But Above Normal Operating Range - Most Severe Level
5524	Red	Stop / Shutdown	(CENSE™ Fault Code 656) Exhaust Gas Temperature Cylinder 12 (B6) - Data Valid But Above Normal Operating Range - Most Severe Level

Next Generation CENSE™ CM2330 - Fault Code Information Update			
New Fault Code Number	Lamp	Lamp Device	Cummins® Description
5525	Red	Stop / Shutdown	(CENSE™ Fault Code 657) Exhaust Gas Temperature Cylinder 14 (B7) - Data Valid But Above Normal Operating Range - Most Severe Level
5526	Red	Stop / Shutdown	(CENSE™ Fault Code 658) Exhaust Gas Temperature Cylinder 16 (B8) - Data Valid But Above Normal Operating Range - Most Severe Level
5527	None	None	(CENSE™ Fault Code 694) Turbocharger 1 Compressor Intake Temperature Circuit - Voltage Above Normal or Shorted to High Source
5528	None	None	(CENSE™ Fault Code 695) Turbocharger 1 Compressor Intake Temperature Circuit - Voltage Below Normal or Shorted to Low Source

Document History

Date	Details
2013-10-7	Module Created

Last Modified: 15-Oct-2013
