

Customer/Code word
 Customer Order No., external
 Serial-No. ZYC220673100001
 Customer Order No., internal 3001565031
 Pos. No. 1000
 Order Number CABINET_800-Z
 Options see next Page

Technical Data:

Input	DC / 675V-1080V	1230A
Output	3AC / 0V-0,75*InputV	1025A
Duty Class	I	
Cooling Method	AF	
Temperature Range	+ 0 - + 40	
Degree of protection	IP20	

Test according to:	Part List SINAMICS_CE_APP	Test Instructions 4 SE A5E00328331A QP 4 SE A5E00328332A QP
--------------------	------------------------------	---

Tests carried out according to:

1. Visual test
2. Insulation test: EN 50178, EN 60146-1
3. Function test

The routine test has been passed in all respects.

The product is released for delivery through:

Wang, Min Jiang - SEDL P2

This test certificate was generated on:

30.11.2011

This test certificate is only valid with the red test label on the converter cubicle.

Comments:

Options	Description
D02	CUSTOMER-SPECIFIC DOCUMENTATION IN DXF FORMAT
K50	SMC30 INCREMENTAL ENCODER MODULE
M27	SIDE PANEL ONLY MOUNTED ON THE LEFT (FOR SIDE-BY-SIDE MOUNTING)
M60	ADDITIONAL SHOCK PROTECTION WITH CABINET DOOR OPENED
M84	DC BUSBAR CONNECTION (ID=2730 A)
X30	IMPLEMENTATION ACCORDING TO CUSTOMER SPECIFICATIONS
Y11	TRANSPORTATION UNIT FOR CABINET MODULES
Y33	LABELING OF CABINET MODULES WITH PLANT IDENTIFICATION (FOUR-LINE)

Customer/Code word

Customer Order No., external

Serial-No. ZYC220673100002

Customer Order No., internal 3001565031

Pos. No. 2000

Order Number CABINET_600-Z

Options see next Page

Technical Data:

Input 3AC / 500V-690V 1600A

Output 3AC / 0V-1*InputV 1600A

Duty Class I

Cooling Method AF

Temperature Range + 0 - + 40

Degree of protection IP20

Test according to:

Part List
SINAMICS_CE_APP

Test Instructions
4 SE A5E00328331A QP
4 SE A5E00328332A QP

Tests carried out according to:

4. Visual test
5. Insulation test: EN 50178, EN 60146-1
6. Function test

The routine test has been passed in all respects.

The product is released for delivery through:

Wang, Min Jiang - SEDL P2

This test certificate was generated on:

30.11.2011

This test certificate is only valid with the red test label on the converter cubicle.

Comments:

Options	Description
D02	CUSTOMER-SPECIFIC DOCUMENTATION IN DXF FORMAT
M60	ADDITIONAL SHOCK PROTECTION WITH CABINET DOOR OPENED
M84	DC BUSBAR CONNECTION (ID=2730 A)
X30	IMPLEMENTATION ACCORDING TO CUSTOMER SPECIFICATIONS
Y11	TRANSPORTATION UNIT FOR CABINET MODULES
L42	LINE CONNECTION MODULE FOR ACTIVE INFEEED
L87	INSULATION MONITORING
Y33	LABELING OF CABINET MODULES WITH PLANT IDENTIFICATION (FOUR-LINE)

Customer/Code word

Customer Order No., external

Serial-No. ZYC220673100003

Customer Order No., internal 3001565031

Pos. No. 3000

Order Number CABINET_1400-Z

Options see next Page

Technical Data:

Input AC / 500V-690V 1270A

Output DC / 0V-1,5*InputV 1422A

Duty Class I

Cooling Method AF

Temperature Range + 0 - + 40

Degree of protection IP20

Test according to:

Part List
SINAMICS_CE_APP

Test Instructions

4 SE A5E00328331A QP
4 SE A5E00328332A QP

Tests carried out according to:

- 7. Visual test
- 8. Insulation test: EN 50178, EN 60146-1
- 9. Function test

The routine test has been passed in all respects.

The product is released for delivery through:

Wang, Min Jiang - SEDL P2

This test certificate was generated on:

30.11.2011

This test certificate is only valid with the red test label on the converter cubicle.

Comments:

Options	Description
D02	CUSTOMER-SPECIFIC DOCUMENTATION IN DXF FORMAT
M60	ADDITIONAL SHOCK PROTECTION WITH CABINET DOOR OPENED
M84	DC BUSBAR CONNECTION (ID=2730 A)
X30	IMPLEMENTATION ACCORDING TO CUSTOMER SPECIFICATIONS
Y11	TRANSPORTATION UNIT FOR CABINET MODULES
Y33	LABELING OF CABINET MODULES WITH PLANT IDENTIFICATION (FOUR-LINE)

Customer/Code word

Customer Order No., external

Serial-No. ZYC220673100004

Customer Order No., internal 3001565031

Pos. No. 4000

Order Number CABINET_800-Z

Options see next Page

Technical Data:

Input DC / 675V-1080V 1230A

Output 3AC / 0V-0,75*InputV 1025A

Duty Class I

Cooling Method AF

Temperature Range + 0 - + 40

Degree of protection IP20

Test according to:

Part List
SINAMICS_CE_APP

Test Instructions
4 SE A5E00328331A QP
4 SE A5E00328332A QP

Tests carried out according to:

10. Visual test

11. Insulation test: EN 50178, EN 60146-1

12. Function test

The routine test has been passed in all respects.

The product is released for delivery through:

Wang, Min Jiang - SEDL P2

This test certificate was generated on:

30.11.2011

This test certificate is only valid with the red test label on the converter cubicle.

Comments:

Options	Description
D02	CUSTOMER-SPECIFIC DOCUMENTATION IN DXF FORMAT
K50	SMC30 INCREMENTAL ENCODER MODULE
M60	ADDITIONAL SHOCK PROTECTION WITH CABINET DOOR OPENED
M84	DC BUSBAR CONNECTION (ID=2730 A)
X30	IMPLEMENTATION ACCORDING TO CUSTOMER SPECIFICATIONS
Y11	TRANSPORTATION UNIT FOR CABINET MODULES
Y33	LABELING OF CABINET MODULES WITH PLANT IDENTIFICATION (FOUR-LINE)