

Customer/Code word
 Customer Order No., external
 Serial-No. ZYC309673100006
 Customer Order No., internal 3001629880
 Pos. No. 17000
 Order Number CABINET_600-Z
 Options see next Page

Technical Data:

Input	-- / V- V	-A
Output	-- / -V--V	-A
Duty Class	I	
Cooling Method	AF	
Temperature Range	+ 0 - + 40	
Degree of protection	IP20	

Test according to:	Part List SINAMICS_CE_APP	Test Instructions 4 SE A5E00328331A QP 4 SE A5E00328332A QP
--------------------	-------------------------------------	--

Tests carried out according to:

1. Visual test
2. Insulation test: EN 50178, EN 60146-1
3. Function test

The routine test has been passed in all respects.

The product is released for delivery through:

Wang, Min Jiang - SEDL P2

This test certificate was generated on:

30.11.2011

This test certificate is only valid with the red test label on the converter cubicle.

Comments:

Options	Description
D02	CUSTOMER-SPECIFIC DOCUMENTATION IN DXF FORMAT
M27	SIDE PANEL ONLY MOUNTED ON THE LEFT (FOR SIDE-BY-SIDE MOUNTING)
M84	DC BUSBAR CONNECTION (ID=2730 A)
X30	IMPLEMENTATION ACCORDING TO CUSTOMER SPECIFICATIONS
Y11	TRANSPORTATION UNIT FOR CABINET MODULES
Y33	LABELING OF CABINET MODULES WITH PLANT IDENTIFICATION (FOUR-LINE)