AC$B Camp Unit 9RbW Monthly Report - Unit Commander

2023-05

Company
Logo

Table of Contents

1. Electricity Consumption

AC$B Camp: EUI by Units in 2023-05

AC$B Camp: Month to Month EUI by Units in 2023-05

Unit 9RbW Peer Comparison in 2023-05	
EUI for 9RbW	3,805 Wh/m2
EUI for Best Performing Peer	1,031 Wh/m2
EUI % Against Best Performing Peer	269%
EUI % Against Median Peer	24%

Monthly Performance

Weekly Performance

Average Hourly Performance

Unit 9RbW Self Comparison in 2023-05	
EUI This Month	3,805 Wh/m2
EUI Last Month	3,348 Wh/m2
EUI Month to Month Comparison	increase 14%
Highest EUI Week	1,445 Wh/m2, Week Starting From 2023-05-22
Highest EUI Hour	6 Wh/m2 in 14:00-15:00 hr

2. Water Consumption

AC$B Camp: WEI by Units in 2023-05

AC$B Camp: Month to Month WEI by Units in 2023-05

Unit 9RbW Peer Comparison in 2023-05	
WEI for 9RbW	0.058 m3/m2
WEI for Best Performing Peer	0.023 m3/m2
WEI % Against Best Performing Peer	148%
WEI % Against Median Peer	0%

Monthly Performance

Weekly Performance

Average Hourly Performance

| Unit 9RbW Peer Comparison in 2023-05	
WEI This Month	0.058 m3/m2
WEI Last Month:	0.052 m3/m2
WEI Month to Month Comparison	increase 11%
Highest WEI Week	0.021 m3/m2, Week Starting From 2023-05-15
Highest WEI Hour	0.0001 m3/m2 in 23:00-24:00 hr

3. Anomaly Detection

### 3.1. Top 1 Highest Daily Anomaly - Block 725 on 2023-05-01

In 2023-05, the top 1 highest daily anomaly in blk-725 is observed on 2023-05-01 with total anomalous consumption of 84509.27 Wh 29.01% deviation from expected consumption.

### 3.2. Top 2 Highest Daily Anomaly - Block 723 on 2023-05-01

In 2023-05, the top 2 highest daily anomaly in blk-723 is observed on 2023-05-01 with total anomalous consumption of 75278.28 Wh 27.78% deviation from expected consumption.

### 3.3. Top 3 Highest Daily Anomaly - Block 723 on 2023-05-08

In 2023-05, the top 3 highest daily anomaly in blk-723 is observed on 2023-05-08 with total anomalous consumption of 26848.22 Wh 9.88% deviation from expected consumption.

## 3.4. Top 4 Highest Daily Anomaly - Block 701 on 2023-05-02

In 2023-05, the top 4 highest daily anomaly in blk-701 is observed on 2023-05-02 with total anomalous consumption of 74520.14 Wh 9.63% deviation from expected consumption.

## 3.5. Top 5 Highest Daily Anomaly - Block 724 on 2023-05-01

In 2023-05, the top 5 highest daily anomaly in blk-724 is observed on 2023-05-01 with total anomalous consumption of 14111.46 Wh 5.78% deviation from expected consumption.

3.6. Top 6 Highest Daily Anomaly - Block 723 on 2023-05-20

In 2023-05, the top 6 highest daily anomaly in blk-723 is observed on 2023-05-20 with total anomalous consumption of 7533.88 Wh 5.47% deviation from expected consumption.