

NEXT-White experiment energy plane electronics design

Vicente Álvarez^{a,*}, Vicente Herrero^b, Juan José Gomez Cadenas^a, Raúl Esteve^b, Andrew Laing^b, Javier Rodríguez^b, Marc Querol^a, Francesc Monrabal^c, José Francisco Toledo^b

^a*Instituto de Física Corpuscular (IFIC), CSIC & Universitat de València
Calle Catedrático José Beltrán, 2, 46980 Paterna, Valencia, Spain*

^b*Instituto de Instrumentación para Imagen Molecular (I3M), Universitat Politècnica de València
Camino de vera, s/n, Edificio 8B, 46022 Valencia, Spain*

^c*Department of Physics, University of Texas at Arlington
Arlington, Texas 76019, USA*

Abstract

NEXT-White (NEW) experiment is looking for the neutrinoless double beta decay of ^{136}Xe , and therefore requires good level of radiopurity. To this end, the PMTs used for the energy measurement and their electronics have been designed and implemented in the NEXT-White (NEW) demonstrator not only considering the 1% energy resolution required but taking into account radiopurity limitations. The design was done to assure the required front-end electronics specifications such as linearity and low noise and also meet a low radioactivity level. In order to reduce low frequency noise effects and enhance detector's security a grounded cathode connection has been used. A detailed description of the electronics and required signal postprocessing to obtain a liner response and overcome AC coupling effects are provided.

Keywords:

Energy, plane, PMT, Calometry, Front-end electronics, FEE, ATCA, DSP, BLR

1. Introduction

NEXT (Neutrino Experiment with a Xenon TPC) [1] is a neutrinoless double-beta ($\beta\beta 0\nu$) decay experiment at the Canfranc Underground Laboratory (LSC) [2]. It seeks to detect the ($\beta\beta 0\nu$) decay of ^{136}Xe using a high pressure xenon gas TPC with electroluminescent (EL) amplification. The NEXT-White (NEW) detector (shown on figure 1), with an active xenon mass of about 10 kg at 15 bar, is the first NEXT prototype installed at Canfranc Underground Laboratory (LSC). It implements the NEXT detector concept tested in smaller prototypes using the same radiopure sensors and materials that will be used in the future NEXT-100, serving as a benchmark for technical solutions.




Figure 1: NEW detector

The NEW detector is fully operational at LSC. A low background run using depleted Xe is foreseen

*Corresponding author (vicente.alvarez@ific.uv.es)

during 2018; these data will be essential to validate the background model of NEXT-100, based on the radiopurity measurements of all the relevant components.

A background of 4×10^{-4} counts $\text{keV}^{-1} \text{kg}^{-1} \text{y}^{-1}$ in the energy region of interest means the experiment is sensitive to a half life of up to 6×10^{25} years after running for 3 effective years [3, 4]. The required background level is achievable thanks to passive shielding, background discrimination techniques based on charged particle tracking [3, 5] and a thorough material radiopurity control.

The energy plane of NEW consists of a 12 cm thick copper support plate with 12 sapphire windows brazed in copper flanges and then screwed to the copper plate (figure 2). A 12 cm thick copper cap is placed behind each PMT, to shield the fiducial volume. The energy plane will be held at vacuum levels of less than 10^{-4} mbar. The twelve R11410-10 [6] PMTs from Hamamatsu are optically coupled to the sapphire windows using NyoGel OCK-451, and held in place with a plastic support and spring. The external face of the windows is coated with tetraphenyl-butadiene (TPB) to shift the xenon VUV light to blue and coated with PDOT (poly(3,4-ethylenedioxythiophene)), a conductive polymer which stops the electric field from the TPC penetrating as far as the PMT dynodes. The twelve PMTs are located 12 cm behind the TPC cathode and cover approximately 30% of its surface area. This level of coverage was chosen as a compromise between the need to collect as much light as possible and the need to minimize the number of sensors to reduce cost, technical complexity and radioactivity. The selected model R11410-10 is a 3" PMT specially developed for low-background operation, equipped with a synthetic fused silica window and a photocathode made of low temperature bialkali with high quantum efficiency.

The PMTs receive high voltage and have their signal extracted via kapton twisted cables connected to a feedthrough in the torispherical head of the pressure vessel. The distribution of signal and supply at each individual PMT is done by means of a Kapton circuit board (PMT base) which is covered with a copper cap and filled with epoxy. PMT bases are connected to the support plate to allow generated heat to be dissipated under vacuum




Figure 2: Energy plane detail

conditions.

The most important design requirement for the energy plane is linearity over the whole dynamic range. In terms of linearity the worst situation is for long signals which could extend for more than 100 microseconds. In this case, the PMT base circuit must provide enough charge for the PMT with negligible change in dynode-to-dynode voltage. Changes in these voltages introduce a time varying gain which acts as a nonlinear distortion mechanism and has a strong effect on PMT behaviour and linearity..

2. PMT base circuit

The design is made more challenging due to the required trade-off between radiopurity and linearity. The size and number of components must be carefully studied and limited so that the radioisotope budget is not exceeded without compromising the linearity of the PMT response and, thus, the final energy resolution.

Moreover the whole structure must be connected to earth for electrical safety reasons, which implies a PMT grounded cathode connection scheme. In such a configuration the anode output must be AC coupled through an isolation capacitor since anode output DC voltage equals the high voltage (HV) being applied to the PMT (figure 3). As a consequence the AC coupling capacitor must be




Figure 3: Grounded Cathode PMT connection scheme




Figure 4: Simulation of temperature in Comsol Multiphysics

able to cope with the HV needed to provide the required gain in the PMT (typically from 1000 V to 1750 V).

The maximum allowable amount of heat to be dissipated by each base so that no disturbances are introduced in the rest of the detector has been established in 40 mW. In order to achieve this in vacuum they will be encased in thermal epoxy (Araldite 2011®) and connected via a copper cap to the support. This limit has been found through simulation in a finite element software (COMSOL) and verified in a test bench where a EP temperature of 24 °C was achieved with 21 °C of ambient temperature.

Using scheme shown in figure 3 with the static power constrain in mind, a lower limit for the sum of all the series resistor can be found. Since the manufacturer recommends a set o resistor ratios, the values for base resistors are shown in table (1). In order to increase linearity and provide the




Figure 5: LED based PMT+FEE test bench for linearity measurements

dynodes of the PMT with the required currents a certain number of resistor chain stages need to be backed by capacitors. An algorithm to find this number and capacitor values will be presented in next section.

2.1. Test bench for linearity measurements

A test bench for linearity measurements was developed in order to test each component under NEW energy plane conditions. The test includes not only a PMT (with its base) but also the associated front-end electronics (FEE) due to the special characteristics of the signals captured and the high linearity required. The dynamic range of every channel must cover from a single photon up to 100k photons. Moreover, signal length in NEXT can vary from a few microseconds up to ~150 μ s which presents an additional challenge to electronics design.

The linearity test bench makes use of a signal generator which introduces a voltage square pulse with very short rise and fall edges into the LED (435 nm centered radiation spectrum). The amount of photons being generated is proportional to the length of the pulse. In order to avoid LED switching effects the minimum pulse length is 20 μ s (the setting time of the LED is in order of 1 μ s). The effect of LED output fluctuation is limited by averaging over 200 samples for each device under test. Additionally, a set of 90% attenuation optical filters were used directly coupled to the LED.

PMT bias voltage was established through a trade-off between single photon detection capability and manufacturer recommended high voltage (HV) range for best linearity. In order to achieve sufficient SNR, electronics induced noise must be reduced. This imposes a practical limit to the




Figure 6: Base Circuit. Capacitor sizing procedure

amplifier's gain and demands the use of high-gain PMTs.

The capacitors for the base were chosen using the algorithm described in figure 6 where the main goal is to get a worst case drop of 0.1% in voltage between dynodes. Since each stage increases the gain by a given factor (based on the geometry and characteristics of the PMT) the highest voltage drops will be located at the last stages where the amount of charge to be delivered by the PMT is higher. Therefore starting from the last PMT stage, a certain number of stages will be backed with capacitors.

In order to meet the radiopurity limits [3] a first proposal based on a minimum of 2 stage coverage (5 capacitors to withstand the high voltage between terminals) has been tested. Although generally this design shows good linearity there remain some long-pulse-length signals with non-linear distortion in time (figure 7). The output signal does not show a typical overload effect which would appear in the case of a usual fall in the gain




Figure 7: Linearity of the PMT base with 2 stage capacitors (5 units). 80us pulse

value for high number of photons. The observed behaviour is related to a distortion mechanism that appears due to charge redistribution in the base capacitors. It is possible for a capacitor which has been depleted to drain charge from the capacitor previous to it in the chain. If the charge drained by the former is too high, voltage drops accumulate, affecting overall gain. The length of signal pulse able to generate this distortion depends on the time constants of each stage and may change with voltage distribution among stages.

The measured linearity ¹ is 1.95% for 100k photo electrons. This means that a better capacitor coverage is required so a 3 stage coverage is proposed (figure 8). This circuit shows virtually no time distortion. The linearity fit gives a 0.38% for 140k pe. which exceeds the initial requirements for linearity (less than 1%).

3. Front-end electronics

Front-End Electronics (FEE) and complementary Digital Signal Processing (DSP) techniques will be described in this section. Also data measurements taken in order to verify FEE behavior and validate DSP techniques will be presented.

¹Measured as the worst case deviation from the linear fit




Figure 8: Base Circuit layout




Figure 9: Grounded Cathode Equivalent Circuit and Frequency response


3.1. Grounded cathode

The use of an AC coupling scheme implies a high pass filter (HPF) will be created. Such a filter blocks DC component and attenuates frequency components below the cutoff frequency (f_{cutoff}). The whole model of FEE includes last stage effect of the base ((R2 parallel with C1) + R1) by the pseudodifferential connection. To reduce the complexity we assume R2 is much higher and we eliminate it. Figure 9 shows the electrical equivalent circuit of the connection scheme with a simple current source model as the PMT. The Laplace transfer function of the whole system can be obtained as: (eq. 1)


$$\frac{v_O}{i_I} = A \frac{Z_{in} R_1}{Z_{in} + R_1} \frac{(R_1 + Z_{in}) C s}{1 + (R_1 + Z_{in}) C s} \quad (1)$$

$$f_{cutoff} = \frac{1}{(R_1 + Z_{in}) C_2 \cdot 2\pi} \quad (2)$$

PMT base capacitors can exchange some charge with the coupling capacitor, so they should be included in the model. Using an equivalent circuit shown in figure 10 (a) which can be even further simplified (b), the equations shown in eq. 3 arise. Thus the original high pass filter turns into a pole/zero combination as shown in the



(a) FEE + PMT base



(b) FEE + PMT base simplified

Figure 10: FEE Full model.




Figure 11: FEE Full Frequency Response for high τ solution.

low frequency range of the final FEE frequency response.

$$\frac{v_O}{i_I} = \frac{Z_{in}}{(1 + \frac{C_1}{C_2})} \frac{1 + R_1 C_1 s}{1 + \frac{(R_1 + Z_{in}) C_1}{(1 + \frac{C_1}{C_2})} s} \quad (3)$$

3.2. High τ constant value solution

Since the τ (time constant) of the equivalent circuit shown in figure 11 is proportional to the inverse of f_{cutoff} , a higher τ will attenuate a shorter range of frequencies producing a signal which closely resembles the original one. However there is a problem with the implementation of this solution: good quality AC coupling capacitors that can withstand high voltages typically have low nominal values. It is hard to find capacitors higher than ~ 10 nF that meet such specifications forcing the use of high value resistors.

Such high value resistors may amplify low frequency components as shown in eq. 3. This effect will translate into additional baseline shifts or baseline wandering.

3.3. Digital Baseline Restoring alternative

Our proposal for this novel FEE design is to reduce the value of the R1 resistor. This would bring a wide swing in the baseline but it can be accurately recovered using a Digital Signal Processing algorithm once the AC coupled signal

has been acquired. The decision has been taken based on the results shown in the previous section: extremely high resistor values gave results too close to the energy resolution limits, and second order effects related to components parasitics might have a strong influence on final results. Moreover high impedance nodes such as the associated to high resistors are more sensitive to coupled external noise. As a result, a trade-off between low frequency effects suppression and feasibility of signal recovery has been established. The lower the f_{cutoff} the easier to recover the AC coupled signal but the higher the vulnerability to low frequency noise and baseline random walks that can have a very negative effect on energy resolution computation in long signals. A value of $R_1 = 1600 \Omega$ has been chosen which gives a $f_{cutoff} = 10$ kHz. This should attenuate most of the common noises related to electrical engines and other industrial environment elements. Higher f_{cutoff} frequencies would provide a better filtering effect but also would reduce SNR due to the loss in signal amplitude in AC coupled signals.

Noise has been one of the most important specifications, carefully studied from the beginning in order to enhance energy resolution results. The active components in the FEE have been chosen mainly relying on their noise specs. The bandwidth of the FEE (3 MHz) has been chosen to make it work as a shaping filter, stretching the time length of the single photo-electron (SPE) response that was provided as a specification by the team in charge of the detector calibration. The SPE must be wider to can measure better with our sampling frequency.

A simplified version of the FEE is shown in figure 12. A pseudo-differential transmission has been chosen in order to reduce coupled noise which is expected to be high, since the distance between the FEE rack and the vessel is about 12 m. The AC coupled transmission enables the injection of the high voltage supply to the PMTs through the same signal cable. Assuming C2 AC coupling capacitor has a self resonant frequency (SRF) higher than the maximum estimated bandwidth of the FEE, the line termination (120Ω) will be implemented at Z_{in} . This design choice also allows to terminate the common mode signal that travels along the transmission line and is expected to be quite high since a non-fully-differential transmission




Figure 12: Simplified FEE Scheme

is being used. The common mode termination is implemented at the amplifier input (π type termination with RA and RB).

Mirror capacitor C1 acts as base stabilizers in order to further enhance linearity in the PMT, so they should have a value similar to the PMT base capacitors.

3.4. Noise Measurements

In order to verify if the design specifications are met, noise measurements carries out both at testbench and at the LSC NEXT installation. The results are shown in the table 1.

Noise specs have been fulfilled with a worst case total noise of 0.8 LSB. The theoretically computed noise of the FEE was 0.35 LSB without power supply contribution. The indirectly measured FEE noise contribution is 0.36 LSB which is really close to specifications. Since the FEE is quite lower than the DAQ system contribution the design has accomplished its main goal. An improvement in noise specs probably would require a new DAQ system design.

3.5. Front-end electronics model for simulation

Once the design has been validated through real measurements it is important to build a simulation model which can help in the development of other parts of the project. This time the model has a high level of abstraction in order to be easily integrated with the software analysis modules, Python language with help of Numpy-Scipy libraries. The model comprises two different elements: the low frequency range which has already been developed (eq. 3) plus a fourth order




Figure 13: FEE Full Frequency Response.

low pass filter (due to the required shaping) with the right gain factor. The model response has been checked against SPICE simulations of the implemented FEE (figure 13).

Noise generation is introduced in the system to resemble the noise behavior of the real system, taking into account the filtering effect of every part. This is to say that for instance, the input equivalent noise of the FEE has been increased to simulate the observed effect given the 3 MHz bandwidth. The noise equivalent model of the FEE is shown in fig. 14 as well as the noise equations relative to the different noise contributions:

$$GAIN = FEE_{GAIN}.DAQ_{GAIN} \quad (4)$$

$$v_{T_n}^2 = v_{DAQ_n}^2(out) + v_{F+P_n}^2(out) \quad (5)$$

$$\begin{aligned}
v o_{Tn}^2 &= \int_0^{BW=3MHz} v_{F+Pn}^2 |G.H(jw)|^2 \quad (6) \\
&+ \int_0^{BW=20MHz} v_{DAQn}^2 |DAQ_G.H(jw)|^2 \quad (7)
\end{aligned}$$

$$v_{OTn(rms)} = \sqrt{v_{OTn}^2} = 0.76LSB_{rms} \quad (8)$$

Where total Gain is the FEE gain multiplied by adquisition system gain. Moreover, the total noise ($vo_{T_n}^2$) is the DAQ out noise ($v_{DAQn}^2(out)$) plus the noise of the FEE and the PMT base ($v_{F+Pn}^2(out)$).

Table 1: Noise Measurements (in LSB_{rms})

		IFIC Laboratory	LSC NEXT
Direct Measurement	DAQ Sys.	0.64	0.66
	FEE + ATCA	0.75	0.75
	FEE + ATCA + PMT	0.76	0.8
Indirect Measurement	FEE	0.39	0.36
	PMT	0.12	0.28




Figure 14: Noise generation scheme

3.6. Digital Baseline Restoration procedure

The design trade-off chosen for this solution allowed a more relaxed FEE design, less prone to low frequency issues and less noisy in general relying on a Digital Signal Postprocessing (DSP) to recover the baseline distortion introduced by the AC coupling capacitor. The DSP algorithm is based on the implementation of a inverse function of a first order high pass filter (HPF). The impulse response of this inverse function has a structure composed of a delta in the origin plus a step function whose amplitude equals the value of $\frac{1}{\tau}$ where τ is $(R_1 + Z_{in}) \cdot C$ (eq. 10). This means that the convolution operation can be carried out using just an accumulator and a multiplier instead of a FIR filter.

$$HPF^{-1}(s) = 1 + \frac{1}{\tau \cdot s} \quad (9)$$

$$HPF^{-1}(t) = \delta(t) + \frac{1}{\tau} \int_0^t dt \quad (10)$$

An interesting advantage of this algorithm is that it doesn't have to work continuously, it only has to be activated when a pulse is detected and can be switched off when the pulse ends. This means that an important amount of low frequency noise filtered by the AC coupling capacitor will not be restored since it is slower than the pulse length.

However, the low frequency zero introduced by the PMT base interaction adds a low amount of DC to the theoretically AC coupled output signal of the FEE. In order to nullify this effect a high pass filter (cleaning filter) with a cutoff frequency equal to the frequency of this zero is introduced previous to the Digital BaseLine Restoration (DBLR) algorithm. This completely cancels the DC effect so that the reconstructed signal shows no baseline shift at the end.

Since the BLR algorithm uses an accumulator, it might be sensitive to noise and its effects must be studied not only as simple noise equivalent but also taking into account the effect of different frequency components. In case a non zero mean noise appears, the accumulator might get saturated. Typically the accumulator should end the deconvolution process in an empty state, however, the residue low frequency components of the noise makes a small residue remain in the accumulator at the end. Due to finite sampling of the signals residue is not always random. For instance in a burst of short signals (photoelectrons) this residue tends to be positive because the pulses have a higher positive lobe. As a consequence the accumulator starts to rise without limit introducing a baseline shift in the output signal.

This novel DBLR algorithm introduces a control based on a smoothing function to deplete the residue remaining in the accumulator after a pulse reconstruction. The algorithm flowchart is shown in figure 15. In this algorithm the reconstruction process is started independently from the pulse start, and can be working indefinitely. The control relies on the accumulator operations that can be *Update* or *Discharge*. When the DAQ signal rises above a threshold or the accumulator value is above another threshold (which is the condition for an active pulse) the accumulator is updated as in

the original algorithm. However, when none of those conditions are met, which means that there is no active signal pulse, the accumulator is forced to a controlled discharge state. This discharge operation is carried out following a smooth curve so that the reconstructed signal shows no jumps or discontinuities.




Figure 15: Accumulator based BLR

4. Data acquisition system implementation

In the NEXT experiment Data Acquisition System (DAQ), FPGA-based DAQ modules work in free-running mode, storing data continuously in a circular buffer, while an DAQ Trigger module processes trigger candidates received, generating a trigger accept signal that causes data to be sent to a PC farm [7]. Trigger candidates are generated for each PMT channel in the DAQ Data modules, since each PMTs channel is able to sense the primary and/or the secondary scintillation light produced in the chamber. The trigger candidates' generation is based on the early energy estimation of the events, which requires at the same time a stable baseline [8]. As a consequence digital baseline restoration must be implemented online.

A similar version of the DBLR algorithm, introduced in subsection 3.6 and shown on figure 15 has been implemented. This DBLR block is activated whenever the input signal rises above a threshold thus producing an output signal with its baseline completely restored. The threshold is defined using signal baseline as a reference which requires a precise on-line baseline computation mechanism. A moving average filter has been used in this implementation. In order to avoid baseline shifts due to residues remaining in the accumulator, and further simplify the logic and use of FPGA resources in the DAQ and trigger modules, the control mechanism makes use of a simple linear smoothing function. As in the original algorithm, in case the accumulator is not completely empty when the reconstruction process ends, it must be automatically flushed.

The DBLR algorithm has been implemented in a Xilinx Virtex-6 FPGA (XC6VLX240T-1ff1156). There is a DBLR block per channel (12 PMT channels per ATCA-FEC module), and a preceding cleaning filter, both configurable. The implemented algorithm and the cleaning filter have been implemented in a 42-bit fixed point format (Q11.30). The format has been selected as a tradeoff between algorithm stability and physical resources used.

5. Conclusion

Finally the PMT base was designed and fabricated with the balance between the best possible response and radiopurity. After all the materials involved in the base were screened, we conclude that the level of radiopurity is good for us. This way we accomplish the radiopurity requirements as well as the electronics requirements.

Regarding the front-end electronics, we simulated, designed, manufactured, mounted, tested and we obtained the results that we expected. Once the electronics results were validated as good, we proceeded to build a simulation model. After that, we started with the digital baseline restoration process.

The digital baseline reconstruction approach

has been designed to reduce front-end electronics complexity thus improving its performance in terms of noise and linearity. Therefore the baseline recovery operation is computed in the digital domain where signal to noise ratio gets hardly affected.

Excellent results have been achieved in terms of noise and linearity with acceptable radiopurity levels. Figure 16 shows linearity measurements for the whole front-end including PMT (with its base), FEE and acquisition system. A set of light pulses with constant amplitude and variable length were used.





Figure 16: Linearity of the NEW base = 0.38% (140kpe)


Figure 17 shows a real PMT signal with AC coupling effects (a) and the resulting signal after DBLR has been applied (b)

6. Acknowledgments

The NEXT Collaboration acknowledges support from the following agencies and institutions: the European Research Council (ERC) under the Advanced Grant 339787-NEXT; the Ministerio de Economía y Competitividad of Spain under grants FIS2014-53371-C04; the GVA of Spain under grant PROMETEO/2016/120; the Portuguese FCT and FEDER through the program COMPETE, project PTDC/FIS/103860/2008; the U.S. Department of Energy under contracts number DE-AC02-07CH11359 (Fermi National Accelerator



(a) Blue - Real input signal; Orange - FEE output signal



(b) Digital baseline reconstruction applied

Figure 17: Signal of 50us pulse. 25865 pe. Noise 0.74 LSB

Laboratory) and DE-FG02-13ER42020 (Texas A&M); and the University of Texas at Arlington and special thanks to the Laboratorio subterráneo de Canfranc.

References

- [1] V. Álvarez, F. I. G. M. Borges, S. Cárcel, et al., Next-100 technical design report (tdr). executive summary, Journal of Instrumentation 7 (06) (2012) T06001.
 URL <http://stacks.iop.org/1748-0221/7/i=06/a=T06001>
- [2] Laboratorio subterráneo de canfranc.
 URL <http://www.lsc-canfranc.es/es/>
- [3] J. Martín-Albo, J. Muñoz Vidal, P. Ferrario, et al., Sensitivity of next-100 to neutrinoless double beta decay, Journal of High Energy Physics 2016 (5) (2016) 159.
 doi:10.1007/JHEP05(2016)159.
 URL [https://doi.org/10.1007/JHEP05\(2016\)159](https://doi.org/10.1007/JHEP05(2016)159)
- [4] V. Álvarez, I. Bandac, A. Bettini, et al., Radiopurity control in the next-100 double beta decay experiment: procedures and initial measurements, Journal of Instrumentation 8 (01) (2013) T01002.
 URL <http://stacks.iop.org/1748-0221/8/i=01/a=T01002>
- [5] J. Renner, A. Farbin, J. M. Vidal, et al., Background rejection in next using deep neural networks, Journal of Instrumentation 12 (01) (2017) T01004.
 URL <http://stacks.iop.org/1748-0221/12/i=01/a=T01004>
- [6] Hamamatsu photonics, r11410-10 data sheets. (2011).
 URL <http://www.hamamatsu.com/eu/en/product/category/3100/3001/index.html>
- [7] R. Esteve, J. Toledo, J. Rodríguez, M. Querol, V. Álvarez, Readout and data acquisition in the next-new detector based on srs-atca, Journal of Instrumentation 11 (01) (2016) C01008.
 URL <http://stacks.iop.org/1748-0221/11/i=01/a=C01008>
- [8] R. Esteve, J. Toledo, F. Monrabal, et al., The trigger system in the next-demo detector, Journal of Instrumentation 7 (12) (2012) C12001.
 URL <http://stacks.iop.org/1748-0221/7/i=12/a=C12001>