ASPEN
Building foundations for the future

ASPEN/BEE/06/2023-24 **Date: 08/01/2024**

To,
The Project Engineer
Bureau of Energy Efficiency (Ministry of Power, Government of India)
4th Floor, Sewa Bhawan
R.K. Puram, Sector-1
New Delhi-110066

Respected Sir/ Madam,

Subject: **Energy Accounting Report (July to Sept. 2023) from ASPEN DCRN. DIS0047GJ**

Dear Sir/ Madam,

With respect to above referred letter and subject matter, please find hard copies of following documents:

Q-2 (July-Sept.2023) Energy Accounting report

Please acknowledge the same.
Yours faithfully,

Authorized Signatory

For AspenPark Infra Vadodara Private Limited
(Mr. Apurva Shah)

Enclosures: As referred above

Cc: Sr.Project Executive, 4th Floor, Block No.11-12, Udhyogbhavan, Sector-11, Gandhinagar -382017, India

General Information

1	**Name of the DISCOM**	AspenPark Infra Vadodara Private Limited		
2	**i) Year of Establishment**	2008		
	ii) Government/Public/Private	Private		
3	**DISCOM's Contact details & Address**			
i	City/Town/Village	Pipalya, Waghodiya		
ii	District	Vadodara		
iii	State	Gujarat	Pin	391760
iv	Telephone	02668-245301/02/03	Fax	NA
4	**Registered Office**			
i	Company's Chief Executive Name	Mr.Deep Bhatt		
ii	Designation	Director		
iii	Address	Survey No.26, Village:Pipaliya, Ta.Waghodia		
iv	City/Town/Village	Vadodara	P.O.	391760
v	District	Vadodara		
vi	State	Gujarat	Pin	391760
vii	Telephone	02668-245301/02/03	Fax	NA
5	**Nodal Officer Details***			
i	Nodal Officer Name (Designated at DISCOM's)	**Mr.Apurva Shah**		
ii	Designation	Head - SEZ		
iii	Address	AspenPark Infra Vadodara Private Limited		
iv	City/Town/Village	Pipalya, Waghodiya	P.O.	NA
v	District	Vadodara		
vi	State	Gujarat	Pin	391760
vii	Telephone	8155889990	Fax	NA
6	**Energy Manager Details***			
i	Name	Jalpesh Panchal		
ii	Designation	Senior Manager-Technical	Whether EA or EM	NA
iii	EA/EM Registration No.	NA		
iv	Telephone	02668-245301/02/03	Fax	NA
v	Mobile	9714877447	E-mail ID	jalpesh@aspensez.in
7	**Period of Information**			
	Year of (FY) information including Date and Month (Start & End)	1st July-2023 to 30th September-2023		

Performance Summary of Electricity Distribution Companies			
1	Period of Information Year of (FY) information including Date and Month (Start & End)	1st July-2023 to 30th September-2023	
2	**Technical Details**		
(a)	**Energy Input Details**		
(i)	Input Energy Purchase (From Generation Source)	Million kwh	1.63
(ii)	Net input energy (at DISCOM Periphery after adjusting the transmission losses and energy traded)	Million kwh	1.63
(iii)	Total Energy billed (is the Net energy billed, adjusted for energy traded))	Million kwh	1.59
(b)	Transmission and Distribution (T&D) loss Details	Million kwh	0.05
		%	2.96%
	Collection Efficiency	%	100%
(c)	Aggregate Technical & Commercial Loss	%	3%

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal

Name of Authorised Signatory Mr. Anand Shah
Name of the DISCOM:
Full Address:-

AspenPark Infra Vadodara Pvt. Ltd.
Village: Pipariya & Ajwa,
Tal. Vaghodia, Dist. Vadodara
Vadodara-391 760

Seal

Signature:-
Name of Energy Manager*: Jalpesh Panchal
Registration Number: — NA —

Form-Details of Input Infrastructure

1	Parameters	Total	Covered during in audit	Verified by Auditor in Sample Check	Remarks (Source of data)
i	Number of circles	0	0	0	NA
ii	Number of divisions	0	0	0	NA
iii	Number of sub-divisions	0	0	0	NA
iv	Number of feeders	4	4	4	Feeder logbook data
v	Number of DTs	5	5	5	-
vi	Number of consumers	6	6	6	-
2	**Parameters**	**66kV and above**	**33kV**	**11/22kV**	**LT**
a. i.	Number of conventional metered consumers	0	2	3	1
ii	Number of consumers with 'smart' meters	0	0	0	0
iii	Number of consumers with 'smart prepaid' meters	0	0	0	0
iv	Number of consumers with 'AMR' meters	0	0	0	0
v	Number of consumers with 'non-smart prepaid' meters	0	0	0	0
vi	Number of unmetered consumers	0	0	0	0
vii	**Number of total consumers**	0	2	3	1
b.i.	Number of conventionally metered Distribution Transformers	0	4	1	0
ii	Number of DTs with communicable meters	0	0	0	0
iii	Number of unmetered DTs	0	0	0	0
iv	**Number of total Transformers**	0	4	1	0
c.i.	Number of metered feeders	0	4	0	0
ii	Number of feeders with communicable meters	0	0	0	0
iii	Number of unmetered feeders	0	0	0	0
iv	**Number of total feeders**	0	4	0	0
d.	Line length (ct km)	0.703			
e.	Length of Aerial Bunched Cables	0			
f.	Length of Underground Cables	2			

3	Voltage level	Particulars	MU	Reference	Remarks (Source of data)
i	66kV and above	Long-Term Conventional	2	Includes input energy for franchisees	
		Medium Conventional			
		Short Term Conventional			
		Banking			
		Long-Term Renewable energy			
		Medium and Short-Term RE		Includes power from bilateral/ PX/ DEEP	
		Captive, open access input		Any power wheeled for any purchase other than sale to DISCOM. Does not include input for franchisee.	
		Sale of surplus power			
		Quantum of inter-state transmission loss		As confirmed by SLDC, RLDC etc	
		Power procured from Inter-state sources	2	Based on data from Form 5	
		Power at state transmission boundary	2		
ii	33kV	Long-Term Conventional	0		
		Medium Conventional			
		Short Term Conventional			
		Banking			
		Long-Term Renewable energy			
		Medium and Short-Term RE			
		Captive, open access input			
		Sale of surplus power			
		Quantum of intra-state transmission loss	0		
		Power procured from Intra-state sources	0		
iii		**Input in DISCOM wires network**	1.634		
iv	33 kV	Renewable Energy Procurement			
		Small capacity conventional/ biomass/ hydro plants Procurement			
		Captive, open access input			
v	11 kV	Renewable Energy Procurement			
		Small capacity conventional/ biomass/ hydro plants Procurement			
		Sales Migration Input			
vi	LT	Renewable Energy Procurement			
		Sales Migration Input			
vii		**Energy Embedded within DISCOM wires network**	0		
viii		**Total Energy Available/ Input**	1.634		
4	**Voltage level**	**Energy Sales Particulars**	**MU**	**Reference**	
i	LT Level	DISCOM' consumers	0	Include sales to consumers in franchisee areas, unmetered consumers	
		Demand from open access, captive		Non DISCOM's sales	
		Embedded generation used at LT level		Demand from embedded generation at LT level	
		Sale at LT level	0		
		Quantum of LT level losses	0		
		Energy Input at LT level	0.017		
ii	11 kV Level	DISCOM' consumers	1	Include sales to consumers in franchisee areas, unmetered consumers	
		Demand from open access, captive	0	Non DISCOM's sales	
		Embedded generation at 11 kV level used	0	Demand from embedded generation at 11kV level	
		Sales at 11 kV level	0.814		
		Quantum of Losses at 11 kV	0		
		Energy input at 11 kV level	0.826		
iii	33 kV Level	DISCOM' consumers	1	Include sales to consumers in franchisee areas, unmetered consumers	
		Demand from open access, captive		Non DISCOM's sales	
		Embedded generation at 33 kV or below level		This is DISCOM and OA demand met via energy generated at same voltage level	
		Sales at 33 kV level	0.755		
		Quantum of Losses at 33 kV	0		
		Energy input at 33kV Level	0.792		
iv	> 33 kV	DISCOM' consumers	0	Include sales to consumers in franchisee areas, unmetered consumers	
		Demand from open access, captive		Non DISCOM's sales	
		Cross border sale of energy			
		Sale to other DISCOMs			
		Banking			
		Energy input at > 33kV Level	0.000		
		Sales at 66kV and above (EHV)	0.000		
		Total Energy Requirement	1.634		
		Total Energy Sales	1.586		

Energy Accounting Summary

5	DISCOM	Input (In MU)	Sale (In MU)	Loss (In MU)	Loss %
i	LT	0.016827	0.016827	0	0
ii	11 Kv	0.8259037	0.8139	0.0120037	1.453401892
iii	33 kv	0.7915088	0.7552	0.0363088	4.587289491
iv	> 33 kv	0	0	0	0
6	**Open Access, Captive**	**Input (In MU)**	**Sale (In MU)**	**Loss (In MU)**	Not Applicble
i	LT				
ii	11 Kv				
iii	33 kv				
iv	> 33 kv				

Loss Estimation for DISCOM	
T&D loss	0
D loss	0
T&D loss (%)	0.02956268
D loss (%)	0.02956268

Details of Division Wise Losses (See note below**)

Division Wise Losses

Period From.1st July 2023 To 30th Sept.2023

S.No	Name of circle	Circle code	Name of Division	Consumer profile: Consumer category	No of connection metered (Nos)	No of connection Un-metered (Nos)	Total Number of connections (Nos)	% of number of connections	Connected Load metered (MW)	Connected Load Un-metered (MW)	Total Connected Load (MW)	% of connected load	Energy parameters: Input energy (MU)	Billed energy (MU): Metered energy	Billed energy (MU): Unmetered/assessment energy	Billed energy (MU): Total energy	% of energy consumption	Losses: T&D loss (MU)	Losses: T&D loss (%)	Commercial Parameter: Billed Amount in Rs. Crore	Collected Amount in Rs. Crore	Collection Efficiency	AT & C loss (%)
1	AIVPL	NA	NA	Residential	0	0	0	0%	0	0	0	0%	1.63424	0	0	0	0%	0.048313	3%	0	0	0.00%	
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0	0.00%	
				Commercial/Industrial-LT	1	0	1	17%	0.0185	0	0.0185	0%		0.016827	0	0.016827	1%			0.01810583	0.01810583	100.00%	
				Commercial/Industrial-HT	5	0	5	83%	13.925	0	13.925	100%		1.5691	0	1.5691	99%			1.69144553	1.69144553	100.00%	
				Others	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0	0.00%	
Sub-total					6	0	6	100%	13.9435	0	13.9435	100%	1.63424	1.585927	0	1.585927	100%	0.048313	3%	1.70955136	1.70955136	100.00%	2.96%

76	Total		Residential	0	0	0	0%	0	0	0	0%	1.63424	0	0	0	0%	0.048313	3%	0	0	0.00%	
			Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0	0.00%	
			Commercial/Industrial-LT	1	0	1	17%	0.0185	0	0.0185	0%		0.016827	0	0.016827	1%			0.01810583	0.01810583	100.00%	
			Commercial/Industrial-HT	5	0	5	83%	13.925	0	13.925	100%		1.5691	0	1.5691	99%			1.69144553	1.69144553	100.00%	
			Others	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0	0.00%	
77	At company level			6	0	6	100%	13.9435	0	13.9435	100%	1.63424	1.585927	0	1.585927	100%	0.048313	3%	1.70955136	1.70955136	100.00%	2.96%

** Note - It shall be mandatory to record the energy supplied separately for each category of consumers which is being provided a separate rate of subsidy in the tariff, by the state government, so that the subsidy due for the electricity distribution company is quarterly calculated by multiplying the energy supplied to each of such category of consumers by the applicable rate of subsidy notified by the state government.

Colo r code	Parameter
	Please enter name of circle
	Please enter circle code
0	Please enter numeric value or 0
	Formula protected

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal

Signature:-
Name of Energy Manager: Jaipesh Panchal
Registration Number: — NA —

Name of Authorised Signatory: Mr. Apurva Shah

Name of the DISCOM: AspenPark Infra Vadodara Pvt. Ltd.
Full Address:- Village: Pipariya & Ajwa, Tal. Vaghodia, Dist. Vadodara Vadodara-391 760.

Seal

Form-Input energy(Details of Input energy & Infrastructure)

A. Summary of energy Input & Infrastructure

S.No	Parameters	Period 1st July 2023 To 30th Sept.2023	Remarks (Source of data)
A.1	Input Energy purchased (MU)	1.63424	MGVCL Bills
A.2	Transmission loss (%)	0%	No intra state / Inter state transmission losses
A.3	Transmission loss (MU)	0	
A.4	Energy sold outside the periphery(MU)	0	
A.5	Open access sale (MU)	0	
A.6	EHT sale	0	We are not selling energy outside the periphery
A.7	Net input energy (received at DISCOM periphery or at distribution point)-(MU)	1.63	Purchase and Input energy is same
A.8	Is 100% metering available at 66/33 kV (Select yes or no from list)	Yes	
A.9	Is 100% metering available at 11 kV (Select yes or no from list)	Yes	
A.10	% of metering available at DT	100%	
A.11	% of metering available at consumer end	100%	
A.12	No of feeders at 66kV voltage level	0	
A.13	No of feeders at 33kV voltage level	4	2500 KVA 33/11KV TR-07 Nos.
A.14	No of feeders at 11kV voltage level	0	
A.15	No of LT feeders level	0	
A.16	Line length (ckt. km) at 66kV voltage level	0	
A.17	Line length (ckt. km) at 33kV voltage level	1.5	Approximated length of Underground cable
A.18	Line length (ckt. km) at 11kV voltage level	1.2	Approximated combined length of Underground cable
A.19	Line length (km) at LT level	0	
A.20	Length of Aerial Bunched Cables	0	
A.21	Length of Underground Cables	0	
A.22	HT/LT ratio	0	

B. Meter reading of Input energy at injection points

S.No	Zone	Circle	Voltge Level (KVA)	Division (KVA)	Sub-Division (KVA)	Feeder ID	Feeder Name	Feeder Metering Status (Metered/ unmetered/ AMI/AMR)	Status of Meter (Functional/Non-functional)	Metering Date	Feeder Type (Agri/ Industrial/Mixed)	Status of Communication			Period from...to...				Sales	Remarks (Source of data)
										Date of last actual meter reading/ communication		% data received through automatically if feeder AMR/AMI	Number of hours when meter was unable to communicate in period	Total Number of hours in the period	Meter S.No	CT/PT ratio	Import (MU)	Export (MU)		
B.1	NA	NA	66 KV	NA	NA	NA	Aspen SEZ	Metered	Functional	NA	Industrial	NA	NA	NA	CHT 50456	CT Ratio 40/1	1.63	0.00	0.00	MGVCL Bills
B.2																				
B.3																				

B.13395			
B.13396			
B.13397			
B.13398			
B.13399			
B.13400			
B.13401	Total (MU)	1.63	0.00
B.13402	Net input energy at DISCOM periphery (MU)	1.63	

Color code	Parameter
	Please enter voltage level or leave blank
	Please enter feeder id and name or leave blank
	Enter meter no or leave blank
	Enter CT/PT ratio or leave blank
0	Please enter numeric value or 0
	Please select yes or no from list
	Formula protected

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal

Name of Authorised Signatory Mr. Apurva Shah
Name of the DISCOM:
Full Address: AspenPark Infra Vadodara Pvt. Ltd.
Village: Pipariya & Ajwa,
Tal. Vaghodia, Dist. Vadodara
Vadodara-391 760.

Seal AspenPark Infra Vadodara Pvt. Ltd.

Signature:-
Name of Energy Manager*: Jalpesh Panchal
Registration Number: — NA —

Details of Input Energy Sources

Period 1st July 2023 To 30th Sept. 2023

A. Generation at Transmission Periphery (Details)

S.No.	Name of Generation Station	Generation Capacity (In MW)	Type of Station Generation (Based- Solid (Coal ,Lignite)/Liquid/Gas/Renewable (biomass-bagasse)/Others)	Type of Contract (in years/months/days)	Type of Grid (Intra-state/Inter-state)	Point of Connection (POC) Loss MU	Voltage Level (At input)	Remarks (Source of data)
1	MGVCL	NA	DISCOM	NA	NA	0	66 kV	MGVCL
								is DISCOM

(Details of Consumers)						
Summary of Energy						
Period 1st July 2023 To 30th Sept. 2023						
S.No	Type of Consumers	Category of Consumers (EHT/HT/LT/Others)	Voltage Level (In Voltage)	No of Consumers	Total Consumption (In MU)	Remarks (Source of data)
1	Domestic					
2	Commercial	LT	440V	1	0.016827	Unit Holder Bills , LT Billing ca
3	IP Sets					
4	Hor. & Nur. & Coffee/Tea & Rubber (Metered)					
5	Hor. & Nur. & Coffee/Tea & Rubber (Flat)					
6	Heating and Motive Power					
7	Water Supply					
8	Public Lighting					
9	HT Water Supply					
10	HT Industrial	HT	33KV, 11KV	5	1.5691	Unit Holders and Self Bills
11	Industrial (Small)					
12	Industrial (Medium)					
13	HT Commercial					
14	Applicable to Government Hospitals & Hospitals					
15	Lift Irrigation Schemes/Lift Irrigation Societies					
16	HT Res. Apartments Applicable to all areas					
17	Mixed Load					
18	Government offices and department					
19	Others-1 (if any , specify in remarks)					
20	Others-2 (if any , specify in remarks)					
21	Others-3 (if any , specify in remarks)					
22	Others-4 (if any , specify in remarks)					
23	Others-5 (if any , specify in remarks)					
24						
25						
26						
27						
28						
29						
30						
31						
32						
33						
34						
35						
36						
37						
38						
39						
40						
			Total	6	1.59	

(Details of Feeder-wise losses)

Period 1st July 2023 To 30th Sept. 2023

Sl No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (In MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automatically (if feeder AMR/AMI)	Remarks
1	Aspen SEZ						Feeder 8	Industrial	Metered	0.7915088	0.7915088	0.7552	4.587289491	4.587289491	0	Internal data base
2	Aspen SEZ						Feeder 7	Industrial	Metered	0	0	0	0	0	0	Internal data base , Due to Fau
3	Aspen SEZ						Feeder 5/6	Industrial	Metered	0.8259037	0.8259037	0.8139	1.453401892	1.453401892	0	Internal data base