



General Information

1	Name of the DISCOM	Damodar Valley Corporation		
2	i) Year of Establishment	1948		
	ii) Government/Public/Private	Government		
3	DISCOM's Contact details & Address			
i	City/Town/Village	Kolkata		
ii	District	Kolkata		
iii	State	West Bengal	Pin	700054
iv	Telephone	033-66072141	Fax	
4	Registered Office			
i	Company's Chief Executive Name	Shri M Raghu Ram		
ii	Designation	Chairman		
iii	Address	DVC Tower, VIP Road, Kolkata, West Bengal - 700054		
iv	City/Town/Village	Kolkata	P.O.	Maniktala
v	District	Kolkata		
vi	State	West Bengal	Pin	700054
vii	Telephone	(033)2355-7935	Fax	
5	Nodal Officer Details*			
i	Nodal Officer Name (Designated at DISCOM's)	Arun Patra		
ii	Designation	Sr. General Manager		
iii	Address	1st Floor, Commercial Department, DVC Tower, VIP Road		
iv	City/Town/Village	Kolkata	P.O.	Maniktala
v	District	Kolkata		
vi	State	Kolkata	Pin	700054
vii	Telephone	(033)6607-2133	Fax	
6	Energy Manager Details*			
i	Name	Om Prakash		
ii	Designation	Senior Manager	Whether EA or EM	EA
iii	EA/EM Registration No.	EA-8622		
iv	Telephone		Fax	
v	Mobile	9955105415	E-mail ID	om.prakash1@dvc.gov.in
7	Period of Information			
	Year of (FY) information including Date and Month (Start & End)	1st July, 2023 - 30th September, 2023		

Performance Summary of Electricity Distribution Companies

1	Period of Information Year of (FY) information including Date and Month (Start & End)	1st July, 2023 - 30th September, 2023	
2	Technical Details		
(a)	Energy Input Details		
(i)	Input Energy Purchase (From Generation Source)	Million kwh	11444.49
(ii)	Net input energy (at DISCOM Periphery after adjusting the transmission losses and energy traded)	Million kwh	5241.50
(iii)	Total Energy billed (is the Net energy billed, adjusted for energy traded))	Million kwh	5132.15
(b)	Transmission and Distribution (T&D) loss Details	Million kwh	109.35
		%	2.09%
	Collection Efficiency	%	99%
(c)	Aggregate Technical & Commercial Loss	%	2.34%

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal		Signature:-	
Name of Authorised Signatory	Arun Patra	Name of Energy Manager*:	Om Prakash
Name of the DISCOM:	Damodar Valley Corporation	Registration Number:	EA-8622
Full Address:-	1st Floor, Commercial Department, DVC Towers, VIP Road, Kolkata-700054.		
Seal			

Form-Details of Input Infrastructure					
1	Parameters	Total	Covered during in audit	Verified by Auditor In Sample Check	Remarks (Source of data)
i	Number of circles	NA	NA	NA	
ii	Number of divisions	7	7	NA	Online Billing Portal
iii	Number of sub-station	37	37	NA	Online Billing Portal
iv	Number of feeders	163	163	NA	System Group
v	Number of DTs	61	61	NA	System Group
vi	Number of consumers	328	328	NA	Online Billing Portal
2	Parameters	66kV and above	33kV	11/22kV	LT
a. i.	Number of conventional metered consumers	0	0	0	0
ii	Number of consumers with 'smart' meters	0	0	0	0
iii	Number of consumers with 'smart prepaid' meters	0	0	0	0
iv	Number of consumers with 'AMR' meters	44	251	33	0
v	Number of consumers with 'non-smart prepaid' meters	0	0	0	0
vi	Number of unmetered consumers	0	0	0	0
vii	Number of total consumers	44	251	33	0
b.i.	Number of conventionally metered Distribution Transformers	NA	NA	NA	0
ii	Number of DTs with communicable meters		58	3	0
iii	Number of unmetered DTs	NA	NA	NA	0
iv	Number of total Transformers		58	3	0
c.i.	Number of metered feeders	27	133	3	0
ii	Number of feeders with communicable meters	NA	NA	NA	0
iii	Number of unmetered feeders	NA	NA	NA	0
iv	Number of total feeders	27	133	3	0
d.	Line length (ct km)	6516	1506	11.7	0
e.	Length of Aerial Bunched Cables	0	0	0	0
f.	Length of Underground Cables	0	0	2	0
3	Voltage level	Particulars	MU	Reference:	Remarks (Source of data)
i	66kV and above	Long-Term Conventional	540.73	Includes input energy for franchisees	
		Medium Conventional	0		
		Short Term Conventional	308.80		
		Banking	0		
		Long-Term Renewable energy	11.93		
		Medium and Short-Term RE	51.27	Includes power from bilateral/ PX/ DEEP	
		Captive, open access Input	251.36	Any power wheeled for any purchase other than sale to DISCOM, Does not include input for franchisee	
		UI Drawal	8.56		
		Sale of surplus power	0.00%		
		Quantum of inter-state transmission loss		As confirmed by SLDC, RLDC etc	
		Power procured from inter-state sources	1,172.64	Based on data from Form 5	
		Power at state transmission boundary	1,172.64		
		Gross Generation	11,065.23		
ii	33 kV	Unit Auxiliary Consumption	793.38		
		Units delivered to system from generation	10,271.85		
		Long-Term Conventional	0		
		Medium Conventional	0		
		Short Term Conventional	0		
		Banking	0		
		Long-Term Renewable energy	0		
		Medium and Short-Term RE	0		
		Captive, open access input	0		
		Sale of surplus power	0		
		Quantum of intra-state transmission loss	0		
		Power procured from intra-state sources	0		
		Input in DISCOM wires network	11,444.49		
iii		Renewable Energy Procurement	0		
iv	33 kV	Small capacity conventional/ biomass/ hydro plants Procurement	0		
v	11 kV	Captive, open access input	0		
		Renewable Energy Procurement	0		
		Small capacity conventional/ biomass/ hydro plants Procurement	0		
		Sales Migration Input	0		
vi	LT	Renewable Energy Procurement	0		
		Sales Migration Input	0		
		Energy Embedded within DISCOM wires network	0		
viii		Total Energy Available/ Input	11,444.49		

4	Voltage level	Energy Sales Particulars	MU	Reference	
i	LT Level	DISCOM' consumers	0	Include sales to consumers in franchisee areas, unmetered consumers	
		Demand from open access, captive	0	Non DISCOM's sales	
		Embedded generation used at LT level	0	Demand from embedded generation at LT level	
		Sale at LT level	0		
		Quantum of LT level losses	0		
		Energy input at LT level	0		
ii	11 kV Level	DISCOM' consumers	3,760	Include sales to consumers in franchisee areas, unmetered consumers	
		Demand from open access, captive	0	Non DISCOM's sales	
		Embedded generation at 11 kV level used	0	Demand from embedded generation at 11kV level	
		Sales at 11 kV level	3,760		
		Quantum of Losses at 11 kV	-3,760		
		Energy input at 11 kV level	0		
iii	33 kV Level	DISCOM' consumers	2,984.98	Include sales to consumers in franchisee areas, unmetered consumers	Substation Auxiliary & Colony consumption of 34.03 MU included
		Demand from open access, captive	0	Non DISCOM's sales	
		Embedded generation at 33 kV or below level	0	This is DISCOM and OA demand met via energy generated at same voltage level	
		Sales at 33 kV level	2,984.98		
		Quantum of Losses at 33 kV	-2,984.98		
		Energy input at 33kV Level	0.000000		
iv	> 33 kV	DISCOM' consumers	2143.41	Include sales to consumers in franchisee areas, unmetered consumers	
		Demand from open access, captive	277.76	Non DISCOM's sales	
		Cross border sale of energy	612.03	Sale to Bangladesh	
		Sale to other DISCOMs	5,313.20	Other DISCOM Sale as GENCO	
		Banking	0		
		Energy input at > 33kV Level	0.00	UI Drawal	
		Sales at 66kV and above (EHV)	8,346.40		
Total Energy Requirement			11,444.49		
Total Energy Sales			11,335.14		

Energy Accounting Summary

5	DISCOM	Input (in MU)	Sale (in MU)	Loss (in MU)	Loss %
i	LT	NA	0.00		
ii	11 Kv	NA	3.76		
iii	33 kv	NA	2984.98		
iv	> 33 kv	11,444.49	8346.40		
6	Open Access, Captive	Input (in MU)	Sale (in MU)	Loss (in MU)	Loss %
i	LT	NA	NA		
ii	11 Kv	NA	NA		
iii	33 kv	NA	NA		
iv	> 33 kv	NA	NA		

Loss Estimation for DISCOM

T&D loss	109.35
D loss	109.35
T&D loss (%)	2.09%
D loss (%)	2.09%

* Meter installation for measurement of Input Energy at substation level under SEMA Phase-II project is under progress. After completion of the same, T&D Loss and AT&C Losses will be provided in line with the BEB prescribed format.

Details of Division Wise Losses (See note below)**

Division-Wise Losses																										
Period From 01/07/2023 To 30/09/2023																										
S.No	Name of Substation	Circle code	Name of Division	Consumer category	Consumer profile				Energy parameters										Losses		Commercial Parameter			AT & C Loss (%)		
					No of connection metered (Nos)	No of connection Un-metered (Nos)	Total Number of connections (Nos)	% of number of connections	Connected Load metered (MW)	Connected Load Un-metered (MW)	Total Connected Load (MW)	% of connected load	Input energy (MU)	Metered energy	Unmetered/assessment energy	Total energy	% of energy consumption	T&D loss (MU)	T&D loss (%)	Billed Amount in Rs. Crore	Collected Amount in Rs. Crore	Collection Efficiency				
1	ASP		GOMD-I	Residential	0	0	0	0%	0	0	0	0%	72.9988	0	0	0	0%	0.49	1%	0.00	0.00	0.00%	3%			
				Agricultural	0	0	0	0%	0	0	0	0%	72.9988	0	0	0	0%	0.49	1%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	41.492	0	41.492	100%	72.9988	72.9988	0	72.9988	100%	0.49	1%	46.67	46.67	100.00%				
				Commercial/Industrial-HT	6	0	6	100%	41.492	0	41.492	100%	72.9988	72.9988	0	72.9988	100%	0.49	1%	46.67	46.67	100.00%				
Sub-total				0	0	0	0%	0	0	0	0%	72.9988	72.9988	0	72.9988	100%	0.49	1%	46.67	46.67	100.00%					
2	BARHI		GOMD-V	Residential	0	0	0	0%	0	0	0	0%	61.8463	0	0	0	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Agricultural	0	0	0	0%	0	0	0	0%	61.8463	0	0	0	0%	0.00	0%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	38.824	0	38.824	100%	61.8463	61.8463	0	61.8463	100%	0.00	0%	29.62	29.62	99.85%				
				Commercial/Industrial-HT	8	0	8	100%	38.824	0	38.824	100%	61.8463	61.8463	0	61.8463	100%	0.00	0%	29.62	29.62	99.85%				
Sub-total				0	0	0	0%	0	0	0	0%	61.8463	61.8463	0	61.8463	100%	0.00	0%	29.62	29.62	99.85%					
3	BARIDORA		GOMD-M	Residential	0	0	0	0%	0	0	0	0%	742.3752	0	0	0	0%	1.88	0%	0.00	0.00	0.00%	0%			
				Agricultural	0	0	0	0%	0	0	0	0%	742.3752	0	0	0	0%	1.88	0%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	400.0988	0	400.0988	100%	742.3752	742.3752	0	742.3752	100%	1.88	0%	463.78	463.78	100.00%				
				Commercial/Industrial-HT	36	0	36	100%	400.0988	0	400.0988	100%	742.3752	742.3752	0	742.3752	100%	1.88	0%	463.78	463.78	100.00%				
Sub-total				0	0	0	0%	0	0	0	0%	742.3752	742.3752	0	742.3752	100%	1.88	0%	463.78	463.78	100.00%					
4	BEIMURI		GOMD-I	Residential	0	0	0	0%	0	0	0	0%	17.848	0	0	0	0%	-0.54	-3%	0.00	0.00	0.00%	0%			
				Agricultural	0	0	0	0%	0	0	0	0%	17.848	0	0	0	0%	-0.54	-3%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	16.56	0	16.56	100%	17.848	18.38755	0	18.38755	100%	-0.54	-3%	9.47	9.47	99.68%				
				Commercial/Industrial-HT	1	0	1	100%	16.56	0	16.56	100%	17.848	18.38755	0	18.38755	100%	-0.54	-3%	9.47	9.47	99.68%				
Sub-total				0	0	0	0%	0	0	0	0%	17.848	18.38755	0	18.38755	100%	-0.54	-3%	9.47	9.47	99.68%					
5	BIADA		GOMD-IV	Residential	0	0	0	0%	0	0	0	0%	203.367	0	0	0	0%	3.33	2%	0.00	0.00	0.00%	3%			
				Agricultural	0	0	0	0%	0	0	0	0%	203.367	0	0	0	0%	3.33	2%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	137.48112	0	137.48112	100%	203.367	200.0412	0	200.0412	100%	3.33	2%	97.59	96.31	98.70%				
				Commercial/Industrial-HT	43	0	43	100%	137.48112	0	137.48112	100%	203.367	200.0412	0	200.0412	100%	3.33	2%	97.59	96.31	98.70%				
Sub-total				0	0	0	0%	0	0	0	0%	203.367	200.0412	0	200.0412	100%	3.33	2%	97.59	96.31	98.70%					
6	BITPS		GOMD-IV	Residential	0	0	0	0%	0	0	0	0%	63.91518	0	0	0	0%	0.83	1%	0.00	0.00	0.00%	1%			
				Agricultural	0	0	0	0%	0	0	0	0%	63.91518	0	0	0	0%	0.83	1%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	43.7	0	43.7	100%	63.91518	63.08742	0	63.08742	100%	0.83	1%	36.82	36.82	100.00%				
				Commercial/Industrial-HT	3	0	3	100%	43.7	0	43.7	100%	63.91518	63.08742	0	63.08742	100%	0.83	1%	36.82	36.82	100.00%				
Sub-total				0	0	0	0%	0	0	0	0%	63.91518	63.08742	0	63.08742	100%	0.83	1%	36.82	36.82	100.00%					
7	BURDWAN		GOMD-I	Residential	0	0	0	0%	0	0	0	0%	116.9933	0	0	0	0%	0.56	0%	0.00	0.00	0.00%	3%			
				Agricultural	0	0	0	0%	0	0	0	0%	116.9933	0	0	0	0%	0.56	0%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	56.764	0	56.764	100%	116.9933	116.43	0	116.43	100%	0.56	0%	73.72	71.83	97.44%				
				Commercial/Industrial-HT	5	0	5	100%	56.764	0	56.764	100%	116.9933	116.43	0	116.43	100%	0.56	0%	73.72	71.83	97.44%				
Sub-total				0	0	0	0%	0	0	0	0%	116.9933	116.43	0	116.43	100%	0.56	0%	73.72	71.83	97.44%					
8	BURNPUR		GOMD-II	Residential	0	0	0	0%	0	0	0	0%	230.501	0	0	0	0%	5.70	-2%	0.00	0.00	0.00%	0%			
				Agricultural	0	0	0	0%	0	0	0	0%	230.501	0	0	0	0%	5.70	-2%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	147.2	0	147.2	100%	230.501	236.2047	0	236.2047	100%	5.70	-2%	186.70	186.51	99.90%				
				Commercial/Industrial-HT	2	0	2	100%	147.2	0	147.2	100%	230.501	236.2047	0	236.2047	100%	5.70	-2%	186.70	186.51	99.90%				
Sub-total				0	0	0	0%	0	0	0	0%	230.501	236.2047	0	236.2047	100%	5.70	-2%	186.70	186.51	99.90%					
9	CHANDOL		GOMD-III	Residential	0	0	0	0%	0	0	0	0%	152.71	0	0	0	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Agricultural	0	0	0	0%	0	0	0	0%	152.71	0	0	0	0%	0.00	0%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	100.28	0	100.28	100%	152.71	152.71	0	152.71	100%	0.00	0%	65.15	65.09	99.92%				
				Commercial/Industrial-HT	2	0	2	100%	100.28	0	100.28	100%	152.71	152.71	0	152.71	100%	0.00	0%	65.15	65.09	99.92%				
Sub-total				0	0	0	0%	0	0	0	0%	152.71	152.71	0	152.71	100%	0.00	0%	65.15	65.09	99.92%					
10	CTPS		GOMD-IV	Residential	0	0	0	0%	0	0	0	0%	410.76	0	0	0	0%	20.01	5%	0.00	0.00	0.00%	5%			
				Agricultural	0	0	0	0%	0	0	0	0%	410.76	0	0	0	0%	20.01	5%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	243.34	0	243.34	100%	410.76	390.7454	0	390.7454	100%	20.01	5%	203.06	202.86	99.91%				
				Commercial/Industrial-HT	4	0	4	100%	243.34	0	243.34	100%	410.76	390.7454	0	390.7454	100%	20.01	5%	203.06	202.86	99.91%				
Sub-total				0	0	0	0%	0	0	0	0%	410.76	390.7454	0	390.7454	100%	20.01	5%	203.06	202.86	99.91%					
11	DHANBAD		GOMD-IV	Residential	0	0	0	0%	0	0	0	0%	141.7045	0	0	0	0%	-0.62	0%	0.00	0.00	0.00%	-1%			
				Agricultural	0	0	0	0%	0	0	0	0%	141.7045	0	0	0	0%	-0.62	0%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	94.0516	0	94.0516	100%	141.7045	142.4147	0	142.4147	100%	-0.62	0%	73.77	73.94	100.23%				
				Commercial/Industrial-HT	10	0	10	100%	94.0516	0	94.0516	100%	141.7045	142.4147	0	142.4147	100%	-0.62	0%	73.77	73.94	100.23%				
Sub-total				0	0	0	0%	0	0	0	0%	141.7045	142.4147	0	142.4147	100%	-0.62	0%	73.77	73.94	100.23%					
12	ZIPS		GOMD-I	Residential	0	0	0	0%	0	0	0	0%	10.2119	0	0	0	0%	0.00	0%	0.00	0.00	0.00%	-2%			
				Agricultural	0	0	0	0%	0	0	0	0%	10.2119	0	0	0	0%	0.00	0%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	9.2	0	9.2	100%	10.2119	10.2119	0	10.2119	100%	0.00	0%	9.25	9.25	99.90%				
				Commercial/Industrial-HT	1	0	1	100%	9.2	0	9.2	100%	10.2119	10.2119	0	10.2119	100%	0.00	0%	9.25	9.25	99.90%				
Sub-total				0	0	0	0%	0	0	0	0%	10.2119	10.2119	0	10.2119	100%	0.00	0%	9.25	9.25	99.90%					
13	Sub-total		GOMD-I	Residential	0	0	0	0%	0	0	0	0%	10.2119	0	0	0	0%	0.00	0%	0.00	0.00	0.00%	-2%			
				Agricultural	0	0	0	0%	0	0	0	0%	10.2119	0	0	0	0%	0.00	0%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	9.2	0	9.2	100%	10.2119	10.2119	0	10.2119	100%	0.00	0%	9.25	9.25	99.90%				
				Commercial/Industrial-HT	1	0	1	100%	9.2	0	9.2	100%	10.2119	10.2119	0	10.2119	100%	0.00	0%	9.25	9.25	99.90%				
Sub-total				0	0	0	0%	0	0	0	0%	10.2119	10.2119	0	10.2119	100%	0.00	0%	9.25	9.25	99.90%					
14	Sub-total		GOMD-I	Residential	0	0	0	0%	0	0	0	0%	10.2119	0	0	0	0%	0.00	0%	0.00	0.00	0.00%	-2%			
				Agricultural	0	0	0	0%	0	0	0	0%	10.2119	0	0	0	0%	0.00	0%	0.00	0.00	0.00%				
				Commercial/Industrial-LT	0	0	0	0%	9.2	0	9.2	100%	10.2119	10.2119	0	10.2119	100%	0.00	0%	9.25	9.25	99.90%				
				Commercial/Industrial-HT	1	0	1	100%	9.2	0	9.2	100%	10.2119	10.2119	0	10.2119	100%	0.00	0%	9.25	9.25	99.90%				
Sub-total				0	0																					

Period From 01/07/2023 To 30/09/2023																													
S.No	Name of Substation	Circle code	Name of Division	Consumer category	Consumer profile					Energy parameters										Losses		Commercial Parameter			AT & C loss (%)				
					No of connection metered (Nos)	No of connection Un-metered (Nos)	Total Number of connections (Nos)	% of number of connections	Connected Load (MW)	Connected Load metered (MW)	Connected Load Un-metered (MW)	Total Connected Load (MW)	% of connected load	Input energy (MU)	Metered energy	Unmetered/assessment energy	Total energy (MU)	% of energy consumption	T&D loss (MU)	T&D loss (%)	Billed Amount in Rs. Crore	Collected Amount in Rs. Crore	Collection Efficiency						
14	Sub-total			Others	13	0	13	100%	173.558	0	0	173.558	0%	305.4984	307.6204	0	307.6204	100%	-2.12	-1%	205.67	207.56	100.92%	0.0%	0.0%	-2%			
	GIRDH	Residential			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Agricultural			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Commercial/Industrial-LT			0	0	0	0%	0	0	0	0	0%	341.1785	0	0	0.0000	0%	0.14	0%	0.00	0.00	0.00%						
		Commercial/Industrial-HT			35	0	35	100%	186.024	186.024	0	186.024	100%	341.1389	0	0	341.1389	100%			165.25	164.95	99.82%	0.0%	0.0%				
15	Sub-total			Others	35	0	35	100%	186.024	0	0	186.024	0%	341.1785	341.1389	0	341.1389	100%	0.14	0%	165.25	164.95	99.82%	0.0%	0.0%	0%			
	GOLA	Residential			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Agricultural			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Commercial/Industrial-LT			0	0	0	0%	0	0	0	0	0%	44.7892	0	0	0.0000	0%	0.04	0%	20.68	20.67	99.92%						
		Commercial/Industrial-HT			4	0	4	100%	24.104	24.104	0	24.104	100%	44.7446	0	0	44.7446	100%			0.00	0.00	0.00%						
16	Sub-total			Others	4	0	4	100%	24.104	0	0	24.104	0%	44.7892	44.7446	0	44.7446	100%	0.04	0%	20.68	20.67	99.92%	0.0%	0.0%	0%			
	HOWRAH	Residential			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Agricultural			0	0	0	0%	0	0	0	0	0%	29.398	0	0	0.0000	0%	-0.38	-1%	0.00	0.00	0.00%						
		Commercial/Industrial-LT			0	0	0	0%	0	0	0	0	0%	132.4269	0	0	132.4269	100%	0.00	0%	68.17	68.11	99.92%						
		Commercial/Industrial-HT			2	0	2	100%	27.6	27.6	0	27.6	100%	29.77693	0	0	29.77693	100%			0.00	0.00	0.00%						
17	Sub-total			Others	2	0	2	100%	27.6	0	0	27.6	0%	29.398	29.77693	0	29.77693	100%	-0.38	-1%	13.91	9.97	71.64%	27%					
	JAMSHEDPUR	Residential			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Agricultural			0	0	0	0%	0	0	0	0	0%	132.4269	0	0	132.4269	100%	0.00	0%	0.00	0.00	0.00%						
		Commercial/Industrial-LT			0	0	0	0%	0	0	0	0	0%	132.4269	0	0	132.4269	100%			68.17	68.11	99.92%						
		Commercial/Industrial-HT			3	0	3	100%	139.955	139.955	0	139.955	100%	132.4269	0	0	132.4269	100%	0.00	0%	68.17	68.11	99.92%	0%					
18	Sub-total			Others	3	0	3	100%	139.955	0	0	139.955	0%	132.4269	132.4269	0	132.4269	100%	0.00	0%	68.17	68.11	99.92%	0%					
	JAMURIA	Residential			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Agricultural			0	0	0	0%	0	0	0	0	0%	240	0	0	0.0000	0%	-3.04	-1%	0.00	0.00	0.00%						
		Commercial/Industrial-LT			0	0	0	0%	0	0	0	0	0%	240	0	0	0.0000	0%			0.00	0.00	0.00%						
		Commercial/Industrial-HT			9	0	9	100%	155.02	155.02	0	155.02	100%	243.0364	0	0	243.0364	100%	1.55	2%	42.96	34.27	79.78%						
19	Sub-total			Others	9	0	9	100%	155.02	0	0	155.02	0%	80.7028	79.15432	0	79.15432	100%	-3.04	-1%	149.02	149.02	100.00%	-1%					
	KALIPAHARI	Residential			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Agricultural			0	0	0	0%	0	0	0	0	0%	83.7028	0	0	0.0000	0%	1.55	2%	0.00	0.00	0.00%						
		Commercial/Industrial-LT			0	0	0	0%	0	0	0	0	0%	79.15432	0	0	79.15432	100%			0.00	0.00	0.00%						
		Commercial/Industrial-HT			7	0	7	100%	64.446	64.446	0	64.446	100%	79.15432	0	0	79.15432	100%			42.96	34.27	79.78%						
20	Sub-total			Others	7	0	7	100%	64.446	0	0	64.446	0%	80.7028	79.15432	0	79.15432	100%	1.55	2%	42.96	34.27	79.78%	22%					
	KALYANESWARI	Residential			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Agricultural			0	0	0	0%	0	0	0	0	0%	199.44	0	0	0.0000	0%	-5.43	-2%	0.00	0.00	0.00%						
		Commercial/Industrial-LT			0	0	0	0%	0	0	0	0	0%	304.8676	0	0	304.8676	100%			190.34	190.34	100.00%						
		Commercial/Industrial-HT			10	0	10	100%	152.536	152.536	0	152.536	100%	304.8676	0	0	304.8676	100%			0.00	0.00	0.00%						
21	Sub-total			Others	10	0	10	100%	152.536	0	0	152.536	0%	299.44	304.8676	0	304.8676	100%	-5.43	-2%	190.34	190.34	100.00%	-2%					
	KODHIMA	Residential			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Agricultural			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Commercial/Industrial-LT			0	0	0	0%	0	0	0	0	0%	141.437	0	0	0.0000	0%	3.61	3%	0.00	0.00	0.00%						
		Commercial/Industrial-HT			20	0	20	100%	75.394	75.394	0	75.394	100%	137.8257	0	0	137.8257	100%			62.73	62.73	100.00%						
22	Sub-total			Others	20	0	20	100%	75.394	0	0	75.394	0%	141.437	137.8257	0	137.8257	100%	3.61	3%	62.73	62.73	100.00%	3%					
	KOLAHAT	Residential			0	0	0	0%	0	0	0	0	0%	141.437	137.8257	0	137.8257	100%			0.00	0.00	0.00%						
		Agricultural			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%						
		Commercial/Industrial-LT			0	0	0	0%	0	0	0	0	0%	10.302	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%						
		Commercial/Industrial-HT			1	0	1	100%	7.36	7.36	0	7.36	100%	10.302	0	0	10.302	100%			7.44	7.01	94.24%						
23	Sub-total			Others	1	0	1	100%	7.36	0	0	7.36	0%	10.302	10.302	0	10.302	100%	0.00	0%	7.44	7.01	94.24%	6%					
	KUNARDHUBI	Residential			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Agricultural			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Commercial/Industrial-LT			0	0	0	0%	0	0	0	0	0%	50.36799	0	0	50.36799	100%	-0.35	-1%	0.00	0.00	0.00%						
		Commercial/Industrial-HT			15	0	15	100%	39.8636	39.8636	0	39.8636	100%	50.71913	0	0	50.71913	100%	0.35	-1%	25.17	24.42	96.59%	2%					
24	Sub-total			Others	15	0	15	100%	39.8636	0	0	39.8636	0%	50.36799	50.71913	0	50.71913	100%	0.35	-1%	25.17	24.42	96.99%	2%					
	PANTHON RIGHT BAN	Residential			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Agricultural			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Commercial/Industrial-LT			0	0	0	0%	0	0	0	0	0%	94.743	0	0	94.743	100%	0.09	0%	50.49	46.58	92.26%						
		Commercial/Industrial-HT			9	0	9	100%	49.772	49.772	0	49.772	100%	94.15162	0	0	94.15162	100%			0.00	0.00	0.00%						
25	Sub-total			Others	9	0	9	100%	49.772	0	0	49.772	0%	94.743	94.15162	0	94.15162	100%	0.09	0%	50.49	46.58	92.26%	8%					
	PANTHON	Residential			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						
		Agricultural			0	0	0	0%	0	0	0	0	0%	17.189	0	0	17.189	100%	0.00	0%	0.00	0.00	0.00%						
		Commercial/Industrial-LT			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%						
		Commercial/Industrial-HT			0	0	0	0%	0	0	0	0	0%	0	0	0	0.0000	0%			0.00	0.00	0.00%						

Period From 01/07/2023 To 30/09/2023																										
Consumer profile										Energy parameters					Losses		Commercial Parameter									
S.No	Name of Substation	Circle code	Name of Division	Consumer category	No of connection metered (Nos)	No of connection Un-metered (Nos)	Total Number of connections (Nos)	% of number of connections	Connected Load metered (MW)	Connected Load Un-metered (MW)	Total Connected Load (MW)	% of connected load	Input energy (MJ)	Metered energy	Unmetered/assessment energy	Total energy	% of energy consumption	T&D loss (MJ)	T&D loss (%)	Billed Amount in Rs. Crore	Collected Amount in Rs. Crore	Collection Efficiency	AT & C loss (%)			
27	NIMIAGHAT		GOMD-IV	Others	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	87%			
				Residential	1	0	1	100%	9.2	0	9.2	100%	0.8887	0.8887	0	0.8887	100%	0.00	0%	1.44	0.15	12.95%	0.00%			
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0.00%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0.00%			
				Commercial/Industrial-HT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0.00%			
	Sub-total			Others	0	0	0	0%	0	0	0	0%	2.0505	2.0505	0	2.0505	100%	0.00	0%	1.05	1.05	100.00%	0%			
				Residential	1	0	1	100%	1.84	0	1.84	100%	2.0505	2.0505	0	2.0505	100%	0.00	0%	1.05	1.05	100.00%	0%			
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-HT	2	0	2	100%	36.8	0	36.8	100%	47.7219	0	47.7219	100%	0	0	0.0000	0%	27.49	27.48	99.96%	0%		
28	NORTHKAMPUR		GOMD-VII	Others	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	1%			
				Residential	2	0	2	100%	36.8	0	36.8	100%	48.1285	0	48.1285	0%	0	0	0.0000	0%	0.41	1%	27.48	27.48	99.96%	1%
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-HT	5	0	5	100%	23.782	0	23.782	100%	71.1387	0	71.1387	0%	0	0	0.0000	0%	27.79	39%	27.57	95.06%	0%	
	Sub-total			Others	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	42%			
				Residential	5	0	5	100%	23.782	0	23.782	100%	71.1387	0	71.1387	0%	0	0	0.0000	0%	27.79	39%	27.57	95.06%	42%	
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-HT	11	0	11	100%	204.608	0	204.608	100%	281.4157	0	281.4157	0%	0	0	0.0000	0%	206.45	1%	206.12	99.84%	1%	
29	PANCHET		GOMD-II	Others	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Residential	11	0	11	100%	204.608	0	204.608	100%	279.9496	0	279.9496	0%	0	0	0.0000	0%	206.45	1%	206.12	99.84%	0%	
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-HT	5	0	5	100%	23.782	0	23.782	100%	71.1387	0	71.1387	0%	0	0	0.0000	0%	27.79	39%	27.57	95.06%	0%	
	Sub-total			Others	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Residential	11	0	11	100%	204.608	0	204.608	100%	281.4157	0	281.4157	0%	0	0	0.0000	0%	206.45	1%	206.12	99.84%	0%	
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-HT	14	0	14	100%	83.904	0	83.904	100%	115.0047	0	115.0047	0%	0	0	0.0000	0%	62.18	2%	61.99	99.70%	0%	
30	PARULIA		GOMD-III	Others	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Residential	14	0	14	100%	83.904	0	83.904	100%	120.8795	0	120.8795	0%	0	0	0.0000	0%	62.18	2%	61.99	99.70%	0%	
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-HT	3	0	3	100%	46.092	0	46.092	100%	55.9925	0	55.9925	0%	0	0	0.0000	0%	30.84	0%	30.82	99.91%	0%	
	Sub-total			Others	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Residential	3	0	3	100%	46.092	0	46.092	100%	55.9925	0	55.9925	0%	0	0	0.0000	0%	30.84	0%	30.82	99.91%	0%	
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-HT	3	0	3	100%	14.582	0	14.582	100%	20.1813	0	20.1813	100%	0	0	0.0000	0%	16.63	0%	16.63	100.00%	6%	
31	PATHERDIH		GOMD-IV	Others	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	65%			
				Residential	3	0	3	100%	14.582	0	14.582	100%	20.1813	0	20.1813	100%	0	0	0.0000	0%	16.63	0%	16.63	100.00%	6%	
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-HT	9	0	9	100%	89.2032	0	89.2032	100%	120.889	0	120.889	100%	0	0	0.0000	0%	35.26	0%	35.26	100.00%	0%	
	Sub-total			Others	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Residential	9	0	9	100%	89.2032	0	89.2032	100%	120.889	0	120.889	100%	0	0	0.0000	0%	35.26	0%	35.26	100.00%	0%	
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-HT	24	0	24	100%	179.6024	0	179.6024	100%	317.854	0	317.854	100%	0	0	0.0000	0%	156.96	0%	156.34	99.60%	2%	
32	PATRATU		GOMD-VII	Others	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Residential	24	0	24	100%	179.6024	0	179.6024	100%	317.854	0	317.854	100%	0	0	0.0000	0%	156.96	0%	156.34	99.60%	2%	
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-HT	3	0	3	100%	46	0	46	100%	84.3722	0	84.3722	100%	0	0	0.0000	0%	4.55	-5%	0.00	0.00%	0%	
	Sub-total			Others	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Residential	3	0	3	100%	46	0	46	100%	84.3722	0	84.3722	100%	0	0	0.0000	0%	4.55	-5%	0.00	0.00%	0%	
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-HT	1	0	1	100%	9.2	0	9.2	100%	6.9636	0	6.9636	100%	0	0	0.0000	0%	4.47	0%	4.47	99.90%	0%	
33	PUTRI		GOMD-III	Others	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Residential	1	0	1	100%	9.2	0	9.2	100%	6.9636	0	6.9636	100%	0	0	0.0000	0%	4.47	0%	4.47	99.90%	0%	
				Agricultural	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-LT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			
				Commercial/Industrial-HT	0	0	0	0%	0	0	0	0%	0	0	0	0.0000	0%	0.00	0%	0.00	0.00	0.00%	0%			

period from 01/01/2023 to 30/09/2023

S.No	Name of Substation	Circle code	Name of Division	Consumer category	No of connection metered (Nos)	No of connection Un-metered (Nos)	Total Number of connections (Nos)	% of number of connections	Connected Load metered (MW)	Connected Load Un-metered (MW)	Total Connected Load (MW)	% of connected load	Input energy (MTU)	Metered energy	Unmetered/assessment energy	Total energy	% of energy consumption	T&D loss (MU)	T&D loss (%)	Billed Amount in Rs. Crore	Collected Amount in Rs. Crore	Collection Efficiency	AT & C loss (%)
77	At company level				328	0	328	100%	3191.0577	0	3191.05772	100%	5179.243	5132.151	0	5132.150768	100%	47.09	3%	2963.19	2970.32	98.55%	2.34%

** Note - It shall be mandatory to record the energy supplied separately for each category of consumer which is being provided a separate rate of subsidy in the tariff, by the state government, so that the subsidy due for the electricity distribution company is quarterly calculated by multiplying the energy supplied to each of such category of consumers by the applicable rate of subsidy notified by the state government.

*** Meter installation for measurement of Input Energy at substation level under SEMA Phase-II project is under progress. After completion of the same, T&D Loss and AT&C Losses will be provided in line with the BEE prescribed format.

Color code	Parameter
	Please enter name of circle
	Please enter circle code
0	Please enter numeric value or 0
	Formula protected

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any other person affected, I/we undertake to indemnify such loss.

Authorized Signatory and Seal

Name of Authorized Signatory: Arun Patra
Name of the DISCOM: Damodar Valley Corporation
Full Address: 1st Floor, Commercial Department, DVC Towers, VIP Road, Kolkata-700054.

Signature:-
Name of Energy Manager: Om Prakash
Registration Number: EA-8622

Form-Input energy(Details of Input energy & Infrastructure)				
A. Summary of energy input & Infrastructure				
S.No	Parameters	Period From 01/07/23 To 30/09/23	Remarks (Source of data)	
A.1	Input Energy purchased & generated(MU)	11444.49	As a vertically integrated utility DVC has its own generation, transmission and distribution. So, Total Energy Input including DISCOM is shown here.	
A.2	Transmission loss (%)	2.09%		
A.3	Transmission loss (MU)	109.35	DVC has integrated Transmission & Distribution Network.	
A.4	Energy sold outside the periphery(MU)	5925.23		
A.5	Open access sale (MU)	277.76		
A.6	EHT sale	5132.15	Net Energy utilised for sale to DISCOM consumers including Substation Auxiliary & Colony consumption	
A.7	Net input energy (received at DISCOM periphery or at distribution point)-(MU)	5241.50	Net Energy Input used for DISCOM	
A.8	Is 100% metering available at 66/33 kV (Select yes or no from list)	Yes		
A.9	Is 100% metering available at 11 kV (Select yes or no from list)	Yes		
A.10	% of metering available at DT	100.00%		
A.11	% of metering available at consumer end	100.00%		
A.12	No of feeders at 66kV voltage level	27		
A.13	No of feeders at 33kV voltage level	133		
A.14	No of feeders at 11kV voltage level	3		
A.15	No of LT feeders level	0		
A.16	Line length (ckt. km) at 66kV voltage level	6616.00		
A.17	Line length (ckt. km) at 33kV voltage level	1506.00		
A.18	Line length (ckt. km) at 11kV voltage level	11.70		
A.19	Line length (km) at LT level	0.00		
A.20	Length of Aerial Bunched Cables	0.00		
A.21	Length of Underground Cables	2.00		
A.22	HT/LT ratio	0.00	No LT	

S.No	Zone	Cirle	Voltage Level (KV)	Encliden (KV)	Sub-Station	Fender ID	Fender Name	Problee Number (Functional/Non-Functional)	Refer to the status of the equipment at the time of the last reading/under revision	Fender Type (Refer to the status of the equipment at the time of the last reading/under revision)	% Data reported automatically by the meter/ASAM/AMR	Number of hours meter is in the field	Total Number of hours meter is in the field	Meter S.No	Period from 01/01/23 To 30/09/23	Import [MWh]	Export [MWh]	Sales	Remarks (Date of data)
8.1	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P1_P	BAHAI_DV_112_BAHAI_P1_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.2	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P2_P	BAHAI_DV_112_BAHAI_P2_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.3	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P3_P	BAHAI_DV_112_BAHAI_P3_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.4	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P4_P	BAHAI_DV_112_BAHAI_P4_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.5	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P5_P	BAHAI_DV_112_BAHAI_P5_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.6	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P6_P	BAHAI_DV_112_BAHAI_P6_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.7	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P7_P	BAHAI_DV_112_BAHAI_P7_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.8	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P8_P	BAHAI_DV_112_BAHAI_P8_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.9	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P9_P	BAHAI_DV_112_BAHAI_P9_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.10	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P10_P	BAHAI_DV_112_BAHAI_P10_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.11	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P11_P	BAHAI_DV_112_BAHAI_P11_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.12	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P12_P	BAHAI_DV_112_BAHAI_P12_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.13	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P13_P	BAHAI_DV_112_BAHAI_P13_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.14	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P14_P	BAHAI_DV_112_BAHAI_P14_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.15	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P15_P	BAHAI_DV_112_BAHAI_P15_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.16	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P16_P	BAHAI_DV_112_BAHAI_P16_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.17	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P17_P	BAHAI_DV_112_BAHAI_P17_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.18	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P18_P	BAHAI_DV_112_BAHAI_P18_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.19	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P19_P	BAHAI_DV_112_BAHAI_P19_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.20	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P20_P	BAHAI_DV_112_BAHAI_P20_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.21	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P21_P	BAHAI_DV_112_BAHAI_P21_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.22	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P22_P	BAHAI_DV_112_BAHAI_P22_P	Metred	Functional	The line	100	NA	NA	NA	0.00	0.00	0.00	NA	NA
8.23	NA	NA	423	NA	BAHAI	BAHAI_DV_112_BAHAI_P23_P	BAHAI_DV_112_B												

* DVCs are integrated entities having its own embedded generation, transmission & distribution network. Import & Export meters are installed at DVC Eastern Berlin variator which accounts for total power exchange between DVC & CTU including all the transactions like wheeling, bilateral exchange, etc. Hence, this does not reflect the energy at DVC DISCOM end.

Details of Input Energy Sources											
Period from 01/07/23 to 30/06/24											
A. Generation at Transmission Feeder (Details)											
S.No	Name of Generation Station	Generation Capacity (in MW)	Type of Station Generation (Based on Fuel Type/Source of Energy)	Type of Contract (in years/monthly)	Type of Grid (Inter-state/Intra-state)	Point of Connection (T/O/Loss MC)	Voltage Level (kV)	Remarks (Source of data)	Received at Sub-Division Level (in MW)	Received at Sub-Division Level (kVA)	Received at Sub-Division Level (in MW)
1	NTPC TSTPS-1	1,859	Thermal	25 Years	Inter-State	0.791095634	400 KV	Tariff Order for DISCOM			
2	NTPC Baramulla	594	Hydel Power Station	25 Years	Inter-State	0.394555674	400 KV	Tariff Order for DISCOM			
3	NTPC Teesta	43.5456	Hydel Power Station	25 Years	Inter-State	3.176281609	400 KV	Tariff Order for DISCOM			
4	PTC Chakha	28	Hydel Power Station	25 Years	Inter-State	2.38999908	400 KV	Tariff Order for DISCOM			
5	PTC Tala	55.95	Hydel Power Station	25 Years	Inter-State	2.055001771	400 KV	Tariff Order for DISCOM			
6	PTC Korchi	28.7	Hydel Power Station	25 Years	Inter-State	0.395057888	400 KV	Tariff Order for DISCOM			
7	MPL	140.5	Thermal	25 Years	Inter-State	9.839530917	400 KV	Tariff Order for DISCOM			
B. Embedded Generation in DISCOM Area											
S.No	Name of Generation Station	Generation Capacity (in MW)	Type of Station Generation (Based on Fuel Type/Source of Energy)	Type of Contract (in years/monthly)	Type of Grid (Inter-state/Intra-state)	Voltage Level (kV)	Circle Load (MW)	Received at Sub-Division Level (in MW)	Received at Sub-Division Level (kVA)	Received at Sub-Division Level (in MW)	Received at Sub-Division Level (in MW)
1	Durgam Cheruvu Thermal Power Station 1-2	1000	Coal	Long Term	Self generate source	400 KV	NA	NA	NA	NA	NA
2	Mejla Thermal Power Station 1-4	840	Coal	Long Term	Self generate source	220 KV	NA	NA	NA	NA	NA
3	Mejla Thermal Power Station 5-6	500	Coal	Long Term	Self generate source	220 KV	NA	NA	NA	NA	NA
4	Mejla Thermal Power Station 7-8	1000	Coal	Long Term	National Grid	400 KV	NA	NA	NA	NA	NA
5	Kedarnath Thermal Power Station 1-2	1000	Coal	Long Term	National Grid	400 KV	NA	NA	NA	NA	NA
6	Itanagar Thermal Power Station A	500	Coal	Long Term	National Grid	400 KV	NA	NA	NA	NA	NA
7	Chandrapur Thermal Power Station 7-8	500	Coal	Long Term	Self generate source	220 KV	NA	NA	NA	NA	NA
8	Raghunathpur Thermal Power Station 1-2	1200	Coal	Long Term	National Grid	400 KV	NA	NA	NA	NA	NA
9	Machilipatnam Thermal Power Station	47.2	Hydel	Fully Used in DISCOM	Self generate source	33 KV	NA	NA	NA	NA	NA
10	Panchet Hydel Power Station	50	Hydel	Fully Used in DISCOM	Self generate source	33 KV	NA	NA	NA	NA	NA
11	Tilaiya Hydel Power Station	4	Hydel	Fully Used in DISCOM	Self generate source	11 KV	NA	NA	NA	NA	NA

OW Total Regal Load 1951 MW

[illegible]

(Details of Feeder-wise losses)

Period From July 2023 to September-2023.

Sl No.	Zone	Received at Circle (in MU)	Received at Sub-division (in MU)	Name of the Sub Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Rural/Industrial/Agricultural/Power)	Type of Feeder (AM/AD/MS/Other)	Received at Feeder (in MU)	Feeder Consumption (in MU)	Final Rv/Export at Feeder Level (in MU)	TSD Losses	AT&C losses	% Data Received Automatically (R feeder/AM/AD/MS)	Consumer No of corresponding feeder	Remarks
1	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	18.58	0.03	18.55	0.42				
2	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	47.898	0.03	47.71	0.39				
3	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	50.52	0.03	50.49	0.58				
4	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	11.50	0.03	11.47	0.04				
5	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	26.52	0.03	26.49	0.04				
6	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	21.45	0.03	21.42	0.04				
7	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	51.89	0.03	51.86	0.58				
8	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	19.25	0.03	19.22	0.55				
9	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	80.94	0.03	80.91	0.42				
10	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	41.15	0.03	41.12	0.18				
11	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	21.32	0.03	21.29	0.57				
12	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	4.13	0.03	4.10	0.04				
13	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	55.26	0.03	55.23	0.04				
14	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	1.24	0.03	1.21	0.362				
15	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	18.81	0.03	18.78	0.14				
16	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	11.18	0.03	11.15	0.39				
17	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	16.71	0.03	16.68	0.00				
18	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	2.17	0.03	2.14	0.77				
19	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	0.42	0.03	0.39	0.4279				
20	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	6.15	0.03	6.12	0.26				
21	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	7.77	0.03	7.74	0.76				
22	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	38.80	0.03	38.77	0.7817				
23	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	5.91	0.03	5.88	0.00				
24	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	68.53	0.03	68.50	0.00				
25	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	25.16	0.03	25.13	0.00				
26	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	38.74	0.03	38.71	0.00				
27	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	18.57	0.03	18.54	0.13				
28	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	1.59	0.03	1.56	0.20				
29	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	127.54	0.03	127.51	0.00				
30	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	25.17	0.03	25.14	0.00				
31	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	9.24	0.03	9.21	0.00				
32	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	7.87	0.03	7.84	0.00				
33	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	8.58	0.03	8.55	2.00				
34	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	24.50	0.03	24.47	2.91				
35	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	15.60	0.03	15.57	0.01				
36	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	13.14	0.03	13.11	0.15				
37	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	23.32	0.03	23.29	1.28				
38	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	18.76	0.03	18.73	0.73				
39	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	15.61	0.03	15.58	0.32				
40	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	43.14	0.03	43.11	0.32				
41	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	31.77	0.03	31.74	0.47				
42	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	5.9269	0.03	5.9236	0.00				
43	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	8.87	0.03	8.84	-2.43				
44	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	16.21	0.03	16.18	0.88				
45	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	4.80	0.03	4.77	5.10				
46	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	31.38	0.03	31.35	5.10				
47	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	15.22	0.03	15.19	0.77				
48	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	1.09	0.03	1.06	7.70				
49	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	17.96	0.03	17.93	7.70				
50	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	6.11	0.03	6.08	0.00				
51	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	5.17	0.03	5.14	0.00				
52	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	2.95	0.03	2.92	0.00				
53	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	1.35	0.03	1.32	1.77				
54	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	0.21	0.03	0.18	0.21				
55	GOMD-II HATHON	NA	NA	BUDHMAN	33KV GOMD-II Feeder	33KV GOMD-II Feeder	Industrial	AM	0.21	0.03	0.18	0.21				

Annexure -1: Proforma for Quarterly Consumer Category-wise Subsidy Billed/Received/Due for period JULY-2023 to SEPTEMBER-2023

Consumer Category (Separate for each subsidized consumer category)	Billed Energy			Subsidized Billed Energy			Applicable rate of Subsidy as notified by State govt.		Subsidy Due from State Govt.			Subsidy Actually Billed / claimed from State Govt. (As against col.12)	Subsidy Received from State Govt. (As against col.13)	Balance Subsidy yet to be Received from State Govt.
	Metered	Un- metered*	Total	Metered (out of col.2)	Un- metered* (out of col.3)	Total	Metered Energy**	Un-metered Energy**	Metered Energy	Un-metered Energy	Total	(in Rs. Cr.)	(in Rs. Cr.)	(in Rs. Cr.)
	2	3	4=2+3	5	6	7=5+6	8	9	10=5X8	11=6X9	12=10+11	13	14	15=13-14
1														
Residential	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Agriculture	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Commercial/Industrial - LT	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Commercial/Industrial - HT	0.00	0	0.00	0	0	0	0	0	0	0	0	0	0	0
Other (specify)	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

*It is submitted that DVC supplies power mainly to the industrial consumers without extending any subsidy to them. As such, the issue of subsidy is not applicable for DVC as of now.

a. Division-wise status of DT level metering (please add more rows as per requirement)
Please fill in the data for each division during the reporting period)

Zone name	Circle name	Division name	Feeder name	Total no of DT on feeder	No of unmetered DTs	No of metered DTs				No. of DTs with functional meters		Remarks
						AMR metered (communicable)	AMI metered (communicable)	Non-AMR / AMI metered (non-communicable)	Communicating (Total No out of 7 & 8)	Non-communicating (Total No out of 7 & 8 & 9)		
1	2	3	4	5=(6+7+8+9)	6	7	8	9	10	11		
WEST BENGAL	GOMD-I	HOWRAH	POWER TRANSFORMER-1(132/33/11 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-I	HOWRAH	POWER TRANSFORMER-2(132/33/11 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-I	BELURIAH	POWER TRANSFORMER-1(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-I	KHARAGPUR	POWER TRANSFORMER-1(132/11 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-I	BURDWAN	POWER TRANSFORMER-1(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-I	BURDWAN	POWER TRANSFORMER-2(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-I	BURDWAN	POWER TRANSFORMER-3(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	KALYANESHWARI	POWER TRANSFORMER-1(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	KALYANESHWARI	POWER TRANSFORMER-2(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	KALYANESHWARI	POWER TRANSFORMER-1(220/36 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	KALYANESHWARI	POWER TRANSFORMER-2(220/36 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	BURNPUR	POWER TRANSFORMER-1(220/33 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	BURNPUR	POWER TRANSFORMER-2(220/33 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	KUMARUTUBHI	POWER TRANSFORMER-1(132/33 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	KUMARUTUBHI	POWER TRANSFORMER-2(132/33 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	KUMARUTUBHI	POWER TRANSFORMER-3(132/33 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	KUMARUTUBHI	POWER TRANSFORMER-4(132/33 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	MOSABANI	POWER TRANSFORMER-1(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	PURULIA	POWER TRANSFORMER-1(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	JAMSHEDPUR	POWER TRANSFORMER-1(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-II	JAMSHEDPUR	POWER TRANSFORMER-2(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-III	BIADA	POWER TRANSFORMER-1(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-IV	BIADA	POWER TRANSFORMER-2(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-IV	PUTRI	POWER TRANSFORMER-1(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-IV	PUTRI	POWER TRANSFORMER-2(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-IV	PUTRI	POWER TRANSFORMER-3(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-IV	GRIIDH	POWER TRANSFORMER-1(220/33 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-IV	GRIIDH	POWER TRANSFORMER-2(220/33 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-IV	GRIIDH	POWER TRANSFORMER-3(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-IV	GRIIDH	POWER TRANSFORMER-4(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-V	HAZARIBAGH	POWER TRANSFORMER-1(132/33 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-V	HAZARIBAGH	POWER TRANSFORMER-2(132/33 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-V	HAZARIBAGH	POWER TRANSFORMER-3(132/33 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-V	HAZARIBAGH	POWER TRANSFORMER-4(132/33 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-V	KODERMA	POWER TRANSFORMER-1(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-V	KODERMA	POWER TRANSFORMER-2(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	
WEST BENGAL	GOMD-V	KODERMA	POWER TRANSFORMER-3(132/34/5 KV)	1	0	1	0	0	1	0	No Consumer is Connected	

b. Details of DT-wise losses: [Please add more rows as per requirement]

Sub-Station ID	Feeder ID	Feeder Name	DT Id no.	Predominant type of DT	Domestic/Industrial in/A	Type of metering (Unmetered/AMR /Other)	Status of meter (functional/non- functional)	% of data received (if AMR/AMR)	No. of connected consumers	Input Energy (MU)	Billed Energy (MU)	Loss of Energy (MU)	% Loss =[[6]-[4]-[5]]/[6]*100
BURDWAN	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	302	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	303	INDUSTRIAL	AMR		FUNCTIONAL	100%	7	117.9780866	116.9933	0.984797	0.834728374
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	304	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	132 KV PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	192	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	132 KV PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	191	INDUSTRIAL	AMR		FUNCTIONAL	100%	10	238.378402	234.5036	3.874802	1.625483671
KALYANESWARI	220 KV PTBH1 BAY	POWER TRANSFORMER-1(220/36 KV)	284	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	220 KV PTBH2 BAY	POWER TRANSFORMER-2(220/36 KV)	285	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	220 KV PTBH3 BAY	POWER TRANSFORMER-3(220/36 KV)	266	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	267	INDUSTRIAL	AMR		FUNCTIONAL	100%	1	11.558112	11.449	0.109112	0.944079613
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	138	INDUSTRIAL	AMR		FUNCTIONAL	100%	2	23.41692	23.9298	-0.51288	-2.19021118
BURNPUR	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	34	INDUSTRIAL	AMR		FUNCTIONAL	100%	2	20.1855	20.1533	0.0322	0.15950848
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	524	INDUSTRIAL	AMR		FUNCTIONAL	100%	2	37.88693	38.7369943	-1.050054	-2.78628242
	PTBH3 BAY	POWER TRANSFORMER-3(145.2/34.5 KV)	525	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	701	INDUSTRIAL	AMR		FUNCTIONAL	100%	28	215.4725	213.8664	1.6061	0.745185142
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	640	INDUSTRIAL	AMR		FUNCTIONAL	100%	17	142.094204	139.4713	2.562904	1.804427334
PUTI	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	652	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	653	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	413	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(220/33 KV)	414	INDUSTRIAL	AMR		FUNCTIONAL	100%	39	383.3297485	383.2231	0.106649	0.027821608
	PTBH2 BAY	POWER TRANSFORMER-2(220/33 KV)	444	INDUSTRIAL	AMR		FUNCTIONAL	100%					
GIRDIH	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	437	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	606	INDUSTRIAL	AMR		FUNCTIONAL	100%	5	144.179	143.5419	0.6371	0.441881773
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	604	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	607	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	591	INDUSTRIAL	AMR		FUNCTIONAL	100%	9	114.5079	114.1874	0.3205	0.279893332
BARHI	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	595	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	580	INDUSTRIAL	AMR		FUNCTIONAL	100%	13	192.18377	195.1779	-2.99413	-1.55795154
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	581	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	159	INDUSTRIAL	AMR		FUNCTIONAL	100%	22	265.5219	270.001	-4.4791	-1.68690417
	PTBH3 BAY	POWER TRANSFORMER-3(220/36 KV)	161	INDUSTRIAL	AMR		FUNCTIONAL	100%					
DURGAPUR	PTBH1 BAY	POWER TRANSFORMER-1(220/36 KV)	162	INDUSTRIAL	AMR		FUNCTIONAL	100%	24	131.02683	110.142	0.88483	0.67539444
	PTBH2 BAY	POWER TRANSFORMER-2(220/36 KV)	3	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	4	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(220/36 KV)	5	INDUSTRIAL	AMR		FUNCTIONAL	100%	5	21.16439	21.605	0.44061	2.08184597
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	13	INDUSTRIAL	AMR		FUNCTIONAL	100%					
ASP	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	15	INDUSTRIAL	AMR		FUNCTIONAL	100%	6	110.1216	111.3857	1.2641	1.14791285
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	26	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	23	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	345	INDUSTRIAL	AMR		FUNCTIONAL	100%	17	138.2136	134.1722	4.0414	2.924024843
	PTBH2 BAY	POWER TRANSFORMER-2(220/36 KV)	346	INDUSTRIAL	AMR		FUNCTIONAL	100%	6	81.205	79.9948	1.9102	2.352318207
KALPAHARI	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	199	INDUSTRIAL	AMR		FUNCTIONAL	100%	2	12.96089	12.758	0.20289	0.20389
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	200	INDUSTRIAL	AMR		FUNCTIONAL	100%	3	31.60215	30.9485	0.65365	2.06837191
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	516	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	626	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	622	INDUSTRIAL	AMR		FUNCTIONAL	100%					
NORTHKARANPURA	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	HTK1190268	INDUSTRIAL	AMR		FUNCTIONAL	100%	31	454.56055	437.102	17.45855	3.840753449
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	HTK1190266	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	HTK1190265	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	HTK0180411	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	HTK1190254	INDUSTRIAL	AMR		FUNCTIONAL	100%					
GOLA	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%	6	71.655	72.6241	-1.357453	-1.8874566
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	225	INDUSTRIAL	AMR		FUNCTIONAL	100%	7	0.58784	0.57334	0.0145	2.46657594
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	225	INDUSTRIAL	AMR		FUNCTIONAL	100%	16	2.19475	2.16076	0.03399	1.548693751
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%	9	0.9275	0.92105	0.00645	0.157181572
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%	12	81.4129815	80.2479	1.165086	1.431081878
KIMARABURHI	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%	2	19.11488	18.9512	0.16368	0.855296247
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	225	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
KODERMA	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
DHANBAD	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
KONAR	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
KUMARABURHI	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH3 BAY	POWER TRANSFORMER-3(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH1 BAY	POWER TRANSFORMER-1(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					
	PTBH2 BAY	POWER TRANSFORMER-2(132/34.5 KV)	224	INDUSTRIAL	AMR		FUNCTIONAL	100%					