

SAHYADRI PETROCHEMICALS LTD.	Doc No: SOP-CDU1-1101A
Operations Dept., CDU-1	Rev: 4 Date: 01-Feb-2024
Classification: INTERNAL	Page 1 of 1

STANDARD OPERATING PROCEDURE

Start-up of Crude Charge Pump P-1101A

This procedure covers the safe start-up of Crude Charge Pump **P-1101A**. Applicable to CDU-1 panel and field operators. Read with the unit Emergency Shutdown procedure SOP-CDU1-ESD.

1. Pre-Start Checks (MANDATORY)

- 1.1 Confirm the mechanical-seal **API Plan 52 buffer reservoir level is between MIN and MAX** and cooling water to the seal cooler is flowing.
- 1.2 Confirm suction valve fully open and casing vented.
- 1.3 Confirm latest vibration status is within ISO 10816 Zone B/C. If the asset carries an open reliability alert (e.g. misalignment), **start is prohibited** until cleared by the Reliability Engineer.

2. Start-up

- 2.1 Obtain shift in-charge permission.
- 2.2 Start motor M-1101A.
- 2.3 Observe seal area for leakage/smoke for first 5 minutes.
- 2.4 Log discharge pressure and bearing temperature.

3. Safety Precautions

Crude is a flammable, sour (H₂S-bearing) hydrocarbon. Any seal leakage produces a fire and toxic-exposure hazard. On observing seepage, smoke, or a seal alarm: **trip the pump, start standby P-1101B, isolate, and raise a near-miss report**. Hot-work and area entry are governed by the facility work-permit system.