

Totally Integrated Automation Portal

FYP-LOGISTICS / PLC_1 [CPU 1214C DC/DC/Rly] / Program blocks

MBConfig [DB1]

MBConfig Properties

General

Name	MBConfig	Number	1	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author		Comment		Family	
Version	0.1	User-defined ID					

MBConfig

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA/Web API	Writ-able from HMI/ OPC UA/ Web API	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static									
DISCONNECT	Bool	false	False	True	True	True	False		
MB_MODE	USInt	0	False	True	True	True	False		data mode
DATA_ADDR	UDInt	40001	False	True	True	True	False		Start Address: 40001
DATA_LEN	UInt	10	False	True	True	True	False		
▼ CONNECT	TCON_IP_v4		False	True	True	True	False		
Interfaceld	HW_ANY	64	False	True	True	True	False		HW-identifier of IE-interface submod-ule
ID	CONN_OUC	1	False	True	True	True	False		connection reference / identifier
ConnectionType	Byte	11	False	True	True	True	False		type of connection: 11=TCP/IP, 19=UDP (17=TCP/IP)
ActiveEstablished	Bool	true	False	True	True	True	False		active/passive connection establish-ment
▼ RemoteAddress	IP_V4		False	True	True	True	False		remote IP address (IPv4)
▼ ADDR	Array[1..4] of Byte		False	True	True	True	False		IPv4 address
ADDR[1]	Byte	192	False	True	True	True	False		IPv4 address
ADDR[2]	Byte	168	False	True	True	True	False		IPv4 address
ADDR[3]	Byte	0	False	True	True	True	False		IPv4 address
ADDR[4]	Byte	88	False	True	True	True	False		IPv4 address
RemotePort	UInt	502	False	True	True	True	False		remote UDP/TCP port number
LocalPort	UInt	0	False	True	True	True	False		local UDP/TCP port number
DONE	Bool	false	False	True	True	True	False		
BUSY	Bool	false	False	True	True	True	False		
ERROR	Bool	false	False	True	True	True	False		
STATUS	Word	16#0	False	True	True	True	False		