

WHITEPAPER

# Engineering Long-Life Battery-Powered Smart Water Meters

## Part 7 — Practical Recommendations and the Future of Long-Life Smart Water Metering

A Systems Engineering Approach to Battery Life in Advanced Metering Infrastructure

|           |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
|-----------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Author    | Vincent Wong (Wong Yew Hon)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Published | 29th September 2026                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |
| Category  | Smart Water Metering / AMI / Battery Systems Engineering                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| Part      | <p>7 of 7 — <b>Practical Recommendations and the Future of Long-Life Smart Water Metering</b></p> <p>Whitepaper Series:</p> <ul style="list-style-type: none"><li><input type="checkbox"/> Part 1<br/>Understanding Battery Life and the Battery Life Budget</li><li><input type="checkbox"/> Part 2<br/>Battery Chemistry and Energy Storage</li><li><input type="checkbox"/> Part 3<br/>Ultra-Low-Power Hardware Architecture</li><li><input type="checkbox"/> Part 4<br/>Firmware as the Energy Manager</li><li><input type="checkbox"/> Part 5<br/>Battery Life Qualification and Validation</li><li><input type="checkbox"/> Part 6<br/>From Laboratory to Field: Achieving Real-World Battery Life</li><li><input checked="" type="checkbox"/> <b>Part 7</b><br/><b>Practical Recommendations and the Future of Long-Life Smart Water Metering</b></li></ul> |
| Version   | 1.0 — First Edition                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |

***“Long battery life is not achieved by selecting a better battery. It is achieved by making better engineering and operational decisions throughout the lifecycle of the AMI system.”***

## 7.1 Recommendations for Utilities

Utilities are ultimately responsible for operating smart water metering systems throughout their service life.

Although manufacturers design battery-powered meters and system integrators deploy them, utilities determine how these assets are managed over the next ten to fifteen years.

Many of the operational decisions that influence battery life—including reporting frequency, alarm policies, firmware management, maintenance planning, and communication strategy—are made by the utility rather than the equipment supplier.

For this reason, battery life should be considered an integral part of utility asset management rather than merely a product specification.

### Define Operational Objectives Before Procurement

Successful AMI programmes begin by identifying operational outcomes rather than technical features.

Utilities should first define objectives such as:

- Reduction of Non-Revenue Water (NRW)
- Improved billing accuracy
- Faster leak detection
- Enhanced customer service
- Operational efficiency
- Better network visibility

Once these objectives are established, battery life expectations can be aligned with the operational requirements needed to achieve them.

This approach avoids specifying unnecessarily demanding communication requirements that provide limited operational benefit while increasing energy consumption.

### Procure Against Performance, Not Marketing Claims

Battery life specifications should be supported by measurable engineering assumptions.

During procurement, utilities should request information including:

- Battery Life Budget methodology
- Reporting assumptions
- Communication assumptions
- Environmental qualification results
- Current measurement methodology
- Battery chemistry
- Qualification programme
- Pilot deployment evidence

Transparent engineering evidence enables objective comparison between competing solutions.

## Establish Operational Battery KPIs

Battery performance should be managed using measurable operational indicators.

Examples include:

- Daily data availability
- Monthly communication success rate
- Retry frequency
- Battery replacement rate
- Low battery alarm percentage
- Firmware update success rate

These KPIs should be reviewed regularly alongside other AMI operational metrics.

## Preserve Battery Margin Through Policy

Operational policies should be evaluated not only for their business value but also for their impact on battery consumption.

Utilities should periodically review:

- Reporting frequency
- Alarm thresholds
- Diagnostic activities
- Firmware campaigns
- Communication schedules

Changes should be introduced only after understanding their effect on the remaining Battery Life Budget.

## Invest in People as Well as Technology

Long-life AMI systems require organisational capability as much as technical capability.

Utilities should develop expertise in:

- Battery behaviour
- Communication technologies
- RF performance
- Data analytics
- Firmware lifecycle management
- Predictive maintenance

Well-trained operational teams are often the greatest contributor to long-term AMI success.

## Build a Continuous Improvement Programme

Every deployment provides valuable operational knowledge.

Utilities should routinely review:

- Communication KPIs
- Installation quality
- Battery trends
- Firmware performance
- Maintenance records
- Customer feedback

Lessons learned should feed directly into future procurement specifications and deployment strategies.

Continuous improvement transforms operational experience into long-term competitive advantage.

### Engineering Insight


**Utilities should manage battery life as an operational KPI throughout the entire AMI lifecycle rather than treating it as a fixed product specification established during procurement.**

### Practitioner Observation

Utilities achieving the longest operational battery life typically share a common characteristic: they treat battery performance as part of asset management rather than as a maintenance issue. Procurement, operations, IT, engineering, and field services work together to preserve the Battery Life Budget through coordinated decision-making over the life of the deployment.

## Key Takeaways

- Begin with operational objectives rather than technology features.
- Request engineering evidence supporting battery life claims.
- Monitor battery performance using measurable KPIs.
- Evaluate operational policy changes against their battery impact.
- Build organisational capability alongside technical capability.
- Use field experience to improve future AMI programmes.



**Figure 7.1 — Utility Battery Management Framework**

*Utilities maximize long-term battery performance by integrating procurement, operations, monitoring, and continuous improvement into a single lifecycle management framework.*

## 7.2 Recommendations for Manufacturers

Manufacturers play a fundamental role in determining the long-term performance of battery-powered smart water metering systems.

While battery chemistry is an important design consideration, achieving a reliable ten- to fifteen-year operational lifetime requires careful optimisation of the entire product architecture.

Hardware design, firmware behaviour, communication efficiency, environmental robustness, manufacturing consistency, and lifecycle support all contribute to the final battery performance experienced by utilities.

Manufacturers should therefore view battery life not as a marketing feature, but as the outcome of disciplined engineering.

## Design Around a Battery Life Budget

Battery performance should be planned systematically from the earliest stages of product development.

A structured Battery Life Budget should define:

- Sleep current
- Measurement energy
- Communication energy
- Retry assumptions
- Alarm behaviour
- Environmental operating conditions
- Battery self-discharge
- Design safety margin

Maintaining this Battery Life Budget throughout the design process helps ensure that engineering decisions remain aligned with the intended operational lifetime.

## Optimise the Complete System

Long battery life depends on the efficiency of the complete product rather than any single component.

Engineering optimisation should include:

- Ultra-low-power hardware design
- Efficient firmware scheduling
- Intelligent communication strategies
- Fast wake-up and return-to-sleep sequences
- Optimised radio operation
- Low-leakage component selection
- Robust power management architecture

Small improvements across multiple subsystems often produce greater battery life gains than increasing battery capacity alone.

## Validate Under Representative Conditions

Laboratory qualification should reflect realistic deployment environments.

Testing programmes should include:

- High and low temperature operation
- Humidity exposure
- Underground installations
- Weak communication conditions
- Flood-prone environments
- Long communication sessions
- Retry scenarios

Validation under representative operating conditions provides greater confidence than testing only under ideal laboratory environments.

## Be Transparent About Battery Life Assumptions

Battery life claims should always be supported by clearly documented assumptions.

Manufacturers should specify:

- Reporting interval
- Communication technology
- Signal quality assumptions
- Retry behaviour
- Operating temperature
- Battery chemistry
- Data availability target

Transparent specifications enable utilities to compare products fairly and establish realistic deployment expectations.

## Design for Firmware Evolution

Modern smart water meters continue evolving long after deployment.

Firmware architecture should support:

- Secure OTA updates
- Rollback capability
- Efficient memory management
- Backward compatibility
- Low-energy update procedures

Every firmware release should be evaluated not only for functionality but also for its effect on battery consumption.

Battery performance should remain a formal design requirement throughout the software lifecycle.

## Design for Manufacturability and Consistency

Battery performance achieved in engineering prototypes must be maintained during mass production.

Manufacturers should establish:

- Low-power production testing
- Firmware configuration control
- Statistical process monitoring
- Component traceability

- Battery handling procedures
- Manufacturing quality audits

Consistent production quality helps ensure that every shipped device performs as intended throughout its operational life.

## Support Utilities Beyond Product Delivery

Battery performance continues to evolve after installation.

Manufacturers should support utilities by providing:

- Battery Life Budget documentation
- Engineering assumptions
- Firmware release notes
- Communication optimisation guidance
- Battery monitoring recommendations
- Technical training
- Field investigation support

Long-term technical partnership strengthens deployment success and improves future product development.

### Engineering Insight

**Manufacturers do not ship battery life—they ship engineering decisions. Every design choice made during product development influences how efficiently the Battery Life Budget is used throughout the life of the meter.**


### Practitioner Observation

The most successful manufacturers rarely focus on maximising battery capacity alone. Instead, they optimize every subsystem that consumes energy, validate products under realistic operating conditions, and maintain close collaboration with utilities after deployment. This systems engineering approach consistently delivers more reliable long-term performance than relying on larger batteries or optimistic marketing specifications.



## Key Takeaways

- Develop and maintain a structured Battery Life Budget throughout product development.
- Optimise hardware, firmware, communication, and power management together.
- Validate products under representative deployment conditions.
- Publish transparent battery life assumptions alongside headline specifications.
- Design firmware architecture with long-term battery efficiency in mind.
- Ensure manufacturing consistency through robust production quality processes.
- Support utilities throughout the operational lifecycle, not only during product delivery.



**Figure 7.2 — Manufacturer Responsibilities for Long Battery Life**

*Manufacturers influence battery performance throughout the entire product lifecycle. Engineering discipline, manufacturing consistency, and long-term customer support are equally important contributors to achieving reliable battery life.*

## Practical Manufacturer Self-Assessment

| Assessment Question                                                          | Why It Matters                                                              |
|------------------------------------------------------------------------------|-----------------------------------------------------------------------------|
| Is every battery life claim supported by documented engineering assumptions? | Improves transparency and customer confidence.                              |
| Does product qualification include realistic field conditions?               | Laboratory results should reflect actual deployment environments.           |
| Is battery impact assessed during every firmware release?                    | Prevents gradual increases in power consumption over the product lifecycle. |
| Does production testing include low-power verification?                      | Ensures production units match engineering prototypes.                      |
| Are utilities provided with Battery Life Budget documentation?               | Enables informed operational planning and procurement decisions.            |
| Is field feedback incorporated into future product revisions?                | Continuous improvement strengthens future generations of AMI products.      |

### 7.3 Recommendations for System Integrators

System integrators play a critical role in ensuring that battery-powered smart water metering systems operate as intended after deployment.

Although manufacturers design the hardware and utilities define operational requirements, system integrators are responsible for translating these into a functioning AMI solution.

This includes communication infrastructure, system integration, device provisioning, commissioning, data validation, and operational support.

Poor integration practices can unintentionally increase communication activity, introduce unnecessary retries, or alter operating behaviour, reducing battery life even when the smart meter itself is functioning correctly.

System integrators should therefore view battery performance as a shared system responsibility rather than solely a device characteristic.

#### Understand the Battery Life Budget

Before deployment, system integrators should understand the engineering assumptions supporting the Battery Life Budget.

These assumptions typically include:

- Reporting frequency
- Communication schedule
- Retry limits
- Alarm configuration
- Firmware behaviour
- Network quality expectations

Understanding these assumptions helps ensure that system configuration remains aligned with the original product design.

## Preserve Engineering Intent During Integration

Integration activities should avoid introducing unnecessary communication overhead.

Examples include:

- Excessive polling
- Duplicate data requests
- Unnecessary status queries
- Repeated configuration commands
- Frequent diagnostic requests

While individually small, these activities can collectively increase battery consumption across thousands of deployed devices.

Integration should therefore minimise unnecessary communication while maintaining operational requirements.

## Optimise Commissioning Procedures

Commissioning is the first opportunity to verify that deployed devices operate within expected communication conditions.

Commissioning should confirm:

- Successful device registration
- Initial meter reading
- Signal quality
- Time synchronisation
- Alarm functionality
- Firmware version
- Battery baseline

Recording these measurements provides valuable reference data for future troubleshooting and lifecycle management.

## Validate End-to-End System Performance

Battery performance depends on the behaviour of the complete AMI ecosystem.

System validation should therefore include:

- Smart meter
- Communication network
- Gateway (where applicable)
- Head-End System (HES)
- Meter Data Management System (MDMS)
- Billing platform
- Analytics platform
- Mobile workforce applications

Testing individual components independently is insufficient if the complete workflow introduces unnecessary communication or operational delays.

## Configure Communication Policies Carefully

Many battery issues originate from configuration rather than hardware.

System integrators should review:

- Reporting schedules
- Retry limits
- Alarm thresholds
- Synchronisation intervals
- Timeouts
- Polling frequency
- Communication windows

Configuration should balance operational visibility with battery efficiency.

## Support Operational Optimisation

Integration does not end after system acceptance.

System integrators should continue supporting utilities by:

- Reviewing communication KPIs
- Analysing retry behaviour
- Investigating abnormal battery trends
- Optimising system configuration
- Supporting firmware campaigns
- Improving operational workflows

Continuous optimisation helps maintain battery performance throughout the AMI lifecycle.

## Promote Interoperability

Modern utilities increasingly operate multi-vendor environments.

System integrators should prioritise:

- Open APIs
- Standard communication protocols
- Consistent data models
- Vendor-neutral integration
- Documented interfaces

Interoperable systems reduce unnecessary complexity and simplify future optimisation activities that may affect battery performance.

### Engineering Insight


**System integration should preserve the engineering assumptions established during product development. Every unnecessary communication event introduced during integration consumes part of the Battery Life Budget.**

### Practitioner Observation

Field investigations often reveal that unexpectedly high battery consumption is associated not with the smart meter itself but with system configuration. Excessive polling intervals, repeated diagnostic requests, duplicate data collection, or overly aggressive retry settings within the AMI platform can significantly increase communication activity across the entire deployment. Careful integration and configuration management help prevent these avoidable energy losses.

## Key Takeaways

- Understand the Battery Life Budget before configuring the AMI system.
- Preserve engineering assumptions throughout system integration.
- Validate complete end-to-end workflows rather than individual components alone.
- Configure reporting, alarms, and polling carefully to minimise unnecessary communication.
- Continue optimisation after deployment through operational support and KPI monitoring.
- Promote interoperability to simplify long-term lifecycle management.



**Figure 7.3 — The System Integrator's Role in Battery Performance**

*System integrators preserve the manufacturer's engineering intent by ensuring that communication policies, commissioning procedures, and AMI platform configuration remain aligned with the Battery Life Budget throughout deployment.*

## Practical System Integrator Checklist

| Assessment Question                                                        | Why It Matters                                                          |
|----------------------------------------------------------------------------|-------------------------------------------------------------------------|
| Are reporting intervals consistent with the Battery Life Budget?           | Prevents unnecessary communication activity.                            |
| Has end-to-end communication been validated under operational conditions?  | Ensures the complete AMI workflow performs efficiently.                 |
| Are retry limits and polling intervals optimised?                          | Reduces avoidable battery consumption.                                  |
| Are baseline communication KPIs recorded during commissioning?             | Provides a reference for future troubleshooting.                        |
| Is the utility trained to understand battery-related operational settings? | Enables sustainable long-term operation.                                |
| Are system configuration changes documented and reviewed?                  | Prevents gradual configuration drift that increases energy consumption. |

## 7.4 Recommendations for Regulators and Standards Bodies

The long-term success of smart water metering extends beyond individual manufacturers and utilities.

Regulators, standards organisations, industry associations, and government agencies all play an important role in establishing common expectations for product performance, interoperability, cybersecurity, and lifecycle sustainability.

By promoting transparent engineering practices and measurable performance requirements, regulators can help create a more competitive, reliable, and sustainable AMI ecosystem.

Rather than specifying individual technologies, regulatory frameworks should focus on encouraging outcomes that support long-term operational success.

### Encourage Performance-Based Procurement

Procurement specifications often focus heavily on product features or hardware characteristics.

Greater emphasis should instead be placed on measurable operational performance.

Examples include:

- Daily data availability
- Monthly communication success rate
- Battery life assumptions
- Reading accuracy
- System availability
- Firmware update capability
- Cybersecurity maintenance
- Long-term support commitments

Performance-based procurement encourages innovation while allowing manufacturers to differentiate through engineering quality rather than marketing claims alone.

### Promote Transparent Battery Life Claims

Battery life is one of the most frequently advertised characteristics of battery-powered smart water meters.

However, comparisons between products are difficult when assumptions are not clearly disclosed.

Industry guidance should encourage manufacturers to document:

- Reporting frequency
- Communication technology
- Signal quality assumptions

- Operating temperature range
- Retry assumptions
- Battery chemistry
- Expected service conditions

Transparent assumptions improve procurement quality and reduce misunderstandings during deployment.

## Support Open Standards and Interoperability

Future AMI deployments are increasingly expected to operate within multi-vendor environments.

Standards bodies should continue promoting:

- Open communication protocols
- Standardised APIs
- Common data models
- Interoperable device management
- Consistent security frameworks

Interoperability reduces vendor lock-in, simplifies future system expansion, and encourages healthy market competition.

## Encourage Lifecycle Thinking

Procurement often focuses on initial acquisition cost.

However, the majority of operational expenditure occurs after deployment.

Guidelines should encourage evaluation of:

- Lifecycle cost
- Battery replacement strategy
- Firmware support period
- Spare parts availability
- Technical documentation
- Long-term maintenance capability
- End-of-life planning

Considering lifecycle factors alongside capital cost supports more sustainable investment decisions.



## Promote Engineering Evidence

Manufacturers should be encouraged to support product claims using documented engineering evidence rather than headline specifications alone.

Examples include:

- Battery Life Budget methodology
- Environmental qualification
- Communication testing
- Accelerated ageing studies
- Current profiling
- Field validation
- Production quality assurance

Transparent engineering evidence increases confidence across the industry.

## Encourage Knowledge Sharing

Utilities often face similar deployment challenges but may work independently.

Industry associations and regulators can facilitate:

- Technical workshops
- Best-practice publications
- Lessons learned from pilot projects
- Benchmark studies
- Industry forums
- Collaborative research

Knowledge sharing accelerates industry maturity and helps avoid repeating common deployment mistakes.

## Support Workforce Development

The transition to digital water infrastructure requires new technical capabilities.

Industry initiatives should support education in:

- AMI system engineering
- RF communication
- Battery technology
- Cybersecurity
- Data analytics
- Asset management
- Predictive maintenance

Investment in people is as important as investment in technology.

## Engineering Insight


**The credibility of battery life claims improves when engineering assumptions, validation methods, and operational expectations are transparent and consistently communicated across the industry.**

## Practitioner Observation

As AMI deployments become more widespread, utilities increasingly compare solutions from multiple manufacturers and communication technologies. Procurement decisions become significantly more robust when products are evaluated against common performance metrics and transparent engineering evidence rather than marketing terminology. Regulators and standards bodies can encourage this consistency without prescribing specific technical solutions.

## Key Takeaways

- Promote measurable performance outcomes rather than technology-specific requirements.
- Encourage transparent documentation supporting battery life claims.
- Support open standards and interoperability.
- Include lifecycle cost and long-term support within procurement guidance.
- Encourage evidence-based engineering rather than specification-driven marketing.
- Invest in workforce capability and industry knowledge sharing.



**Figure 7.4 — Building a Sustainable AMI Ecosystem**

*Sustainable smart water metering requires collaboration across the entire ecosystem. Regulators, standards bodies, manufacturers, system integrators, and utilities each contribute to achieving reliable, transparent, and long-lasting AMI deployments.*

## Practical Policy Recommendations

| Policy Objective                 | Suggested Industry Direction                                                      |
|----------------------------------|-----------------------------------------------------------------------------------|
| Improve procurement quality      | Encourage performance-based specifications supported by measurable KPIs.          |
| Increase transparency            | Recommend disclosure of battery life assumptions and validation methods.          |
| Promote interoperability         | Support open communication standards, APIs, and data models.                      |
| Improve lifecycle sustainability | Include maintenance, firmware support, and asset renewal in procurement guidance. |
| Strengthen technical capability  | Invest in industry training, certification, and knowledge-sharing initiatives.    |
| Build public confidence          | Encourage engineering evidence and transparent performance reporting.             |

## 7.5 The Future of Long-Life Smart Water Metering

Smart water metering continues to evolve rapidly.

Advances in communication technologies, battery chemistry, embedded processing, cloud computing, artificial intelligence, and digital infrastructure are creating new opportunities for utilities to operate more efficiently and make better use of operational data.

These developments will undoubtedly expand the capabilities of future AMI systems.

However, regardless of how sophisticated future technologies become, the fundamental principles discussed throughout this whitepaper will remain highly relevant.

Battery energy will always be finite.

Every communication event will continue to consume power.

Engineering trade-offs will remain unavoidable.

Long battery life will therefore continue to depend on disciplined system design, transparent engineering assumptions, and effective lifecycle management.

### Artificial Intelligence Will Improve Battery Management

Artificial intelligence is increasingly being applied to utility operations.

Rather than replacing engineering judgement, AI is expected to enhance decision-making by identifying patterns that would otherwise remain difficult to detect.

Future applications may include:

- Predicting abnormal battery consumption
- Detecting communication anomalies
- Optimising firmware deployment schedules
- Forecasting battery replacement demand
- Identifying deteriorating network performance
- Prioritising maintenance activities

These capabilities can help utilities preserve the Battery Life Budget more effectively across large AMI deployments.

However, AI can only provide reliable recommendations when supported by high-quality operational data.

### Digital Twins Will Support Lifecycle Optimisation

Digital twin technology is gaining attention across many infrastructure sectors.

In future smart water metering systems, digital twins may provide virtual representations of deployed assets that combine:

- Installation records
- Communication history
- Battery trends
- Firmware versions
- Maintenance history
- Environmental conditions
- Operational KPIs

By continuously comparing expected behaviour with actual field performance, digital twins may help utilities identify emerging issues earlier and evaluate the likely impact of future operational changes before implementing them across the network.

## Communication Networks Will Continue to Evolve

Communication technologies will continue improving over the coming decade.

Future LPWAN and cellular networks are expected to offer:

- Improved coverage
- Lower latency
- Higher reliability
- Better energy efficiency
- Increased capacity
- Enhanced security

While these developments may reduce communication energy consumption, efficient system design will remain essential.

No communication technology can eliminate the need for careful Battery Life Budget planning.

## Firmware Will Become Increasingly Intelligent

Future firmware is likely to become more adaptive.

Examples may include:

- Dynamic reporting intervals
- Adaptive retry strategies
- Context-aware communication scheduling
- Intelligent alarm suppression
- Self-optimising power management

These capabilities could improve both operational efficiency and battery utilisation.

Nevertheless, increased software sophistication must continue to be balanced against processing complexity and energy consumption.

## Sustainability Will Become More Important

Utilities worldwide are placing greater emphasis on sustainability.

Long-life smart water meters contribute to these objectives by:

- Reducing battery replacements
- Lowering maintenance vehicle usage
- Minimising electronic waste
- Extending asset service life
- Improving resource efficiency

Future product development should therefore consider battery performance not only as an operational objective but also as part of broader environmental and sustainability goals.

## Data Will Become the Primary Asset

Historically, utilities viewed the smart meter as the primary asset.

Increasingly, the greatest long-term value will come from the operational data generated by that meter.

Reliable battery performance supports:

- Continuous data availability
- Better operational decisions
- Predictive maintenance
- Consumption analytics
- Leak detection
- Infrastructure planning

Protecting battery life therefore also protects the long-term value of utility data.

## Engineering Principles Will Endure

Technology will undoubtedly change.

Communication standards will evolve.

Processing power will increase.

Artificial intelligence will mature.

Battery chemistry will improve.

Yet the core engineering principles described throughout this whitepaper will remain applicable.

Future systems will continue to require:

- Clear engineering assumptions

- Structured Battery Life Budgets
- Representative qualification testing
- Transparent battery life claims
- Lifecycle management
- Continuous operational improvement

These principles are technology-independent and will remain relevant regardless of future innovations.

### Engineering Insight


**Future technologies will improve how battery-powered smart meters are managed, but they will not eliminate the need for disciplined engineering. The Battery Life Budget will remain the foundation upon which reliable long-life AMI systems are built.**

### Practitioner Observation

Over the past decade, the smart water metering industry has seen rapid advances in communication technologies, embedded electronics, cloud platforms, and analytics. Yet the projects that consistently deliver reliable long-term performance continue to share the same characteristics: clear engineering assumptions, realistic qualification, disciplined deployment, and effective operational management. Future technologies are likely to strengthen these practices rather than replace them.

### Key Takeaways

- Artificial intelligence will enhance battery monitoring and predictive maintenance.
- Digital twins will improve lifecycle visibility and operational planning.
- Future communication technologies will improve efficiency but will not remove the need for Battery Life Budgets.
- Sustainability considerations will further increase the importance of long-life battery design.
- Operational data will become increasingly valuable throughout the AMI lifecycle.
- Sound engineering principles will remain the foundation of reliable battery-powered smart water metering.



**Figure 7.5 — The Future Evolution of Battery-Powered Smart Water Metering**

*Emerging technologies such as artificial intelligence, digital twins, and advanced communication networks will enhance smart water metering. However, these innovations will continue to depend on the engineering foundations established through robust Battery Life Budgets, disciplined product design, and effective lifecycle management.*

## Future Research Directions

The industry would benefit from further research in several areas:

- AI-assisted optimisation of Battery Life Budgets using fleet-wide operational data.
- Improved battery health estimation methods for primary lithium batteries.
- Adaptive communication algorithms that dynamically balance data availability and battery consumption.
- Standardised battery performance reporting methodologies for smart water metering.
- Lifecycle carbon footprint assessment of long-life AMI deployments.
- Integration of digital twins with predictive maintenance platforms for utility-scale battery management.

These research areas represent opportunities to strengthen future AMI deployments while preserving the engineering principles outlined throughout this whitepaper.



## 7.6 Final Conclusions

Battery-powered smart water meters have become one of the foundational technologies supporting the digital transformation of water utilities.

Their ability to provide reliable consumption data, improve operational visibility, reduce manual meter reading, and enable data-driven decision-making has made them an essential component of modern Advanced Metering Infrastructure (AMI).

However, achieving a reliable operational lifetime of ten to fifteen years requires far more than selecting a high-capacity battery.

Throughout this whitepaper, we have demonstrated that battery life is the cumulative result of engineering decisions made across the entire product lifecycle.

Battery chemistry is important.

But battery chemistry alone does not determine operational lifetime.

Low-power hardware architecture, efficient firmware, communication behaviour, environmental conditions, manufacturing quality, installation practices, operational policies, maintenance strategies, and continuous lifecycle management all influence how effectively the available battery energy is used.

The concept of the **Battery Life Budget** provides a practical engineering framework for understanding these relationships.

Rather than viewing battery life as a fixed specification or marketing claim, the Battery Life Budget encourages engineers and utilities to account for every source of energy consumption, document operating assumptions, validate designs under representative conditions, and continuously monitor field performance throughout deployment.

This approach transforms battery life from a prediction into a managed engineering objective.

For manufacturers, this means designing products with transparent engineering assumptions, rigorous qualification programmes, and disciplined production processes.

For system integrators, it means preserving those engineering assumptions through careful configuration, commissioning, and operational optimisation.

For utilities, it means managing battery performance as part of long-term asset management rather than treating it solely as a maintenance issue.

For regulators and standards organisations, it means encouraging transparent performance reporting, interoperability, and lifecycle thinking that strengthens confidence across the industry.

Perhaps the most important lesson is that **battery life is a shared responsibility**.

No single stakeholder determines the success of a long-life AMI deployment.

Reliable performance is achieved only when manufacturers, system integrators, communication providers, utilities, and technology partners work together with a common understanding of the engineering assumptions that underpin battery performance.

As communication technologies continue to evolve, artificial intelligence becomes more widely adopted, and digital water infrastructure matures, the tools available to manage battery-powered smart meters will continue to improve.

Yet the engineering principles described throughout this whitepaper will remain relevant.

Battery energy will always be finite.

Engineering trade-offs will always exist.

Disciplined design, transparent validation, and responsible lifecycle management will therefore remain the foundation of reliable long-life smart water metering.

Ultimately, successful AMI projects are not defined by how long a battery is claimed to last.

They are defined by how consistently utilities receive reliable, accurate, and actionable data throughout the operational life of the system.


That is the true measure of battery performance.

And that is the ultimate objective of every Battery Life Budget.

## Final Key Messages

The central themes of this whitepaper can be summarised as follows:

- Battery life is a systems engineering outcome, not simply a battery specification.
- A structured Battery Life Budget provides the foundation for credible battery life prediction and validation.
- Transparent engineering assumptions are essential for meaningful battery life claims.
- Qualification testing should reflect representative deployment conditions rather than ideal laboratory environments.
- Communication efficiency, installation quality, firmware design, and operational policies all influence long-term battery performance.
- Continuous monitoring and predictive maintenance help preserve battery performance throughout the AMI lifecycle.
- Collaboration among manufacturers, system integrators, utilities, and regulators is essential for achieving reliable long-term deployments.
- Engineering discipline—not marketing claims—is the basis of sustainable battery-powered smart water metering.



### **Final Figure — The Complete Battery Life Journey**

*Long battery life is the result of an integrated engineering lifecycle. From Battery Life Budget development and product qualification through deployment, operations, monitoring, and continuous improvement, every stage contributes to reliable long-term smart water metering performance.*

## Disclaimer

The views and observations expressed in this paper are the author's own and are intended for general industry discussion and educational purposes. They are based on publicly available research, practical engineering experience, and regional industry observations, and do not represent the official position, product commitments, customer relationships, or commercial practices of any employer, client, utility, or affiliated organisation. Utilities should evaluate deployment decisions within their own operational, technical, regulatory, and procurement context.

## About the Author



### Vincent Wong (Wong Yew Hon)

Vincent Wong brings over **25 years of engineering and product leadership experience** across industrial infrastructure and technology sectors, with the past decade focused on smart metering, Advanced Metering Infrastructure (AMI), and NB-IoT deployment strategies in ASEAN utility environments. As a senior engineering and product development executive, his work spans hardware engineering, connectivity systems, and utility digitalization initiatives. His writing focuses on the practical operational, connectivity, deployment, and governance realities of smart utility programs in Southeast Asia.

**Connect on LinkedIn:** [linkedin.com/in/vincentwongmy](https://www.linkedin.com/in/vincentwongmy)