

सेवा में,

स्वामी/प्रबन्धक
डोमिनोज़ पिजा कैफ़े
(Dominos Pizza Cafe)
कुलडी, मसूरी
जनपद-देहरादून।

सन्दर्भ:- अग्निशमन एवं आपात सेवा उत्तराखण्ड की वेबसाईट पर उपलब्ध कराये गये यूनिक नम्बर 39238837 दिनांक 18.07.2022 के सम्बन्ध में।

आपके कैफ़े का निरीक्षण अग्नि सुरक्षा व्यवस्था के दृष्टिकोण से प्रभारी/अग्निशमन अधिकारी मसूरी द्वारा किया गया। निरीक्षण आख्या दिनांक 22-07-2022 में आपके कैफ़े में स्थापित प्राथमिक अग्नि सुरक्षा व्यवस्था को सन्तोषजनक इंगित करते हुये अग्नि सुरक्षा व्यवस्था सम्बन्धी कार्यशीलता प्रमाण-पत्र प्रदान करने की संस्तुति की है।

अतः प्रभारी/अग्निशमन अधिकारी मसूरी की निरीक्षण आख्या दिनांक 22-07-2022 के आधार पर आपके कैफ़े हेतु उत्तराखण्ड शासन की अधिसूचना संख्या-342/XX-3/2021-2(39)/2006 देहरादून: दिनांक 29 नवम्बर, 2021 के अनुपालन में दिनांक 01-08-2022 से 31-07-2025 (03 वर्ष) तक के लिये प्राथमिक अग्नि उपकरणों सम्बन्धी कार्यशीलता प्रमाण-पत्र प्रदान किया जाता है। साथ ही उक्त व्यवस्था के कार्यशील होने का स्व-घोषणा प्रमाण पत्र/Audit Report प्रति छः माह में प्रस्तुत/अपलोड करना अनिवार्य होगा। यदि उपरोक्त अग्निसुरक्षा अनापत्ति प्रमाण पत्र से सम्बन्धित भवन या अधिभोग के आकार, प्रकृति, प्रयोजन या स्थान में किसी प्रकार का कोई परिवर्तन किया जाता है, तो अग्नि सुरक्षा प्रमाण पत्र नये सिरे से लिया जाना अनिवार्य होगा। अग्निशमन अधिकारी द्वारा दिये गये निर्देशों का पालन करेंगे एवं अग्नि सुरक्षा व्यवस्थाओं को सदैव उच्च स्तर पर रखेंगे। यह प्रमाण पत्र अवैध निर्माण को वैध करने के लिए मान्य नहीं होगा। अग्निशमन व्यवस्था के सुदृढ़ न पाये जाने अथवा अकार्यशील दशा में पाये जाने पर यह प्रमाण पत्र स्वतः ही निरस्त समझा जायेगा।


(आरोपित/प्रमाणित)
मुख्य अग्निशमन अधिकारी
देहरादून।



Mobile : 7055727770, 9997975366
Phone : 0135-2713029
E-mail : dobhalfiretech@gmail.com

DOBHAL FIRE TECH INDUSTRIES

Dealer & Suppliers of:

All types of ISI marked Fire Extinguishers, Fire Fighting equipments, CCTV systems, and safety equipments

GST NO: 05AOMPDP9767M1Z8 Regd. Off: 35/1, NAI BASTI, CHUKKUWALA, INDRA COLONY, DEHRADUN, U.K 248001



REG.NO. : HPT/DFTI/2025

Dated:- 07/08/2024

HYDRAULIC PRESSURE TEST

The following All Type Fire Extinguisher received from **M/S Dominos Pizza Cafe, Kulri, Mussoorie, Dehradun** has been tested hydraulically Pressure Test as per schedule IS: 2190 & Test Report observed is given as under:

Sr. No.	Type of Fire Extinguishers	Specified Hydraulic Test Pressure	Hold pressure In Min.	Result
1.	ABC 4 KG (1 Nos.)	30-35 kg	2.5 Min.	Ok
2.	CO ₂ 4.5 KG (2 Nos.)	30-35 kg	2.5 Min.	Ok

Authorized Signatory



For DOBHAL FIRE TECH INDUSTRIES

Regd. Off: 35/1, NAI BASTI, CHUKKUWALA, INDRA COLONY, DEHRADUN, U.K 248001
Branch office : 29, Araghar Near Bhura Chiken Corner, Dehradun
Anand Complex First Floor, Near Le Grand Hotel, Ranipur More, Haridwar, UK

Treasury Form-209(1)
Financial Handbook Vol. V, Part- II
Form No. 43A(1)
(See Paragraph 417 and 478)
Challan form for depositing amount



Name of the Treasury/Sub-Treasury/Bank/Bank Branch - State Bank Of India (Payment Gateway)

Status : (S) Completed successfully.

1	Name of the person (designation if necessary or Organization on whose behalf amount is being paid.	DOMINOS PIZZA CAFE
2	Address	KULRI MUSSOORIE
3	Registration Number (if necessary)	
4	Full details of amount to be deposited (for which purpose and in favour of)	FIRE REFILLING FEES
5	Gross value of Challan	30
6	Net value of Challan	30
7	Department	Director General Police
8	Related office for which challan is to be deposit	Senior Superintendent of Police Dehradun
9	Full details of Head of Account	0070 - Other Administrative Services
10	13 Digit code of Head of A/c	As per details below

SL No.	Services	Detail Head	Amount
1	Fire Vsulia in relation to the services went by Brigade.	0070601090100	30
	Total Challan Amount-		30

Amount (in words) - Rs. Thirty only

Signature of departmental officer with seal

DOMINOS PIZZA CAFE

Challan No- 00700825E0014791 Date - 07-AUG-2025	Amount in Figure(Rs.) - 30 Amount in words - Rs. Thirty only Received Through Bank Ref. No. - CPAFMCPX06 State Bank Of India (Payment Gateway)
--	---