



Switching AVO Electro Power Limited

H.O: 97, Raja Ram Mohan Rai Road, Kolkata- 700041

Service Help Line-9674000501 / Fax: 033-24001420 / Email id: service3@avoups.com

FIELD SERVICE REPORT

AVO Branch: Chhattisgarh	AVO Docket No: 2204_191102287
Site/Sol/ATM ID: MPZ04888	Name of Customer: Hitachi
Phone/Mobile:9977300345	Customer Status: Warranty
Date of Call: 2019-11-02 19:16:47	Call Type: New Installation Call
Site Type: new	End User Name: WhiteLabel/Moneyspot
Address:Shop No. 2, Purani Hatari, Secl Colony Road, Banki Mongra, Dist Korba, CG 495447	

Product Details


UPS Model	UPS Capacity	UPS Quantity	UPS Sl.No.	Battery Specs	Battery Qty
avo	3	1	avo	exide,12,100,	3

Voltage Parameters

DC Voltages			Input Voltages			Output Voltages		
With Mains	On Battery	Charging Current	L-N	L-E	N-E	L-N	L-E	N-E
110.00		70.00	240	238	0	230	229	0

Problem Reported: New Installation Call	Problem Type: 8
Time In: 2019-11-02 21:13:16	Time-Out: 2019-11-02 21:23:34
Call Status: Done1	
Service Remark : visit this site new avo make 3kva isolation transformer install compiled ok.isolation transformer working condition fine	

The above mentioned Systems installed/Service by Engineer is found to be functioning & satisfactory.

Engineer Name: Uttam Kumar Kewat	Customer :
	

Engineer Signature	Name & Sign By customer with seal
--------------------	-----------------------------------



Switching AVO Electro Power Limited

H.O: 97, Raja Ram Mohan Rai Road, Kolkata- 700041

Service Help Line-9674000501 / Fax: 033-24001420 / Email id: service3@avoups.com

FIELD SERVICE REPORT

Battery Test Report

S No.	Battery Serial No.	With Mains	Battery Mode
1	40J12457	13.50	12.80
2	40J12457	13.50	12.90
3	40J12457	13.50	12.80
4	40J12457	13.50	12.60
5	40J12457	13.50	12.70
6	40J12457	13.50	12.80
7	40J12457	13.50	12.80
8	40J12457	13.50	12.90