Homeowner Report

Created by:
Test Admin

Run On
December 15, 2022

For:
tj qa
113 Huntfield Way
Mooresville, NC 28117

Thank you for choosing Daikin One and Daikin for your home HVAC system. This report is a snapshot of the configuration of your system at the time this report was run. It details the equipment installed and some of the key settings used to optimize your system for peak and efficient operation.

Daikin One
19001 Kermier Rd
Waller, TX 77484

January 31, 2022

+1 (508) 878-4017
contact@daikinone.com
www.daikinone.com
System connected to Cloud Services

upstairs

Tests Run
- System
- Cooling
- Heat Pump Heat
- Fan
- Forced Defrost
- Pump Down

Standard tests were run. Details from these tests are used by your dealer to optimize your system set-up.

Thermostat
model number
DTST-CWBSA-NI-A

Daikin One+ Smart Thermostat
Smart thermostat with full two-way communications with Daikin HVAC Systems.

Heat Pump
model number
NO SHARED DATA

Air Handler
model number
DV59PECD14

Communicating Variable speed Air Handler with inverter-tuned EEV
The Daikin brand DVPEC Multi-Position, Variable Speed, Inverter-Tuned air handler is part of our ComfortNet family of communicating units.

Thermostat	DTST-CWBSA-NI-A	Daikin One+ Smart Thermostat
Thermostat Name **Thermostat ID**	upstairs DKN_100010997	**Daikin One Home mobile app user ID** t_jia@yahoo.com
Network Connection	online	A WiFi connection is needed to keep the thermostat up to date with automatic software updates.
Firmware	up to date	Version 3.1.4 is the most recent firmware.
Heat Pump	**NO SHARED DATA**	
Heating/Cooling Stages	Variable	More stages provide an increased ability to provide small changes to heating / cooling requests, increasing the comfort and efficiency at which a system runs.
Cool Airflow	on delay: 5 sec	Delays the indoor fan start the specified amount of time to allow the indoor coil to pre-cool for enhanced dehumidification.
	off delay: 30 sec	Allows the indoor fan to run longer than the outdoor unit by the specified time, improving efficiency.
Heat Airflow	on delay: 5 sec	Delays the indoor fan start the specified amount of time to allow the indoor coil to pre-heat for efficient heat transfer at the start of a heating cycle.
	off delay: 30 sec	Allows the indoor fan to run longer than the outdoor unit by the specified time, increasing efficiency by ensuring maximum heat transfer at the end of a heating cycle.
Defrost		Heat Pumps running during winter months need to occasionally defrost to maintain efficiency.
	interval: 30 min	Maximum duration between defrost cycles. Your system monitors the efficiency of your heat pump and defrosts as needed.

Cooling Boost Mode	enabled	Setting for cooling optimization that prioritizes comfort over efficiency in specific temperature conditions.
	activation temp: 105°F	The outdoor temperature at which cooling boost mode is engaged.

Air Handler	DV59PECD14	Communicating Variable speed Air Handler with inverter-tuned EEV
Heater Kit	not installed	Electric air handlers can have electric heat strips installed.These engage if a heat pump cannot keep up with demand, at low outdoor temps, and they can be used to temper indoor air during defrost cycles.
Electric Heater Airflow	heat airflow on delay: 0 sec	Delays the indoor fan start for the specified amount of time to allow the heat strips to pre-heat for comfortable heat transfer at the start of a heating cycle.
	heat airflow off delay: 60 sec	Allows the indoor fan to run longer than the heating call by the specified time, ensuring maximum heat transfer at the end of a heating cycle.

Additional Equipment		
Media Filter	filters: 1	Accessory air filter that ties into your system's ductwork.

This report reflects the settings and configuration of your comfort system and the tests run on your system, at the time of this report. System settings vary by home, and region, your Daikin Comfort Pro has selected settings based on the needs of you and your home.

To keep your system running at peak efficiency, and to maintain your manufacturer's warranty annual maintenance is required. To schedule maintenance or for questions on your system(s), contact Daikin One

Web: www.daikinone.com
Phone: +1 (508) 878-4017
Email: contact@daikinone.com

For more information on your thermostat including help videos and manuals visit, https://daikinone.com/smart_thermostats/oneplus/welcome/

For information on Daikin North America visit, https://daikincomfort.com