

Sub-Array PRS005

2021 Operation & Maintenance Documents

Project Name: PRS005 – Visitor Parking (Lot 16, 20 & 23)

Project Location: 80 Pyne Dr Princeton, NJ 08540

Project Capacity: 1.75MWAC

System Summary:

The 2.349 MW(DC)/1.75 MW(AC) PRS005 photovoltaic (PV) fixed tilt canopy array is located on Princeton Parking Lots 16, 20, and 23 (Visitor Parking Lot), on Elm Dr in Princeton Twp, New Jersey. The PV system is comprised of 6,032 JA Solar PV modules, with 3,406 rated at 385W and 2,626 rated at 395W and associated structural canopy racking by Parasol. The PRS005 system includes (1) 2000A 600V Switchboard, fourteen (14) Chint Power Systems CPS SCA125KTL-DO/US-600 string inverters: One (1) medium voltage transformer: (1) 2000kVA Eaton Transformer. The PV system connects to the grid via the 5kV switchgear located in the Elm Dr substation area.