

Chapter 1

Mathematical model of electrical power systems

In this Chapter, we explain the mathematical model of electrical power systems. In summary, we show that the dynamics of synchronous generators can be described by differential equations, and loads can be described by algebraic equations. Therefore, by combining both the equations of loads and synchronous generators, the entire electrical power system can be expressed as nonlinear differential-algebraic equations.

The current Chapter is structured as follows. First, in Section 1, we introduced to the basic concept of impedance and admittance of circuit elements and phasor representation of current and voltage in AC circuits. Next, in Section 2, we introduce the concept of nodal admittance matrix, which is a mathematical model of power grids. In Sections 3 and 4, mathematical models for generators and loads are explained. Specifically, in Section 3, we show that the model of a power grid composed only by generators can be expressed as a nonlinear ordinary differential equation through Kron reduction of the generator buses. The behavior of such an ordinary differential equation system is shown through a numerical simulation.

1 Foundation of AC circuit theory

1.1 Circuit elements

The basic circuit elements used in mathematical modeling of electrical power systems include resistors, inductors and capacitors. The relationship between terminal voltage and terminal current of each element is presented as follows:




Fig. 1 Basic circuit of resistors, inductors, and capacitors.

- (a) **Resistor:** For the resistor with resistance of R [Ω] shown in 1(a), the following relationship holds between the terminal voltage v [V] and terminal current i [A]:

$$v(t) = Ri(t) \quad (1)$$

where $R \geq 0$.

- (b) **Inductor:** For the inductor with inductance L [H] shown in 1(b), the following relationship holds between the terminal voltage and terminal current:

$$v(t) = L \frac{di}{dt}(t) \quad (2)$$

where $L \geq 0$.

- (c) **Capacitor:** For the capacitor with capacitance C [F] shown in 1(c), the following relationship holds between the terminal voltage and terminal current:

$$i(t) = C \frac{dv}{dt}(t) \quad (3)$$

where $C \geq 0$.

1.2 Instantaneous value and effective value

- (a) **Instantaneous value:** The instantaneous value of an AC quantity is an expression of this quantity in function of time t . For example, for a sinusoidal alternating voltage, its instantaneous value can be expressed by:

$$v(t) = V_m \sin(\omega t + \phi) \quad (4)$$

where V_m [V] is the voltage amplitude, ω [rad/s] is the angular frequency, and ϕ [rad] is the phase. The sine wave period T [s] is expressed as follows using ω :

$$T := \frac{2\pi}{\omega} \quad (5)$$

Frequency f [Hz] is expressed as its reciprocal $f := \frac{1}{T}$. Due to the characteristics of the elements presented in Section 1, when the instantaneous value of voltage is a sine wave, the instantaneous value of the current also becomes a sine wave.

- (b) **Effective value:** The effective value of an AC quantity corresponds to the square root of the average of the square of the values over a period of time T . Because of this definition, the effective value is also called **RMS value** (root mean square value). For example, for the resistor in 1(a), the average electric power consumed in one period can be calculated as follows:

$$\frac{1}{T} \int_t^{t+T} v(\tau) i(\tau) d\tau = \frac{1}{R} \underbrace{\left(\frac{V_m}{\sqrt{2}} \right)^2}_{V_e^2} \quad (6)$$

where V_e is the **effective value** of voltage. The effective value of the current is defined in the same manner. Since the average electric power can be described simply by using the effective value of voltage and current, the effective value is often used to perform calculations for AC circuit. The effective value is also used for the phasor representation of voltage and current introduced below.

1.3 Phasor representation

The AC voltage waveform of Equation 4 can be represented in the complex plane as in Figure 2. In this case, $v(t)$ is expressed by the following equation:

$$v(t) = i \left[V_m e^{j(\omega t + \phi)} \right] \quad (7)$$

In an electrical power system, the angular frequency ω can be considered constant and equal to the reference angular speed. Under this assumption, the voltage $v(t)$ of Equation 7 can be uniquely expressed by the phase ϕ , which can be derived from ωt and the amplitude V_m . Then, by using the effective value as an expression of the amplitude, we can obtain:

$$\mathbf{V} := V_e e^{j\phi} \quad (8)$$

This is called the **phasor representation** of voltage. When an electrical power system is in a steady state, the phasor \mathbf{V} is constant. In other words, the absolute value $|\mathbf{V}| = V_e$ and phase $\angle \mathbf{V} = \phi$ are constant. On the other hand, when an electrical




Fig. 2 Complex plane representation of AC voltage

power system is in a transient state, the temporal changes of $|V|$ and $\angle V$ have to be analyzed. The definition for the current phasor I is the same.

1.4 Impedance and admittance

The concept of impedance Z [Ω] arises when expressing the relationship between voltage and current using the phasor representation explained in Section 1.3. It is equivalent to the resistance in DC circuits, and corresponds to an opposition to alternating current. For the typical circuit elements presented in Section 1, the phasor representations of their terminal voltage and current V , I respect the following relationship.

$$V = ZI \quad (9)$$

The impedance of resistors, inductors and capacitors are, respectively:

$$Z_R := R, \quad Z_L := j\omega L, \quad Z_C := \frac{1}{j\omega C}$$

Please note that the characteristics of components such as synchronous generators and power converters may not be expressed using only constant impedances.

The real part of impedance is called **resistance** and the imaginary part is called **reactance**. As standard symbols, R [Ω] is used for resistance and X [Ω] is used for reactance. In other words:

$$Z = R + jX$$

The reciprocal Z^{-1} of impedance is called **admittance**. As a standard symbol, Y [S] is used. In addition, the real part of admittance is called **conductance** and the imaginary part is called **susceptance**. As a standard symbol, G [S] is used for conductance and B [S] is used for susceptance. In other words:




Fig. 3 Power system model composed of three bus bars

$$Y = G + jB$$

The reading of each physical unit presented so far is, V: volt, A: ampere, Ω : ohm, H: henry, F: farad, rad: radian, s: second, Hz: hertz, and S: siemens.

2 Admittance matrix: representation of interaction between connected devices

2.1 Fundamentals of modeling of power grids

In this section we derive the **admittance matrix** of a power grid, which expresses the interaction between the devices connected to an electrical power system

We derive the **admittance matrix** of a power grid that shows the interaction of equipment connected to an electrical power system using a basic transmission line model. The admittance matrix is derived from Ohm's law and Kirchhoff's laws for each bus bar and the transmission lines that connect them. Depending on the literature, the bus bar may also be called a **node** or **bus**. In this book, the bus bar is shown with a thick line in the diagram of an electrical power system. The bus bar is a conductor where the end of the transmission line has been collected. The thin line that connects the bus bar represents the transmission line.

Example 1.1 Admittance matrix of a power grid

Let us consider a simple electrical power system consisting of three bus bars as shown in Fig. 3. Assume that to each bus there is a device connected. In this book, the word "device" refers to synchronous generators and loads.¹ In addition, in an electrical power system model circuit such as that shown in 3, the connection to ground is often omitted for simplification.

¹ In this book, we analyze only load and generators, however, when considering solar generators, wind generators and batteries, these are also classified as "devices".

Below, the voltage phasor of bus bar i with respect to the ground is expressed as $V_i \in \mathbb{C}$, and the current phasor flowing from the device to the bus bar i is expressed as $I_i \in \mathbb{C}$. The voltage and current phasors are unknown variables, therefore it is necessary to find an equation governed by the power grid that establishes a relationship between the current phasor (I_1, I_2, I_3) and the current phasor (V_1, V_2, V_3) of the bus bars. For this purpose, we define the admittance matrix of the power grid.

The admittance of a transmission line that connects bus bars i and j is expressed as $y_{ij} \in \mathbb{C}$, with y_{ij} being known variables for every pair of bus bars ij . Additionally, the current phasor that flows in each transmission line is expressed as $I_{ij} \in \mathbb{C}$, where y_{ij} and y_{ji} are equal. In addition, the sign for I_{ij} is positive for an arbitrarily determined direction, and $I_{ji} = -I_{ij}$ are equal. The current phasor of this transmission line is an intermediate variable that describes the physical relationship of the current phasor and voltage phasor of the bus bars. Specifically, if the sign of the current phasor is defined positive for the direction indicated by the arrows in Fig. 3, the following relationship can be obtained by applying the Ohm's law:

$$I_{12} = y_{12}(V_1 - V_2), \quad I_{32} = y_{32}(V_3 - V_2)$$

According to Kirchhoff's first law (current law), since the sum of all current on each bus bar is 0, the following relationship is obtained for bus bar 1 to bus bar 3.

$$I_1 - I_{12} = 0, \quad I_2 + I_{12} + I_{32} = 0, \quad I_3 - I_{32} = 0$$

Note that Kirchhoff's first law states that the sum of inflow currents and the sum of outflow currents are equal at the point where an electric circuit branches. By replacing the variables I_{ij} by the previously calculated relationship $I_i = y_{ij}(V_1 - V_2)$, we can find the following vectorized version of the Ohm's law:

$$\begin{bmatrix} I_1 \\ I_2 \\ I_3 \end{bmatrix} = \begin{bmatrix} y_{12} & -y_{12} & 0 \\ -y_{12} & y_{12} + y_{32} & -y_{32} \\ 0 & -y_{32} & y_{32} \end{bmatrix} \begin{bmatrix} V_1 \\ V_2 \\ V_3 \end{bmatrix} \quad (10)$$

The complex matrix obtained in this manner is the admittance matrix of the power grid. Since each transmission line is usually expressed as a circuit with an equivalent resistance and inductance, the real part (conductance) of the admittance of the transmission line y_{ij} is non-negative, and the imaginary part (susceptance) is non-positive. Specifically, the imaginary part is usually negative (non-zero).

Below, we consider an electrical power system connected with N bus bars. Then, the admittance matrix $Y \in \mathbb{C}^{N \times N}$ of the power grid gives the following relationship to the current phasor (I_1, \dots, I_N) and voltage phasor (V_1, \dots, V_N) of the bus bars.

$$\begin{bmatrix} I_1 \\ \vdots \\ I_N \end{bmatrix} = \underbrace{\begin{bmatrix} Y_{11} & \cdots & Y_{1N} \\ \vdots & \ddots & \vdots \\ Y_{N1} & \cdots & Y_{NN} \end{bmatrix}}_Y \begin{bmatrix} V_1 \\ \vdots \\ V_N \end{bmatrix} \quad (11)$$




Fig. 4 Schematic diagram of a power system model

Equation 11 can be considered a mathematical model of the power grid that expresses interactions between inputs and outputs of devices connected to a bus bar. Specifically, if we consider the voltage phasor V_i as the output from the device i to the electrical power system, and current phasor I_i as the input from the electrical power system to the device i , I_i can be expressed as a linear combination of output from the other devices:

$$I_i = Y_{i1}V_1 + \cdots + Y_{iN}V_N$$

The real part and imaginary parts of the admittance matrix are called the **conductance matrix** and **susceptance matrix**, respectively.

The simultaneous equations 11 provide partial information about the current and voltage phasors of the bus bars, such that the current and voltage phasors of each bus bar, (I_1, \dots, I_N) and (V_1, \dots, V_N) , cannot be uniquely determined. To uniquely determine the steady and transient behaviors of the current and voltage phasors of every bus bar, the local relationship between I_i and V_i of each bus bar must be separately determined.

This localized relationship expresses the characteristics of the devices connected to the bus bars and can be considered mathematical models that express the input-output relationship of each device. Specific mathematical models of synchronous generators and loads will be described in detail in Section 3 and beyond.

$$\begin{bmatrix} V_1 \\ \vdots \\ V_N \end{bmatrix} = \underbrace{\begin{bmatrix} Z_{11} & \cdots & Z_{1N} \\ \vdots & \ddots & \vdots \\ Z_{N1} & \cdots & Z_{NN} \end{bmatrix}}_Z \begin{bmatrix} I_1 \\ \vdots \\ I_N \end{bmatrix} \quad (12)$$

If the admittance matrix Y in Equation 11 is nonsingular, $Z = Y^{-1}$, however Y is not always nonsingular. For example, if the admittance matrix of Equation 10 is not nonsingular, the following holds:

$$V_1 = V_2 = V_3 \quad \implies \quad I_1 = I_2 = I_3 = 0$$




Fig. 5 Schematic diagram of a power system model

The singularity of this admittance matrix indicates that when all current phasors of each bus bar are zero, all voltage phasors are the same; however, this value cannot be uniquely determined. Nevertheless, there is rarely any need to pay attention to the singularity of the admittance matrix within the scope of general analysis.

In addition, active power $P_i \in \mathbb{R}$ and reactive power $Q_i \in \mathbb{R}$ provided from device i to bus bar i are defined by:

$$P_i := \text{Re} \left[V_i \bar{I}_i \right], \quad Q_i := \text{Im} \left[V_i \bar{I}_i \right]$$

In other words, the following relationship holds between active power, reactive power, bus bar voltage phasor, and bus bar current phasor.

$$P_i + jQ_i = V_i \bar{I}_i \quad (13)$$

Then, by rearranging Equation 11, it is possible to obtain a power system model in which the active and reactive power supplied to the bus bar is the output of the device.

$$\begin{cases} P_i = \sum_{j=1}^N \text{Re} \left[\bar{Y}_{ij} V_i \bar{V}_j \right] \\ Q_i = \sum_{j=1}^N \text{Im} \left[\bar{Y}_{ij} V_i \bar{V}_j \right] \end{cases} \quad i \in \{1, \dots, N\} \quad (14)$$

Equation 14 is a simultaneous equation that expresses the electric power flow in each bus bar. Figures 4 and 5 are equivalent electrical power system models, but they can be used alternatively according to the analysis purpose.




Fig. 6 π-type circuit model of a transmission line with ground capacitance
(Transmission lines with end points at bus bars 1 and 2)

2.2 Power grid model with capacitance to ground

In short transmission lines, the model from the example 1.1 can be used; however, in medium transmission lines that exceed 50 km, the capacitance to ground (capacitance component) created between the transmission lines and the ground cannot be ignored.

When the capacitance to ground, a transmission line is often represented as a π-type equivalent circuit as shown in Figure 6. In Figure 6, a transmission line connecting the bus bars 1 and 2 is shown, where ω_0 is the system frequency and c_{12} is the capacitance to ground. Using this representation of transmission line, the admittance of the power grid is obtained as follows.

Example 1.2 Admittance matrix for the transmission line in a π-type circuit

For an electrical power system similar to Example 1.1, let's derive the admittance matrix when the transmission line is expressed by a π-type equivalent circuit. First, let's consider the relationship of the current phasors I_{12} , I_{21} , flowing from the bus bars, and the voltage phasors V_1 , V_2 of the bus bars of a transmission line with bus bars 1 and 2 as end points, as illustrated in Figure 6. Then, please note that, unlike in Example 1.1, I_{21} is different from $-I_{12}$. If the current flowing through the transmission line with admittance y_{12} from left to right is expressed as I'_{12} , the following equations are obtained from the Kirchhoff's laws:

$$I_{12} = \frac{j\omega_0 c_{12}}{2} V_1 + I'_{12}, \quad \frac{j\omega_0 c_{12}}{2} V_2 = I_{21} + I'_{12}$$

Moreover, by using the Ohm's law:

$$I'_{12} = y_{12}(V_1 - V_2)$$

By replacing I'_{12} and rearranging the equations, we obtain:

$$\begin{bmatrix} I_{12} \\ I_{21} \end{bmatrix} = \begin{bmatrix} y_{12} + \frac{j\omega_0 c_{12}}{2} & -y_{12} \\ -y_{12} & y_{12} + \frac{j\omega_0 c_{12}}{2} \end{bmatrix} \begin{bmatrix} V_1 \\ V_2 \end{bmatrix}$$

The following is true for the transmission line that uses bus bar 2 and bus bar 3 as end points:

$$\begin{bmatrix} I_{32} \\ I_{23} \end{bmatrix} = \begin{bmatrix} y_{32} + \frac{j\omega_0 c_{32}}{2} & -y_{32} \\ -y_{32} & y_{32} + \frac{j\omega_0 c_{32}}{2} \end{bmatrix} \begin{bmatrix} V_3 \\ V_2 \end{bmatrix}$$

Therefore, by using:

$$I_1 - I_{12} = 0, \quad I_2 - I_{21} - I_{23} = 0, \quad I_3 - I_{32} = 0$$

The admittance matrix of the power grid can be obtained as:

$$\begin{bmatrix} I_1 \\ I_2 \\ I_3 \end{bmatrix} = \begin{bmatrix} y_{12} + \frac{j\omega_0 c_{12}}{2} & -y_{12} & 0 \\ -y_{12} & y_{12} + y_{32} + \frac{j\omega_0 (c_{12} + c_{32})}{2} & -y_{32} \\ 0 & -y_{32} & y_{32} + \frac{j\omega_0 c_{32}}{2} \end{bmatrix} \begin{bmatrix} V_1 \\ V_2 \\ V_3 \end{bmatrix}$$

This is consistent with Equation 10 when c_{12} and c_{32} are zero.

2.3 Mathematical properties of the admittance matrix

In this book, we assume power grids that are connected; in other words, there is at least one route connecting two arbitrarily chosen bus bar. For unconnected power grids, the connected parts can be independently discussed. In Figure 7a, the nodes (circles) correspond to the bus bars and the edges (black lines) correspond to the transmission lines.

In the power grid model of Example 1.1 where the capacitance to ground is ignored, the admittance matrix is expressed as $Y_0 \in \mathbb{C}^{N \times N}$. The real and imaginary parts of Y_0 ; in other words, the conductance and susceptance matrices, are expressed as:

$$G_0 := \text{Re}[Y_0], \quad B_0 := \text{Im}[Y_0]$$

These matrices have the following properties. First, the sum of elements in all row vectors of these matrices is equal to zero. This is expressed by the following equations, where $\mathbf{1} \in \mathbb{R}^N$ is a vector which all elements are equal to one:

$$Y_0 \mathbf{1} = 0 \quad \Longleftrightarrow \quad G_0 \mathbf{1} = 0, \quad B_0 \mathbf{1} = 0 \quad (15a)$$

Furthermore, since the conductance is non-negative and the susceptance is negative in each transmission line, the conductance matrix is positive semi-definite and the susceptance matrix is negative semi-definite; in other words:

$$G_0 = G_0^T \geq 0, \quad B_0 = B_0^T \leq 0 \quad (15b)$$




Fig. 7 Connected and disconnected graphs (Connected graph and unconnected graph)

Specifically, based on the fact that the connectivity of the power grid and the susceptance of the transmission line are non-zero, the multiplicity of the zero eigenvalue of B_0 is derived to be 1. This can also be expressed as:

$$\ker B_0 = \text{span}\{\mathbf{1}\} \quad (15c)$$

Under the graph theory perspective, $-B_0$ is called a **graph Laplacian** of a strongly connected weighted undirected graph. The multiplicity of the zero eigenvalue in a graph Laplacian being 1 is a requirement for the corresponding undirected graph to be strongly connected [?].

Furthermore, when considering a π -type equivalent circuit for the transmission lines like in Example 1.2, a non-negative value is added to the diagonal element of the susceptance matrix B_0 . In other words, the admittance matrix for the power grid model in Examples 1.1 and 1.2 is expressed as:

$$Y = G_0 + j (B_0 + \text{diag}(b_i)_{i \in \{1, \dots, N\}}) \quad (16)$$

where b_i is a non-negative constant equivalent to capacitance to ground, and the conductance G_0 and the susceptance B_0 matrices satisfy Equation (15).

3 Mathematical model of synchronous generators

3.1 Classification of generator models based on the level of detail

In electrical power system engineering, different synchronous generator models with different levels of detail, such as the consideration of the field and damper windings, have been used to analyze the stability of electrical power systems [4, 5, 8, 9]. Here, we present four types of models.

- (a) **Park model** The Park model, also called **complete model**, is a model with a high level of details that considers the change in magnetic flux in the stator and

field and damper windings. It consists of a two-dimensional linear differential equation (swing equation) that expresses the mechanical dynamic characteristics of the rotor of the generator, and a five to seven-dimensional nonlinear differential equation that expresses the magnetic flux changes in the stator, field winding, and damper winding. The dimension of the latter differential equation that expresses changes in magnetic flux varies based on the number of windings to consider and the setting of variables.

The active and reactive power, which represent the electrical output of a generator, are nonlinear functions of the internal state of the generator. The models used in Japanese works consider a type of damper winding on the d-axis and two types of damper windings on the q-axis in addition to field winding on the d-axis [8]. When there is only one type of damper winding on the q-axis, if the constant is set appropriately, there are no issues in terms of practical use.

- (b) **Two-axis model** It is a model that approximates the differential equations to the algebraic equation, assuming that the time constants of the dynamic response of the magnetic flux change in the stator and damper winding are sufficiently small [9, Section 5.4]. It consists of a two-dimensional swing equation and a two-dimensional nonlinear differential equation expressing the magnetic flux change in the field and damper windings. Generally, the dynamic response of the magnetic flux change in the stator and damper winding are sufficiently fast; thus, the behavior of the Park model is generally well simplified.
- (c) **One-axis model** In contrast to the two-axis model, the one-axis model, also called **transient model**, is obtained under the assumption that the time constant of the magnetic flux change in the damper winding is sufficiently small [10-12]. It consists of a two-dimensional swing equation and a one-dimensional nonlinear differential equation that expresses the magnetic flux change in the field winding. In this book, we use a one-axis model to perform analysis. The process of deriving a one-axis model from the Park model is explained in [?, Section 5] and [?, Section 4.15].
- (d) **Classical model** It is a model that ignores the magnetic flux changes in the field and damper windings. It consists of a two-dimensional linear swing equation and the active and reactive power are nonlinear functions of the internal states of the generator. This model is currently widely used to analyze the oscillatory and synchronization phenomena of electrical power systems [10-14].




Fig. 8 Generator connected to bus bar

3.2 Mathematical expression of the one-axis model

3.2.1 Relational expression of current and voltage where the internal state of a generator is the intermediate variable

If the internal voltage of a generator i connected to a bus bar i is E_i , and the rotor argument relative to a coordinate system that rotates with a system frequency ω_0 is δ_i , the following relationship holds for the voltage phasor V_i of bus bar i and current phasor I_i flowing from the generator to the bus bar i :

$$I_i = \frac{1}{jX'_i} (E_i e^{j\delta_i} - V_i) \quad (17a)$$

where X'_i is the transient reactance of the generator. The schematic is shown in 8. The ground is omitted from the Figure.

δ_i and E_i in Equation 17a are intermediate variables that express the internal state of the generator i , which give a dynamic relationship between I_i and V_i . In other words, from the perspective of control systems engineering, Equation 17a uses δ_i and E_i as the internal state, and can be interpreted as an “output equation” of a generator i , when I_i is the output from the generator to the electrical power system and V_i is the input from the electrical power system to the generator. Equally, it can be considered that V_i is the output and I_i is the input. Details will be discussed later. By multiplying both sides of the Equation 17a with $e^{-j\delta_i}$ and considering the equation for the real part and the imaginary part separately, we can see that Equation 17a is equivalent to:

$$\begin{aligned} |V_i| \sin(\delta_i - \angle V_i) &= X'_i |I_i| \cos(\delta_i - \angle I_i), \\ |V_i| \cos(\delta_i - \angle V_i) &= E_i - X'_i |I_i| \sin(\delta_i - \angle I_i) \end{aligned} \quad (17b)$$

Active power P_i provided from the generator i to the bus bar i and can be expressed as:

$$\begin{aligned}
P_i &= \text{Re} \left[\mathbf{V}_i \bar{\mathbf{I}}_i \right] \\
&= \text{Re} \left[|\mathbf{V}_i| e^{-j(\delta_i - \angle \mathbf{V}_i)} |\mathbf{I}_i| e^{-j(\delta_i - \angle \mathbf{I}_i)} \right] \\
&= |\mathbf{V}_i| |\mathbf{I}_i| \cos(\delta_i - \angle \mathbf{V}_i) \cos(\delta_i - \angle \mathbf{I}_i) \\
&\quad + |\mathbf{V}_i| |\mathbf{I}_i| \sin(\delta_i - \angle \mathbf{V}_i) \sin(\delta_i - \angle \mathbf{I}_i)
\end{aligned}$$

Similarly, reactive power Q_i can be expressed as:

$$\begin{aligned}
Q_i &= \text{Im} \left[\mathbf{V}_i \bar{\mathbf{I}}_i \right] \\
&= |\mathbf{V}_i| |\mathbf{I}_i| \cos(\delta_i - \angle \mathbf{V}_i) \sin(\delta_i - \angle \mathbf{I}_i) \\
&\quad - |\mathbf{V}_i| |\mathbf{I}_i| \sin(\delta_i - \angle \mathbf{V}_i) \cos(\delta_i - \angle \mathbf{I}_i)
\end{aligned}$$

Thus, if current phasor is cancelled using the Equation 17b, the following can be obtained:

$$\begin{aligned}
P_i &= \frac{E_i |\mathbf{V}_i|}{X'_i} \sin(\delta_i - \angle \mathbf{V}_i), \\
Q_i &= \frac{E_i |\mathbf{V}_i|}{X'_i} \cos(\delta_i - \angle \mathbf{V}_i) - \frac{|\mathbf{V}_i|^2}{X'_i}
\end{aligned} \tag{18}$$

These expressions indicate that the phase of the bus bar voltage $\angle \mathbf{V}_i$ contributes to the active and reactive power as the difference of generator rotor argument δ_i . In typical electrical power system operation, the difference between δ_i and $\angle \mathbf{V}_i$ is small; thus, the following approximation holds:

$$P_i \simeq \frac{E_i |\mathbf{V}_i|}{X'_i} (\delta_i - \angle \mathbf{V}_i), \quad Q_i \simeq \frac{|\mathbf{V}_i|}{X'_i} (E_i - |\mathbf{V}_i|)$$

This fact indicates that a difference between δ_i and $\angle \mathbf{V}_i$ mainly contributes to the active power, while a difference between E_i and $|\mathbf{V}_i|$ contributes to the reactive power.

When the voltage phasor is the input, Equations (17) and 18 can be interpreted as an equivalent deformation of the output equation of the generator under the definition of active power and reactive power in Equation 13. Similarly, if the voltage phasor is cancelled, an output equation, when current phasor is the input, is obtained as:

$$\begin{aligned}
P_i &= E_i |\mathbf{I}_i| \cos(\delta_i - \angle \mathbf{I}_i), \\
Q_i &= E_i |\mathbf{I}_i| \sin(\delta_i - \angle \mathbf{I}_i) - X'_i |\mathbf{I}_i|^2
\end{aligned} \tag{19}$$

3.2.2 Relational expression of current and voltage in dynamic characteristics of a generator

An oscillation equation that expresses the mechanical and dynamic characteristics of a rotor of the generator can be obtained with:

$$\begin{cases} \dot{\delta}_i = \omega_0 \Delta\omega_i \\ M_i \Delta\dot{\omega}_i = -D_i \Delta\omega_i - P_i + P_{\text{mech}i} \end{cases} \quad (20a)$$

where, $\Delta\omega_i$ is the frequency deviation from the system frequency, ω_0 , M_i is the inertia constant, D_i is the damping factor, and $P_{\text{mech}i}$ is the mechanical torque. In addition, as a differential equation that expresses the attenuation of magnetic flux, the dynamic characteristics of a field circuit are given as follows:

$$\tau_i \dot{E}_i = -\frac{X_i}{X'_i} E_i + \left(\frac{X_i}{X'_i} - 1 \right) |V_i| \cos(\delta_i - \angle V_i) + V_{\text{field}i} \quad (20b)$$

where, τ_i is the time constant of the field circuit, X_i is the synchronous reactance, and $V_{\text{field}i}$ is the field voltage. From the viewpoint of generator control, mechanical torque $P_{\text{mech}i}$ and field voltage $V_{\text{field}i}$ become external inputs. Generally, $X_i > X'_i$ holds.

Summarizing the above, if two variables of voltage phasor ($|V_i|, \angle V_i$) are considered an input from the bus bar i to the generator i , the following equations become the equation of state that expresses the dynamic characteristics of the generator:

$$\begin{cases} \dot{\delta}_i = \omega_0 \Delta\omega_i \\ M_i \Delta\dot{\omega}_i = -D_i \Delta\omega_i - P_i + P_{\text{mech}i} \\ \tau_i \dot{E}_i = -\frac{X_i}{X'_i} E_i + \left(\frac{X_i}{X'_i} - 1 \right) |V_i| \cos(\delta_i - \angle V_i) + V_{\text{field}i} \end{cases} \quad (21a)$$

where the expression of Equation 18 is used for active power P_i . Two variables of current phasor derived from Equation 17b:

$$\begin{aligned} |I_i| &= \sqrt{\left\{ \frac{|V_i|}{X'_i} \sin(\delta_i - \angle V_i) \right\}^2 + \left\{ \frac{E_i}{X'_i} - \frac{|V_i|}{X'_i} \cos(\delta_i - \angle V_i) \right\}^2}, \\ \angle I_i &= \delta_i - \arctan \left(\frac{E_i - |V_i| \cos(\delta_i - \angle V_i)}{|V_i| \sin(\delta_i - \angle V_i)} \right) \end{aligned} \quad (21b)$$

become the output from the generator i to the bus bar i . As discussed above, based on the definition of Equation 13, a set of active power and reactive power of Equation 18, (P_i, Q_i) , can be considered as an output that is mathematically equivalent to $(|I_i|, \angle I_i)$.

Similarly, two variables of current phasor ($|I_i|, \angle I_i$) can be considered an input from the bus bar i to the generator i . In this case,

$$\begin{cases} \dot{\delta}_i = \omega_0 \Delta\omega_i \\ M_i \Delta\dot{\omega}_i = -D_i \Delta\omega_i - P_i + P_{\text{mech}i} \\ \tau_i \dot{E}_i = -E_i - (X_i - X'_i) |I_i| \sin(\delta_i - \angle I_i) + V_{\text{field}i} \end{cases} \quad (22a)$$

becomes the equation of state that expresses the dynamic characteristics of the generator. where the expression of Equation 19 is used for active power P_i . In addition, two variables of the voltage phasor derived from Equation 17b:

$$\begin{aligned} |V_i| &= \sqrt{\{X'_i |I_i| \cos(\delta_i - \angle I_i)\}^2 + \{E_i - X'_i |I_i| \sin(\delta_i - \angle I_i)\}^2}, \\ \angle V_i &= \delta_i - \arctan\left(\frac{X'_i |I_i| \cos(\delta_i - \angle I_i)}{E_i - X'_i |I_i| \sin(\delta_i - \angle I_i)}\right) \end{aligned} \quad (22b)$$

become an output from the generator to the bus bar. The set of active power and reactive power of Equation 19, (P_i, Q_i) , can also be considered as an output that is mathematically equivalent to $(|V_i|, \angle V_i)$.

The unit of each variable is as follows: The unit for rotor argument δ_i , phase for voltage phasor $\angle V_i$, and phase of current phasor $\angle I_i$ of the bus bar is [rad]. Sine frequency deviation $\Delta\omega_i$, internal voltage E_i , absolute value of voltage phasor $|V_i|$, absolute value of current phasor $|I_i|$, active power P_i , active power Q_i , mechanical torque $P_{\text{mech}i}$, and field voltage $V_{\text{field}i}$ are dimensionless values divided by their reference value, and their unit is [pu]. This means “per unit.” If system frequency ω_0 is 50 [Hz], its value is set as 100π . Therefore, unit of $\omega_0 \Delta\omega_i$ is [rad/s].

3.2.3 Relationship with the classical model

With the above one-axis model, the dynamic characteristics of the internal voltage of the generator E_i are taken into consideration. However, in the classical model, this internal voltage is assumed to be constant. Specifically, the following is assumed for the differential equation of internal voltage E_i in Equations (20) and (21):

- Synchronous reactance X_i and transient reactance X'_i are equal, and
- field voltage $V_{\text{field}i}$ is constant.

At this time, if constant of the field voltage is expressed as V_i^* , the steady solution for the differential equation of Equation 20b is $E_i(t) = V_i^*$. In other words, internal voltage E_i becomes V_i^* , which is constant. For the significance and concern of the classical model in an electrical power system analysis, please refer to [?, Section 2.11].

3.3 Kron reduction of a generator bus

In this Section, we analyze an electrical power system model, where the synchronous generator as equipment is connected to each bus bar. At this time, if a subscript set of generator buses is expressed as \mathcal{I}_G , the number of generator buses $|\mathcal{I}_G|$ is equal to the total number of bus bars N . The model for the entire electrical power system is described as “a differential algebraic equation system,” where generators described by Equation 21a are combined through the output equation of Equation 21b based on the input-output relationship of the algebraic equation of Equation 11.

COFFEE BREAK

Differential algebraic equation system: is a system that is described by differential algebraic equations and algebraic equations as follows:

$$\begin{cases} \dot{x}_1 &= f_1(x_1, x_2) \\ 0 &= f_2(x_1, x_2) \end{cases}$$

where x_1 is the stat of the differential equation and x_2 is the stat the algebraic equation. For example, in a system where generator models of Equation (21) are combined with the algebraic equation of the power grid in Equation 12, the vector with the internal state of all generators, $\delta_i, \Delta\omega_i, E_i$, is x_1 , while the vector w variab s of all bus bar voltage phasors, $|V_i|, \angle V_i$, is x_2 . When the algebraic equation has a solution for x_2 , the solution expressed as $x_2 = h(x_1)$. When this is substituted into the differential equation:

$$\dot{x}_1 = f_1(x_1, h(x_1))$$

is an equivalent ordinary differential equation system that describes the behavior of x_1 .

The objective of this Section is to equivalently transform a differential algebraic equation system through the current phasor and voltage phasor of the generator bus to an ordinary differential equation system described only by the state variables of generators by expressing all voltage phasor variables $(|V_i|, \angle V_i)_{i \in \mathcal{I}_G}$ as a function of the state variables of generators $(\delta_i, E_i)_{i \in \mathcal{I}_G}$. This transformation is called **Kron reduction of the generator bus**. The specific steps are as follows:

- (a) Eliminate the current phasor of bus bars $(I_i)_{i \in \mathcal{I}_G}$ from the algebraic equation of the power grid in Equation 11 and the output equation of the generator in Equation 17a, and express voltage phasor $(V_i)_{i \in \mathcal{I}_G}$ as a function of state variables $(\delta_i, E_i)_{i \in \mathcal{I}_G}$.
- (b) Using the relationship below as obtained from Euler’s formula:

$$e^{j\delta_i} \bar{V}_i = |V_i| \cos(\delta_i - \angle V_i) + j|V_i| \sin(\delta_i - \angle V_i)$$

and rewrite the term of trigonometric function related to V_i included in the model by the state variables $(\delta_i, E_i)_{i \in I_G}$.

First, let us consider step (a). If the output equation of Equation 17a is expressed as a vector:

$$\begin{bmatrix} \mathbf{I}_1 \\ \vdots \\ \mathbf{I}_N \end{bmatrix} = \text{diag} \left(\frac{1}{jX'_i} \right) \left(\text{diag} \left(e^{j\delta_i} \right) \begin{bmatrix} E_1 \\ \vdots \\ E_N \end{bmatrix} - \begin{bmatrix} V_1 \\ \vdots \\ V_N \end{bmatrix} \right)$$

If the current phasor is cancelled using the algebraic equation of the power grid in Equation 11, and the equation is solved for the voltage phasor, the following is obtained:

$$\begin{bmatrix} V_1 \\ \vdots \\ V_N \end{bmatrix} = \left(\text{diag} \left(\frac{1}{jX'_i} \right) + Y \right)^{-1} \text{diag} \left(\frac{e^{j\delta_i}}{jX'_i} \right) \begin{bmatrix} E_1 \\ \vdots \\ E_N \end{bmatrix} \quad (23)$$

In this manner, voltage phasor $(V_i)_{i \in I_G}$ of the bus bars is equivalently expressed by the state variables of generators $(\delta_i, E_i)_{i \in I_G}$.

Next, let us consider step (b). If the voltage phasor of the bus bar is expressed with a polar form:

$$V_i = |V_i| e^{j\angle V_i}$$

and the complex conjugate for the whole is taken by multiplying Equation 23 with $\text{diag}(\frac{e^{-j\delta_i}}{X'_i})$ from the left, the following is obtained:

$$\begin{bmatrix} \frac{|V_1|}{X'_1} e^{j(\delta_1 - \angle V_1)} \\ \vdots \\ \frac{|V_N|}{X'_N} e^{j(\delta_N - \angle V_N)} \end{bmatrix} = \text{diag} \left(e^{j\delta_i} \right) \mathbf{\Gamma}^{-1} \text{diag} \left(e^{-j\delta_i} \right) \begin{bmatrix} E_1 \\ \vdots \\ E_N \end{bmatrix} \quad (24)$$

where $\mathbf{\Gamma} \in \mathbb{C}^{N \times N}$ is a complex square matrix defined by:

$$\mathbf{\Gamma} := \text{diag} (X'_i) - j \text{diag} (X'_i) \bar{Y} \text{diag} (X'_i) \quad (25)$$

In Equation 24, if the (i, j) th element of $\mathbf{\Gamma}^{-1}$ is expressed as γ_{ij}^{-1} , the following expression is obtained:

$$\text{diag} \left(e^{j\delta_i} \right) \mathbf{\Gamma}^{-1} \text{diag} \left(e^{-j\delta_i} \right) = \begin{bmatrix} \gamma_{11}^{-1} e^{j(\delta_1 - \delta_1)} & \dots & \gamma_{1N}^{-1} e^{j(\delta_1 - \delta_N)} \\ \vdots & \ddots & \vdots \\ \gamma_{N1}^{-1} e^{j(\delta_N - \delta_1)} & \dots & \gamma_{NN}^{-1} e^{j(\delta_N - \delta_N)} \end{bmatrix}$$

Thus, the real part and imaginary part of the (i, j) th element can be written as:

$$\begin{aligned}\operatorname{Re} \left[\gamma_{ij}^{-1} e^{j(\delta_i - \delta_j)} \right] &= -B_{ij}^{\text{red}} \cos(\delta_i - \delta_j) - G_{ij}^{\text{red}} \sin(\delta_i - \delta_j), \\ \operatorname{Im} \left[\gamma_{ij}^{-1} e^{j(\delta_i - \delta_j)} \right] &= -B_{ij}^{\text{red}} \sin(\delta_i - \delta_j) + G_{ij}^{\text{red}} \cos(\delta_i - \delta_j)\end{aligned}$$

where reduced conductance and susceptance are defined as:

$$G_{ij}^{\text{red}} := \operatorname{Im} \left[\gamma_{ij}^{-1} \right], \quad B_{ij}^{\text{red}} := -\operatorname{Re} \left[\gamma_{ij}^{-1} \right] \quad (26)$$

Here, a matrix \mathbf{Y}^{red} of reduced admittance:

$$\mathbf{Y}_{ij}^{\text{red}} := G_{ij}^{\text{red}} + jB_{ij}^{\text{red}}$$

is called a **reduced admittance matrix**. This is equal to defining as follows using the above complex matrix $\mathbf{\Gamma}^{-1}$:

$$\mathbf{Y}^{\text{red}} := -j\mathbf{\Gamma}^{-1} \quad (27)$$

By using this reduced admittance matrix, the term that includes voltage phasor variables of the bus bar in a generator model ($|V_i|, \angle V_i$) can be rewritten as:

$$\begin{aligned}\frac{|V_i|}{X'_i} \cos(\delta_i - \angle V_i) &= -\sum_{j=1}^N E_j \{ B_{ij}^{\text{red}} \cos(\delta_i - \delta_j) + G_{ij}^{\text{red}} \sin(\delta_i - \delta_j) \}, \\ \frac{|V_i|}{X'_i} \sin(\delta_i - \angle V_i) &= -\sum_{j=1}^N E_j \{ B_{ij}^{\text{red}} \sin(\delta_i - \delta_j) - G_{ij}^{\text{red}} \cos(\delta_i - \delta_j) \}\end{aligned} \quad (28)$$

Please note that the trigonometric function term related to the voltage phasor of the bus bar on the left side is expressed by the rotor argument difference $\delta_i - \delta_j$ and internal voltage E_i of the generators on the right side. Therefore, a differential algebraic equation model of an electrical power system, in which the generator model of Equation (21) is combined by the simultaneous equation of Equation 11, can be equivalently expressed as a simultaneous ordinary differential equation system related to all $i \in \mathcal{I}_G$.

$$\begin{cases} \dot{\delta}_i = \omega_0 \Delta \omega_i \\ M_i \Delta \dot{\omega}_i = -D_i \Delta \omega_i - f_i(\delta, E) + P_{\text{mech}i} \\ \tau_i \dot{E}_i = -\frac{X_i}{X'_i} E_i + (X_i - X'_i) g_i(\delta, E) + V_{\text{field}i} \end{cases} \quad i \in \mathcal{I}_G \quad (29)$$

However, δ and E are vectors with δ_i and E_i in columns, expressing a nonlinear term that expresses interaction between generators.




Fig. 9 Changes in bond structure due to Kron reduction

$$\begin{aligned}
 f_i(\delta, E) &:= -E_i \sum_{j=1}^N E_j (B_{ij}^{\text{red}} \sin \delta_{ij} - G_{ij}^{\text{red}} \cos \delta_{ij}) \\
 g_i(\delta, E) &:= - \sum_{j=1}^N E_j (B_{ij}^{\text{red}} \cos \delta_{ij} + G_{ij}^{\text{red}} \sin \delta_{ij})
 \end{aligned} \tag{30}$$

It was defined as $\delta_{ij} := \delta_i - \delta_j$.

Based on the expression of the ordinary differential equation system of Equation 29, only the relative difference of rotor argument δ_i of a generator and rotor argument $(\delta_j)_{j \in \mathcal{I}_G \setminus \{i\}}$ of all the other generators has an impact on the behavior of generators i . Furthermore, by comparing with Equation 21a, we can see that function $f_i(\delta, E)$ of Equation 29 expresses active power P_i output by the generators. If the real part of the admittance matrix \mathbf{Y} is 0; in other words, if the conductance of all transmission lines is 0 (equivalent resistance is 0), reduced conductance G_{ij}^{red} also becomes 0 for all (i, j) . As will be discussed in Section ??, this corresponds to when there is no transmission loss of active power in the power grid.

In addition, though the admittance matrix \mathbf{Y} is a sparse matrix that reflects the graph structure of the power grid, the reduced admittance matrix \mathbf{Y}^{red} in Equation 29 is usually not a sparse matrix. Therefore, please note that an ordinary differential equation system of Equation 29 has a combined structure in which the internal state of all generators densely interact (9). Let us confirm this fact with numerical examples along with the behavior of the electrical power system model.

COFFEE BREAK

Sparse and dense matrices: A matrix with many 0 elements is called a **sparse matrix**. In contrast, a matrix with almost no 0 elements is called a **dense matrix**. However, how many 0 elements are necessary to call a matrix sparse depends on the context. The inverse matrix of a sparse matrix that is not a diagonal matrix is usually a dense matrix.

Example 1.3 Behavior of an electrical power system model where a generator bus is reduced Let us consider an electrical power system model consisting of three

Table 1 Physical constants of the generator model

i	M_i [s]	D_i [pu]	τ_i [s]	X_i [pu]	X'_i [pu]
1	100	10	5.14	1.569	0.936
2	18	10	5.90	1.651	0.911
3	12	10	8.97	1.220	0.667

Table 2 Steady-state values of external inputs and internal conditions of the generator

i	$P_{mech_i}^*$ [pu]	$V_{field_i}^*$ [pu]	δ_i^* [rad]	$\Delta\omega_i^*$ [pu]	E_i^* [pu]
1	-0.5623	1.5132	0.4656	0	1.4363
2	0.8832	2.2216	1.0903	0	1.8095
3	-0.3160	0.9198	0.6067	0	1.1030

bus bars as discussed in Example 1.1. Here, the one-axis generator model that was explained in Section 3.2 is connected to each bus bar. In other words, the electrical power system model can be drawn as shown in the left image in 9. For the physical constant of the generators, values from 1 are used. Since the system frequency is set to 60 [Hz], the value of ω_0 is 120π .

The admittance of the two transmission lines is set as:

$$y_{12} = 1.3652 - j11.6041, \quad y_{23} = 1.9422 - j10.5107 \quad (31)$$

In this manner, the admittance matrix of the power grid in Equation 10 is obtained. In addition, if we calculate the real part (reduced conductance matrix) and the imaginary part (reduced susceptance matrix) of the reduced admittance matrix Y^{red} of Equation 27, the following is obtained:

$$G^{\text{red}} = \begin{bmatrix} 0.0073 & 0.0005 & -0.0079 \\ 0.0005 & 0.0041 & -0.0046 \\ -0.0079 & -0.0046 & 0.0125 \end{bmatrix},$$

$$B^{\text{red}} = \begin{bmatrix} -0.3716 & -0.3167 & -0.3800 \\ -0.3167 & -0.3550 & -0.4260 \\ -0.3800 & -0.4260 & -0.6933 \end{bmatrix}$$

It shows that both are dense matrices. This dense structure corresponds to the right image of 9.

Next, let us calculate the time response of an ordinary differential equation system model of Equation 29. Below, we obtain the initial response when the external input, mechanical torque and field voltage are fixed as constant. In this example, we use the steady state calculation method, which will be discussed in Section ??, and assume that the external input of the electrical power system model and steady value of the internal state have been obtained in advance. Specifically, the external input, mechanical torque and field voltage are set to constants in the first and second columns of 2. In this case, the steady value of the internal state of the electrical

power system are values in the third to fifth columns in 2. These steady values are one of the solutions that satisfy simultaneous equations:

$$\begin{cases} 0 = -f_i(\delta^*, E^*) + P_{\text{mech}i}^* \\ 0 = -\frac{X_i}{X_i'} E_i^* + (X_i - X_i') g_i(\delta^*, E^*) + V_{\text{field}i}^* \end{cases} \quad i \in \{1, 2, 3\}$$

where δ^* and E^* are vectors with δ_i^* and E_i^* . Functions f_i and g_i are defined by Equation ??.

First, let us consider a situation where the steady value is perturbed to set the initial value. Specifically:

$$\begin{bmatrix} \delta_1(0) \\ \delta_2(0) \\ \delta_3(0) \end{bmatrix} = \begin{bmatrix} \delta_1^* + \frac{\pi}{6} \\ \delta_2^* \\ \delta_3^* \end{bmatrix}, \quad \begin{bmatrix} E_1(0) \\ E_2(0) \\ E_3(0) \end{bmatrix} = \begin{bmatrix} E_1^* + 0.1 \\ E_2^* \\ E_3^* \end{bmatrix} \quad (32)$$

where the initial value of the frequency deviation is 0. The time response of the electrical power system model at this time is shown in 10. This figure shows that, after frequency deviation and rotor argument were perturbed for about 15 seconds, they asymptotically converge to the original steady state. However, since only the relative difference among generators is meaningful in the rotor argument, the convergence value of the rotor argument shifts by a constant from the original steady value. In other words, for a certain constant c_0 :

$$\lim_{t \rightarrow \infty} \delta_i(t) = \delta_i^* + c_0, \quad \forall i \in \{1, 2, 3\}$$

For any value of c_0 , the steady value is essentially equivalent. The voltage phasor of the bus bar shown in 10 can be calculated independently of the internal state of the generators using the relationship in Equation 23. Similarly, the active and reactive power can be calculated independently using Equation 19. Furthermore, since the system frequency is set to 60 [Hz], 5×10^{-3} [pu] of the frequency deviation is equal to 0.3 [Hz].

Next, let us consider a case wherein the value of the external input is perturbed. Specifically, the mechanical torque of generator 1 is perturbed:

$$\begin{bmatrix} P_{\text{mech}1}(t) \\ P_{\text{mech}2}(t) \\ P_{\text{mech}3}(t) \end{bmatrix} = \begin{bmatrix} P_{\text{mech}1}^* + 0.05 \\ P_{\text{mech}2}^* \\ P_{\text{mech}3}^* \end{bmatrix}$$

11 shows the time response of the electrical power system model under this condition. The initial value is set to be the same as the value in Equation 32. The phase of the rotor argument and the voltage phasor of the bus bar voltage phasor express the remainder when divided by 2π . In this case, the frequency deviation does not become 0 under a steady state, and the rotor argument where it has been integrated continues to change constantly. 12 shows the time response of the electrical power system model when field voltage of generator 1 is similarly perturbed:

$$\begin{bmatrix} V_{\text{filed1}}(t) \\ V_{\text{filed2}}(t) \\ V_{\text{filed3}}(t) \end{bmatrix} = \begin{bmatrix} V_{\text{filed1}}^* + 0.5 \\ V_{\text{filed2}}^* \\ V_{\text{filed3}}^* \end{bmatrix}$$

In this situation as well, the frequency deviation in a steady state does not become 0. As such, to calculate the time response of an electrical power system model, not only must the initial value be set to the appropriate values, but the external inputs, mechanical torque and field voltage as well.

Since Equation 29 is an ordinary differential equation system model, by using a differential equation solver, which is a standard add-on in MATLAB, its behavior can be numerically simulated. However, as shown in example 1.3, unless the value of the mechanical torque and the field voltage are set appropriately, the frequency deviation of each generator under a steady state does not become 0, and the rotor argument constantly deviates from the reference coordinates. Thus, to perform a numerical simulation that is realistically meaningful, a process to calculate valid equilibrium points and initial values is necessary. These details will be explained in Chapter ??.

3.4 Derivation of the Kuramoto-type oscillator model

By applying Kron reduction of generator bus to the classical model explained in Section 3.2, the Kuramoto-type oscillator model can be derived. Specifically, if we assume that the value of synchronous reactance X_i and transient reactance X'_i are equal, and field voltage $V_{\text{field}i}$ is constant at V_i^* , the internal voltage E_i becomes V_i^* and is constant. Therefore, the electrical power system model in which a generator is connected to each bus bar is expressed with a differential equation system model.

$$\begin{cases} \dot{\delta}_i = \omega_0 \Delta \omega_i \\ M_i \Delta \dot{\omega}_i = -D_i \Delta \omega_i - \hat{f}_i(\delta) + P_{\text{mech}i} \end{cases} \quad i \in \mathcal{I}_G \quad (33)$$

However, the nonlinear term is given by:

$$\hat{f}_i(\delta) := -V_i^* \sum_{j=1}^N V_j^* \left(B_{ij}^{\text{red}} \sin \delta_{ij} - G_{ij}^{\text{red}} \cos \delta_{ij} \right)$$

Function $\hat{f}_i(\delta)$ expresses the active power of a generator i . An electrical power system model, where it is assumed that the conductance of a transmission line is 0; in other words, G_{ij}^{red} is 0, is occasionally used.

COFFEE BREAK

Translated with DeepL
Kuramoto model:




Fig. 10 Time response when perturbation is added to the initial value
 ((Blue: Bus 1, Black: Bus 2, Red: Bus 3))

The following differential equation system with N oscillators moving on the circumference

$$\dot{\theta}_i = \omega_i - \frac{K}{N} \sum_{j=1}^N \sin(\theta_i - \theta_j), \quad i = 1, \dots, N$$

is called **Kuramoto model**. However, ω_i is a constant representing the intrinsic angular velocity of the oscillator i , and K is a constant representing the bond strength. In general, the angular velocity of the oscillator $\dot{\theta}_1$, when the bond strength K is large enough compared to the magnitude of the inhomogeneity of the intrinsic angular velocity $\omega_1, \dots, \omega_N$. It has the property that $\dot{\theta}_1, \dots, \dot{\theta}_N$ are asymptotically synchronized.

The Kuramoto model has been analyzed mainly in the field of physics as a mathematical model describing synchronization phenomena of nonlinear oscillators,




Fig. 11 Time response when perturbation is added to machine input
(Blue: Bus 1, Black: Bus 2, Red: Bus 3)

and is known to have a wide range of applications [?, ?]. The model extended to the second-order nonlinear oscillator system with inertia is also applied to the analysis of the synchronization phenomenon of the power system [?, ?, ?, ?].

3.5 Single machine infinite bus system model

In basic mathematical analysis in electrical power system engineering, for example, a simplified electrical power system model, called a **single machine infinite bus system model**, such as [?, Section 1.3] and [?, Section 6.3, Section 8.3], is often used. The single machine infinite bus system model is an electrical power system model consisting of a generator, transmission line, and infinite bus bar as shown in




Fig. 12 Time response when perturbation is applied to the field input
(Blue: Bus 1, Black: Bus 2, Red: Bus 3)




Fig. 13 1 infinity bus system model

13. The infinite bus bar is interpreted as a rough approximation of the entire electrical power system, except for the generator of interest, as a “fixed voltage source.”

Specifically, we assume that voltage phasor of the infinite bus bar V_0 is maintained as a constant, independent of the internal state of the generator. In other words, considering electric power that is lost in transmission, the active and reactive power generated by the generator are assumed to be consumed each moment, without excess or deficiency, by the infinite bus bar.

As follows, since there is only one generator of interest, we omit the subscript i , and note the variables of the generator and generator bus. For the dynamic characteristics of the generator expressed in Equation (21), the voltage phasor V and current phasor I of a generator bus have the following relationship:

$$I = y(V - V_0)$$

This is the algebraic equation that determines the input-output relationship of the generator and the electrical power system. For reference, let us derive an ordinary differential equation model obtained through Kron reduction for a single machine infinite bus bar system when the resistance of a transmission line is 0, and the reactance is x ; in other words, the admittance of a transmission line is:

$$y = \frac{1}{jx}$$

Specifically, using the same procedure as that used for Kron reduction of a generator bus in Section 3.3, the following two equations are used:

$$I = \frac{1}{jx}(V - V_0), \quad I = \frac{1}{jX'}(Ee^{j\delta} - V)$$

to cancel the current phasor and voltage phasor of the generator bus. When the voltage phasor is cancelled and the Equation is reorganized, the following is obtained:

$$|I|e^{j(\delta - \angle I)} = -\frac{E - |V_0|e^{j\delta}}{j(X' + x)}$$

It is assumed that $\angle V$ is 0 with the phase of voltage phasor of the infinite bus bar as the reference, and generality is not lost. Therefore, by substituting the relationship of this current phasor into Equation 22a, the expression of the ordinary differential equation system is obtained as follows:

$$\begin{cases} \dot{\delta} = \omega_0 \Delta\omega \\ M\Delta\dot{\omega} = -D\Delta\omega - \frac{E|V_0|}{X' + x} \sin \delta + P_{\text{mech}} \\ \tau \dot{E} = -\frac{X + x}{X' + x} E + \frac{X - X'}{X' + x} |V_0| \cos \delta + V_{\text{field}} \end{cases}$$

Similarly, the active and reactive power supplied from the generator to the generator bus are obtained as follows from the relationship of Equation 19:

$$P = \frac{E|V_0| \sin \delta}{X' + x}, \quad Q = \frac{x E^2 + (X' - x)E|V_0| \cos \delta - X'|V_0|^2}{(X' + x)^2}$$

As a reference, we introduced the single machine infinite bus system model, but since we focus on an analysis of an electrical power system model consisting of multiple generators in this book, analysis with this model is basically not performed.

3.6 Mathematical properties of the admittance matrix with reduced generator bus

Below, we mathematically discuss the existence and definiteness of the reduced admittance matrix \mathbf{Y}^{red} of Equation 27. Let us remember that with the admittance matrix \mathbf{Y}_0 when the capacitance to ground of Equation (15) can be ignored, the real part of the conductance matrix G_0 is positive semi-definite and the imaginary part of the susceptance matrix B_0 is negative definite. The reduced admittance matrix also has a similar definiteness. Below, the reduced conductance matrix and reduced susceptance matrix, the real and imaginary parts of \mathbf{Y}^{red} , are expressed as follows:

$$\mathbf{G}^{\text{red}} := \text{Re}[\mathbf{Y}^{\text{red}}], \quad \mathbf{B}^{\text{red}} := \text{i}[\mathbf{Y}^{\text{red}}] \quad (34)$$

At this time, the following facts are indicated.

Theorem 1.1 (existence and definiteness of the reduced admittance matrix) *If the following is true for the admittance matrix $\mathbf{Y} \in \mathbb{C}^{N \times N}$ of Equation 16:*

$$b_i X'_i \leq 1, \quad \forall i \in \mathcal{I}_G \quad (35)$$

And the inequality holds exactly for Equation 35 for at least one generator bus at the same time, $\mathbf{\Gamma}$ of Equation 25 is nonsingular. At this time, for the admittance matrix \mathbf{Y}^{red} of Equation 27, the reduced conductance matrix \mathbf{G}^{red} is positive semi-definite, and the reduced susceptance matrix \mathbf{B}^{red} is negative definite.

Proof Translated with DeepL By using the complementary reflex: nonsing at the end of the chapter, we show the regularity of $\mathbf{\Gamma}$ in the formula 25. From the definition, if the real part of $\mathbf{\Gamma}$ is \mathbf{M} and the imaginary part is \mathbf{N} , then

$$\begin{aligned} \mathbf{M} &:= \text{diag}(\mathbf{X}'_i(1 - b_i X'_i)) - \text{diag}(\mathbf{X}'_i) \mathbf{B}_0 \text{diag}(\mathbf{X}'_i), \\ \mathbf{N} &:= -\text{diag}(\mathbf{X}'_i) \mathbf{G}_0 \text{diag}(\mathbf{X}'_i) \end{aligned}$$

Here, since \mathbf{B}_0 in equation 16 is semi-negative definite, \mathbf{M} is at least semi-positive definite when equation 35 holds. If $b_i X'_i < 1$ for at least one $i \in \mathcal{I}_G$, then

$$\underbrace{\ker \text{diag}(\mathbf{X}'_i) \mathbf{B}_0 \text{diag}(\mathbf{X}'_i)}_{\text{span}\{\text{diag}(1/X'_i) \mathbf{1}\}} \not\subseteq \ker \text{diag}(\mathbf{X}'_i(1 - b_i X'_i))$$

then, \mathbf{M} is positive definite. Therefore, since \mathbf{N} is symmetric, $\mathbf{M} + \mathbf{N}\mathbf{M}^{-1}\mathbf{N}$ is positive definite. This implies that $\mathbf{M} + \mathbf{N}\mathbf{M}^{-1}\mathbf{N}$ is regular. Also, since \mathbf{N} is semi-negative definite from the relation in equation 15b, from the complement 1.2 at the end of the chapter, it can be shown that the real part of $\mathbf{\Gamma}^{-1}$ is positive definite and the imaginary part is semi-negative definite. Therefore, the real part \mathbf{G}^{red} of \mathbf{Y}^{red} is semipositive definite and the imaginary part \mathbf{B}^{red} is negative definite. \square

Inequality in Equation 35 is the condition required for $\mathbf{\Gamma}$ to be nonsingular. However, if $b_i X'_i$ is 1 for all generator buses, $\mathbf{\Gamma}$ is no longer nonsingular. If all b_i is

sufficiently small; in other words, if the capacitance to ground of each transmission line can be ignored as in the Example 1.1, inequality of Equation 35 holds. At this time, the reduced conductance matrix G^{red} , the real part of Y^{red} , is positive semi-definite. The imaginary part, the reduced susceptance matrix B^{red} , is negative definite. For this reason, the definiteness of the admittance matrix is invariable to the Kron reduction.

3.7 Mathematical model for salient pole synchronous generators

Let us look at a salient pole generator model that incorporates the difference in the reactance of the d-axis and q-axis. Specifically, let us consider a situation where Equation 17b is as follows:

$$\begin{aligned} |V_i| \sin(\delta_i - \angle V_i) &= X_{qi} |I_i| \cos(\delta_i - \angle I_i), \\ |V_i| \cos(\delta_i - \angle V_i) &= E_i - X'_{di} |I_i| \sin(\delta_i - \angle I_i) \end{aligned} \quad (36)$$

X'_{di} is the transient reactance of the d-axis. If X'_{di} and X_{qi} are equal X'_i , Equation 36 is consistent with Equation 17b.

When cancelling the current phasor using Equation 36, the active and reactive power are expressed as:

$$\begin{aligned} P_i &= \frac{|V_i| E_i}{X'_{di}} \sin(\delta_i - \angle V_i) \\ &\quad - \left(\frac{1}{X'_{di}} - \frac{1}{X_{qi}} \right) |V_i|^2 \sin(\delta_i - \angle V_i) \cos(\delta_i - \angle V_i), \\ Q_i &= \frac{|V_i| E_i}{X'_{di}} \cos(\delta_i - \angle V_i) \\ &\quad - |V_i|^2 \left(\frac{\cos^2(\delta_i - \angle V_i)}{X'_{di}} + \frac{\sin^2(\delta_i - \angle V_i)}{X_{qi}} \right) \end{aligned} \quad (37)$$

Similarly, if the voltage phasor is cancelled, the following is obtained:

$$\begin{aligned} P_i &= E_i |I_i| \cos(\delta_i - \angle I_i) \\ &\quad - (X'_{di} - X_{qi}) |I_i|^2 \sin(\delta_i - \angle I_i) \cos(\delta_i - \angle I_i), \\ Q_i &= E_i |I_i| \sin(\delta_i - \angle I_i) \\ &\quad - |I_i|^2 \{ X'_{di} \sin^2(\delta_i - \angle I_i) + X_{qi} \cos^2(\delta_i - \angle I_i) \} \end{aligned} \quad (38)$$

The oscillation equation and dynamic characteristics of generators combined with magnetic flux attenuation are given with the following in the same manner as Equation (21):

$$\begin{cases} \dot{\delta}_i = \omega_0 \Delta \omega_i \\ M_i \Delta \dot{\omega}_i = -D_i \Delta \omega_i - P_i + P_{\text{mech}i} \\ \tau_i \dot{E}_i = -\frac{X_{di}}{X'_{di}} E_i + \left(\frac{X_{di}}{X'_{di}} - 1 \right) |V_i| \cos(\delta_i - \angle V_i) + V_{\text{field}i} \end{cases} \quad (39a)$$

However, for active power P_i , the expression of Equation 37 is used. Here, the voltage phasor is considered an input from the electrical power system to the generator i . In addition, the current phasor becomes an output from the generator to the electrical power system:

$$\begin{aligned} |I_i| &= \sqrt{\left\{ \frac{|V_i|}{X_{qi}} \sin(\delta_i - \angle V_i) \right\}^2 + \left\{ \frac{E_i}{X'_{di}} - \frac{|V_i|}{X'_{di}} \cos(\delta_i - \angle V_i) \right\}^2}, \\ \angle I_i &= \delta_i - \arctan \left(\frac{\frac{E_i}{X'_{di}} - \frac{|V_i|}{X'_{di}} \cos(\delta_i - \angle V_i)}{\frac{|V_i|}{X_{qi}} \sin(\delta_i - \angle V_i)} \right) \end{aligned} \quad (39b)$$

This is derived from Equation 36. Similarly, if current phasor is considered as an input from the electrical power system to the generator i , the following becomes the equation of state that expresses the dynamic characteristics of the generator:

$$\begin{cases} \dot{\delta}_i = \omega_0 \Delta \omega_i \\ M_i \Delta \dot{\omega}_i = -D_i \Delta \omega_i - P_i + P_{\text{mech}i} \\ \tau_i \dot{E}_i = -E_i - (X_{di} - X'_{di}) |I_i| \sin(\delta_i - \angle I_i) + V_{\text{field}i} \end{cases} \quad (40a)$$

For active power P_i , the expression of Equation 38 is used. The voltage phasor obtained from:

$$\begin{aligned} |V_i| &= \sqrt{\left\{ X_{qi} |I_i| \cos(\delta_i - \angle I_i) \right\}^2 + \left\{ E_i - X'_{di} |I_i| \sin(\delta_i - \angle I_i) \right\}^2}, \\ \angle V_i &= \delta_i - \arctan \left(\frac{X_{qi} |I_i| \cos(\delta_i - \angle I_i)}{E_i - X'_{di} |I_i| \sin(\delta_i - \angle I_i)} \right) \end{aligned} \quad (40b)$$

which is derived from Equation 36, is an output from the generator to the electrical power system. This salient pole generators model assumes that X'_{di} and X_{qi} are equal and X'_i , and if X_{di} is substituted with X_i , it becomes consistent with the generator model discussed in Section 3.2. The relationship, $X_{di} > X_{qi} > X'_{di}$ usually holds between these reactances.

COFFEE BREAK

Translated with DeepL **Relationship between generator models:** The relationship between the 2-axis model, 1-axis model, and classical model can be understood as the difference in the magnitude of the time constant in the dynamic characteristics of magnetic flux attenuation. The equation of state of the 2-axis model when the voltage phasor of the bus is regarded as the input is

$$\begin{cases} \dot{\delta}_i &= \omega_0 \Delta \omega_i \\ M_i \Delta \dot{\omega}_i &= -D_i \Delta \omega_i - P_i + P_{\text{mech}i} \\ \tau_{di} \dot{E}_{qi} &= -\frac{X_{di}}{X'_{di}} E_{qi} + \left(\frac{X_{di}}{X'_{di}} - 1 \right) V_{qi} + V_{\text{field}i} \\ \tau_{qi} \dot{E}_{di} &= -\frac{X_{qi}}{X'_{qi}} E_{di} + \left(\frac{X_{qi}}{X'_{qi}} - 1 \right) V_{di} \end{cases}$$

However, X'_{qi} is the transient reactance of the q axis.

$$V_{di} := |V_i| \sin(\delta_i - \angle V_i), \quad V_{qi} := |V_i| \cos(\delta_i - \angle V_i)$$

Also, the output equations for active power and reactive power are:

$$\begin{cases} P_i &= \frac{E_{qi}}{X'_{di}} V_{di} - \frac{E_{di}}{X'_{qi}} V_{qi} + \left(\frac{1}{X'_{qi}} - \frac{1}{X'_{di}} \right) V_{di} V_{qi}, \\ Q_i &= \frac{E_{qi}}{X'_{di}} V_{qi} + \frac{E_{di}}{X'_{qi}} V_{di} - \left(\frac{V_{di}^2}{X'_{qi}} + \frac{V_{qi}^2}{X'_{di}} \right) \end{cases}$$

Note that the state variables of the internal voltage have increased to two, E_{di} and E_{qi} . This two-axis model is known to match the salient pole-type one-axis model in the limit when the time constant τ_{qi} is small enough. Specifically, assuming that τ_{qi} is formally 0, the state variable E_{di} satisfies the following relationship over time.

$$0 = -\frac{X_{qi}}{X'_{qi}} E_{di} + \left(\frac{X_{qi}}{X'_{qi}} - 1 \right) V_{di}$$

At this time, the active power and the active power are

$$\begin{cases} P_i &= \frac{E_{qi}}{X'_{di}} V_{di} + \left(\frac{1}{X'_{qi}} - \frac{1}{X'_{di}} \right) V_{di} V_{qi}, \\ Q_i &= \frac{E_{qi}}{X'_{di}} V_{qi} - \left(\frac{V_{di}^2}{X'_{qi}} + \frac{V_{qi}^2}{X'_{di}} \right) \end{cases}$$

That is, the dynamic characteristics of the generator model match those of the salient pole type uniaxial model. Furthermore, in the limit when the time constant τ_{di} is also small enough

$$\begin{cases} P_i &= \frac{V_{\text{field}i}}{X_{di}} V_{di} + \left(\frac{1}{X_{qi}} - \frac{1}{X_{di}} \right) V_{di} V_{qi}, \\ Q_i &= \frac{V_{\text{field}i}}{X_{di}} V_{qi} - \left(\frac{V_{di}^2}{X_{qi}} + \frac{V_{qi}^2}{X_{di}} \right) \end{cases}$$

In particular, it is non-polar, that is, X_{di} and X_{qi} are equal X_i , and the field input. Assuming that $V_{\text{field}i}$ is constant with the constant V_i^* :




Fig. 14 Load connected to bus bar

$$P_i = \frac{V_i^* |V_i|}{X_i} \sin(\delta_i - \angle V_i), \quad Q_i = \frac{V_i^* |V_i|}{X_i} \cos(\delta_i - \angle V_i) - \frac{|V_i|^2}{X_i}$$

This matches the classic model. For the detailed derivation process, refer to [?, Section 5].

4 Mathematical model of load

4.1 Relational expression of current and voltage based on load characteristics

As a static load model, three types of models — **constant impedance model**, **constant power model**, and **constant current model**— or their combinations are often used. These are all static models described by algebraic equations related to the current phasor and voltage phasor. Let us assume that voltage phasor of a bus bar i connected with a load is V_i and the current phasor flowing from the load to the bus bar is I_i (14). At this time, the constant impedance model gives the following relationship:

$$I_i = -\frac{V_i}{z_{loadi}^*} \quad (41a)$$

where, $z_{loadi}^* \in \mathbb{C}$ is a constant that expresses the impedance of the load. Here, the reason that there is a negative sign on the right side of Equation 41a is that the equipment that is equivalent to the load is grounded, and the direction of the flow from the load to the bus bar i is defined as positive sign of the current phasor I_i . Specifically:

$$I_i = \frac{1}{z_{loadi}^*} (0 - V_i)$$

Incandescent lamps and electric heaters are expressed as the constant impedance model.

The constant current model gives the following relationship with the constant that represents the fixed current phasor as $I_{loadi}^* \in \mathbb{C}$:

$$\mathbf{I}_i = \mathbf{I}_{\text{load}i}^* e^{j\angle V_i} \quad (41b)$$

In other words, the following is true for the absolute value $|\mathbf{I}_{\text{load}i}^*|$ and phase $\angle \mathbf{I}_{\text{load}i}^*$:

$$|\mathbf{I}_i| = |\mathbf{I}_{\text{load}i}^*|, \quad \angle \mathbf{I}_i = \angle \mathbf{I}_{\text{load}i}^* + \angle V_i$$

The constant power model gives the following relationship:

$$\mathbf{I}_i = \frac{P_{\text{load}i}^* - jQ_{\text{load}i}^*}{\bar{V}_i} \quad (41c)$$

where $P_{\text{load}i}^* \in \mathbb{R}$ and $Q_{\text{load}i}^* \in \mathbb{R}$ are constants that express the active and reactive power supplied to the bus bar i . This is derived by considering the complex conjugate of:

$$P_{\text{load}i}^* + jQ_{\text{load}i}^* = V_i \bar{\mathbf{I}}_i$$

The electric power converter is expressed as the constant current model and the constant power model based on its properties.

Depending on the purpose of the analysis, a dynamic load model might be employed. Please see [?, Section 7.1.2] for further details.

4.2 Kron reduction of the load bus bar

When there are generators and multiple types of loads, the relationship between the current phasor and voltage phasor of each device is stipulated by Equations (21) and (41), and by combining these with Equation 11, the mathematical model of the entire electrical power system can be obtained. At this time, the constant impedance model of Equation 41a provides a linear relationship for the current phasor and voltage phasor. On the other hand, since the constant current model of Equation 41b and the constant power model of Equation 41c give a nonlinear relationship for the current phasor and voltage phasor, mathematical analysis of the obtained electrical power system model would generally be difficult. Let us confirm with the following example.

Example 1.4 Kron reduction of load bus bar Let us assume that in the electrical power system of the Example 1.1, the generators are connected as equipment 1 and equipment 2, and load is connected as equipment 3. The relationship of the current phasor vector and voltage phasor vector of the admittance matrix of a power grid is given by Equation 10. First, let us consider a case where the load is given as the constant impedance model. If $z_{\text{load}3}^*$ is the impedance of the load, the following Equation is obtained:

$$\mathbf{I}_3 = -\frac{\mathbf{V}_3}{z_{\text{load}3}^*}$$

If this is substituted into Equation 10 to cancel \mathbf{I}_3 , the following is obtained:

$$\begin{bmatrix} \mathbf{I}_1 \\ \mathbf{I}_2 \\ 0 \end{bmatrix} = \begin{bmatrix} \mathbf{y}_{12} & -\mathbf{y}_{12} & 0 \\ -\mathbf{y}_{12} & \mathbf{y}_{12} + \mathbf{y}_{32} & -\mathbf{y}_{32} \\ 0 & -\mathbf{y}_{32} & \mathbf{y}_{32} + \frac{1}{\mathbf{z}_{\text{load}3}^*} \end{bmatrix} \begin{bmatrix} \mathbf{V}_1 \\ \mathbf{V}_2 \\ \mathbf{V}_3 \end{bmatrix} \quad (42)$$

Please note that, with the Equation on the third row, voltage phasor \mathbf{V}_3 of the load bus bar is replaced by voltage phasor \mathbf{V}_2 of the generator bus. Specifically, it can be expressed as:

$$\mathbf{V}_3 = \left(\mathbf{y}_{32} + \frac{1}{\mathbf{z}_{\text{load}3}^*} \right)^{-1} \mathbf{y}_{32} \mathbf{V}_2$$

If we also eliminate \mathbf{V}_3 using this, the relationship between the current and voltage phasors of the generator bus bar group is

$$\begin{bmatrix} \mathbf{I}_1 \\ \mathbf{I}_2 \end{bmatrix} = \mathbf{Y}_{\text{Kron}} \begin{bmatrix} \mathbf{V}_1 \\ \mathbf{V}_2 \end{bmatrix}$$

Here, the reduced admittance matrix of the load bus bar is obtained as:

$$\mathbf{Y}_{\text{Kron}} := \begin{bmatrix} \mathbf{y}_{12} & -\mathbf{y}_{12} \\ -\mathbf{y}_{12} & \mathbf{y}_{12} + \mathbf{y}_{32} \end{bmatrix} - \begin{bmatrix} 0 \\ \mathbf{y}_{32} \end{bmatrix} \left(\mathbf{y}_{32} + \frac{1}{\mathbf{z}_{\text{load}3}^*} \right)^{-1} \begin{bmatrix} 0 & \mathbf{y}_{32} \end{bmatrix}$$

Therefore, if the load is given as the constant impedance model, $\mathbf{Y}_{\text{Kron}} \in \mathbb{C}^{2 \times 2}$ obtained in this way is considered as the admittance matrix of a new power grid to cancel the load bus bar and its variable, allowing for equivalent transformation to a differential-algebraic equation system where only generators are connected to bus bars.

Next, let us consider a situation where the load is given as the constant current model. Let us assume that current phasor flows from the load to bus bar 3:

$$\mathbf{I}_3 = \mathbf{I}_{\text{load}3}^* e^{j\angle \mathbf{V}_3}$$

At this time, in the same procedure as the constant impedance model, if \mathbf{I}_3 and \mathbf{V}_3 are cancelled from Equation 10, the following is obtained:

$$\begin{bmatrix} \mathbf{I}_1 \\ \mathbf{I}_2 \end{bmatrix} = \mathbf{Y}'_{\text{Kron}} \begin{bmatrix} \mathbf{V}_1 \\ \mathbf{V}_2 \end{bmatrix} + \begin{bmatrix} 0 \\ -\mathbf{y}_{32} \end{bmatrix} \mathbf{y}_{32}^{-1} \mathbf{I}_{\text{load}3}^* e^{j\angle \mathbf{V}_3}$$

where:

$$\mathbf{Y}'_{\text{Kron}} := \begin{bmatrix} \mathbf{y}_{12} & -\mathbf{y}_{12} \\ -\mathbf{y}_{12} & \mathbf{y}_{12} + \mathbf{y}_{32} \end{bmatrix} - \begin{bmatrix} 0 \\ \mathbf{y}_{32} \end{bmatrix} \mathbf{y}_{32}^{-1} \begin{bmatrix} 0 & \mathbf{y}_{32} \end{bmatrix}$$

This means that, if the load is given as the constant current model, an affine relationship is given to the current phasor and voltage phasor of the generators. However, phase $\angle \mathbf{V}_3$ of the voltage phasor of the load bus bar also has an impact on the current phasor of the generators. Generally, phase $\angle \mathbf{V}_3$ of the voltage phasor is a nonlinear function of the voltage phasor \mathbf{V}_3 .

Finally, let us consider a case wherein the load is given as the constant power model. When a constant active power $P_{\text{load}3}^*$ and reactive power $Q_{\text{load}3}^*$ are supplied from the load to bus bar 3, the following relationship is given:

$$I_3 = \frac{P_{\text{load}3}^* - jQ_{\text{load}3}^*}{\bar{V}_3}$$

Since this is a nonlinear relationship of I_3 and V_3 , to cancel V_3 from Equation 10, nonlinear calculation is necessary. Specifically, V_3 is given as a solution for the quadratic equation related to complex variables:

$$y_{32}V_3\bar{V}_3 - y_{32}V_2\bar{V}_3 - P_{\text{load}3}^* + jQ_{\text{load}3}^* = 0$$

Therefore, if the load of the constant power model is included in an electrical power system model, it is usually difficult to cancel the load bus bar through equivalent transformation.

As shown in Example 1.4, if the load is given as a static model expressed by Equation (41), the current phasor and voltage phasor of some or all load bus bars can be equivalently cancelled through algebraic calculation. This operation is called **Kron reduction of the load bus bar**. Specifically, when the load is given as the constant impedance model, Kron reduction of the load bus bar corresponds to reducing the dimension of the admittance matrix of the power grid by mathematically equivalent calculation.

If there is no equipment, such as a generator or load, connected to the bus bar, we can assume that the absolute value of $z_{\text{load}i}^*$ in Equation 41a is where the load of an infinite constant impedance model is connected to the bus bar i . This is equal to virtually connecting the load of the constant current model, where the current phasor between the load and the bus bar is always 0. Therefore, the above-described Kron reduction of the load bus bar allows for equivalent cancellation of the bus bar without equipment.

4.3 Mathematical properties of the admittance matrix with reduced load bus bar

Let us analyze properties that hold for Kron reduction of the load bus bar when all loads are given by the constant impedance model. First, we will show Kron reduction steps for the Example 1.4 as a general form when generator buses and load bus bars are arbitrary. The subscripts set of generator buses is \mathcal{I}_G and the subscripts set of load bus bars is \mathcal{I}_L . We assume that a smaller number is assigned to general buses than load bus bars without losing generality. In other words:

$$\mathcal{I}_G = \{1, \dots, n\}, \quad \mathcal{I}_L = \{n+1, \dots, n+m\}$$

where n and m are numbers of generator buses and load bus bars, respectively. The definition stipulates that $n + m$ is equal to the total number of bus bars N .

A vector with current phasors of all generator buses is $\mathbf{I}_G \in \mathbb{C}^n$ and a vector with voltage phasors of all generator buses is $\mathbf{V}_G \in \mathbb{C}^n$. Similarly, a vector with current phasors of all load bus bars is $\mathbf{I}_L \in \mathbb{C}^m$ and a vector of voltage phasors of all load bus bars is $\mathbf{V}_L \in \mathbb{C}^m$. At this time, the relationship between all current phasors and voltage phasors related to the admittance matrix of power grids $\mathbf{Y} \in \mathbb{C}^{N \times N}$ can be expressed as:

$$\begin{bmatrix} \mathbf{I}_G \\ \mathbf{I}_L \end{bmatrix} = \underbrace{\begin{bmatrix} \mathbf{Y}_{GG} & \mathbf{Y}_{GL} \\ \mathbf{Y}_{LG} & \mathbf{Y}_{LL} \end{bmatrix}}_{\mathbf{Y}} \begin{bmatrix} \mathbf{V}_G \\ \mathbf{V}_L \end{bmatrix} \quad (43)$$

The relationship between the current phasor and voltage phasor determined by the load of the constant impedance model can be expressed as follows by using the admittance, which is a reciprocal of the impedance:

$$\mathbf{I}_L = -\text{diag}(\mathbf{y}_{\text{load}i}^*)_{i \in \mathcal{I}_L} \mathbf{V}_L$$

Though $\mathbf{y}_{\text{load}i}^*$ defined as a reciprocal of $\mathbf{z}_{\text{load}i}^*$ of Equation 41a must have a non-zero value, since this is an expression of bus bars with no equipment connected, formally, $\mathbf{y}_{\text{load}i}^*$ is allowed to be 0. If this is substituted into Equation 43 to cancel \mathbf{V}_L :

$$\mathbf{I}_G = \underbrace{\left\{ \mathbf{Y}_{GG} - \mathbf{Y}_{GL} (\mathbf{Y}_{LL} + \text{diag}(\mathbf{y}_{\text{load}i}^*)_{i \in \mathcal{I}_L})^{-1} \mathbf{Y}_{LG} \right\}}_{\mathbf{Y}_{\text{Kron}}} \mathbf{V}_G \quad (44)$$

is obtained. Note that, generally, when a load consumes active power and reactive power in terms of the admittances of the load, similar to a transmission line, the following is established:

$$\text{Re}[\mathbf{y}_{\text{load}i}^*] \geq 0, \quad \text{Im}[\mathbf{y}_{\text{load}i}^*] \leq 0, \quad \forall i \in \mathcal{I}_L \quad (45)$$

The conductance and susceptance matrices, where the load bus bar, which is the real and imaginary part of \mathbf{Y}_{Kron} , is reduced, are expressed as:

$$\mathbf{G}_{\text{Kron}} := \text{Re}[\mathbf{Y}_{\text{Kron}}], \quad \mathbf{B}_{\text{Kron}} := \text{Im}[\mathbf{Y}_{\text{Kron}}]$$

This presents the following fact:

Theorem 1.2 (Properties of the Kron-reduced admittance matrix) *For the admittance matrix $\mathbf{Y} \in \mathbb{C}^{N \times N}$ of Equation 16, the partitioned matrix of Equation 43 defines the admittance matrix where the load bus bars have been Kron reduced as $\mathbf{Y}_{\text{Kron}} \in \mathbb{C}^{n \times n}$ of Equation 44. The admittance $\mathbf{y}_{\text{load}i}^*$ of each load satisfies Equation 45. At this point, the reduced conductance matrix \mathbf{G}_{Kron} is positive semi-definite, while the reduced susceptance matrix \mathbf{B}_{Kron} is symmetric. If the following is true for generator buses:*

$$b_i = 0, \quad \forall i \in \mathcal{I}_G \quad (46a)$$

And the following is true for load bus bars:

$$\text{Im}[y_{\text{load}i}^*] + b_i \leq 0, \quad \forall i \in \mathcal{I}_L \quad (46b)$$

B_{Kron} is negative semi-definite, where b_i is a non-negative constant equivalent to the capacitance to ground of Equation 16. Specifically, if the inequality of Equation 46b strictly holds for at least one load bus bar, B_{Kron} is negative definite.

Proof Translated with DeepL To show the subject using the Lemma ?? at the end of the chapter

$$\mathbf{Y}' := \begin{bmatrix} \mathbf{Y}_{\text{GG}} & \mathbf{Y}_{\text{GL}} \\ \mathbf{Y}_{\text{LG}} & \mathbf{Y}_{\text{LL}} + \text{diag}(y_{\text{load}i}^*)_{i \in \mathcal{I}_L} \end{bmatrix}$$

At this time, since the expression ?? and the expression ?? hold, the real part of $j\mathbf{Y}'$ is symmetric, and the imaginary part is half. It is symmetry. Therefore, the lemma ?? shows that the real part of $j\mathbf{Y}_{\text{Kron}}$ is symmetric and the imaginary part is semi-positive. This implies that the real part of \mathbf{Y}_{Kron} , G_{Kron} , is semi-positive definite and the imaginary part, B_{Kron} , is symmetric.

Moreover, when the equation (46) holds, the imaginary part of \mathbf{Y}' is semi-negative definite, which shows the semi-negativity of B_{Kron} by the complement 1.3. Similarly, the imaginary part of \mathbf{Y}' is negative definite if the inequality in equation 46b holds strictly for at least one load matrix. Therefore, B_{Kron} is also negative definite. \square

Theorem 1.2 shows that, if all loads are given by the constant impedance model, even if the load bus bars were Kron reduced, the positive semi-definite nature of the conductance matrix and symmetry of the susceptance matrix in the admittance matrix of Equation 16 is preserved. Therefore, it can be similarly applied to the electrical power system model, in which the generator buses and load bus bars in Section 3.3 are Kron reduced. Theorem 1.2 shows a case where all load bus bars are Kron reduced simultaneously. However, the same fact is shown when only some of load bus bars are Kron reduced.

As discussed above, while the definiteness of the admittance matrix is invariable to Kron reduction, the “element signs” of the real part and imaginary part are not necessarily invariable. Let us confirm this with the next Example.

Example 1.5 Sign change of the admittance matrix by Kron reduction of bus bars In the admittance matrix \mathbf{Y}_0 where the capacitance to ground of Equation (15) can be ignored, the conductance matrix G_0 is positive semi-definite, and the susceptance matrix B_0 is negative semi-definite. At this time, the diagonal and non-diagonal elements of G_0 are non-negative and non-positive, respectively, and the diagonal and non-diagonal elements of B_0 are non-positive and non-negative, respectively. For example, let us consider a case where bus bar 1 and bus bar 2 are generator buses, bus bar 3 is the load bus bar, and the admittance of the load and the admittance matrix of the power grids are:

$$\mathbf{y}_{\text{load}3}^* = \alpha - j\beta, \quad \mathbf{Y} = \underbrace{\gamma \begin{bmatrix} 1 & -1 & 0 \\ -1 & 1 & 0 \\ 0 & 0 & 0 \end{bmatrix}}_{G_0} + j \underbrace{\begin{bmatrix} -2 & 1 & 1 \\ 1 & -2 & 1 \\ 1 & 1 & -2 \end{bmatrix}}_{B_0}$$

where α , β , and γ are non-negative constants. Please note that the signs of the real and imaginary parts of the admittance of the load are the same as the signs of the diagonal element of the admittance matrix.

Kron reduction of the load bus bar causes the admittance matrix of Equation 44 that has been Kron reduced to become:

$$\mathbf{Y}_{\text{Kron}} = \underbrace{\gamma \begin{bmatrix} 1 & -1 \\ -1 & 1 \end{bmatrix} + \frac{\alpha}{\alpha^2 + (2 + \beta)^2} \begin{bmatrix} 1 & 1 \\ 1 & 1 \end{bmatrix}}_{G_{\text{Kron}}} + j \underbrace{\left(\begin{bmatrix} -2 & 1 \\ 1 & -2 \end{bmatrix} + \frac{2 + \beta}{\alpha^2 + (2 + \beta)^2} \begin{bmatrix} 1 & 1 \\ 1 & 1 \end{bmatrix} \right)}_{B_{\text{Kron}}}$$

Here, for arbitrary non-negative constants, α , β , and γ , the diagonal element of G_{Kron} is non-negative and the diagonal and non-diagonal elements of B_{Kron} are negative and positive, respectively. However, the non-diagonal element of G_{Kron} is positive when:

$$\gamma < \frac{\alpha}{\alpha^2 + (2 + \beta)^2}$$

As such, when the load bus bar is Kron reduced, the sign of the non-diagonal element of the admittance matrix is not always invariable. The sign of the diagonal element is invariable because of the positive semi-definite nature of G_0 and negative semi-definite nature of B_0 .

As for changes in the sign of the non-diagonal element, these can occur when the conductance and susceptance are not 0 for the load or transmission line connected to bus bars that have been Kron reduced. For example, in the above case, the admittance of the load is a pure imaginary number when $\alpha = 0$. The admittance of the transmission line connected to bus bar 3; in other words, the elements of the third column and row of \mathbf{Y} are all pure imaginary numbers. In such a case, the signs of elements in the conductance and susceptance matrices do not change.

The above-described Kron reduction has been known as a mathematical operation related to the derivation of an equivalent circuit [?]. Specifically, in an analysis of an electrical power system, it is applied to the power flow calculations explained in Section ???. Kron reduction has also been analyzed from the perspective of graph theory, and has mathematically interesting properties [?].

Mathematical Supplement

Entire section translated with DeepL

Lemma 1.1 Assume that the running matrix M is regular. The necessary and sufficient condition for $M + jN$ to be regular for a running matrix N is that $M + NM^{-1}N$ is regular.

Proof First, the fact that $M + jN$ is regular is equivalent to the fact that there exist certain real square matrices P and Q such that $(M + jN)(P + jQ) = I$. If we rearrange these two equations for the real and imaginary parts, we get

$$\underbrace{\begin{bmatrix} M & -N \\ N & M \end{bmatrix}}_L \begin{bmatrix} P & -Q \\ Q & P \end{bmatrix} = I \quad (47)$$

This means that the regularity of $M + jN$ is equivalent to the regularity of L . Furthermore, from the properties of the determinant of the block matrix:

$$\det L = \det M \det (M + NM^{-1}N)$$

From the assumption that $\det M \neq 0$, the regularity of L is equivalent to the regularity of $M + NM^{-1}N$. From the above, the subject follows the intent of the title. \square

Lemma 1.2 The real part of the complex matrix Z is assumed to be positive definite. If the imaginary part of Z is symmetric, then the real part of Z^{-1} is positive definite and the imaginary part is symmetric. In particular, if the imaginary part of Z is semipositive definite, then the imaginary part of Z^{-1} is seminegative definite. Also, if the imaginary part of Z is positive definite, then the imaginary part of Z^{-1} is negative definite.

Proof Using a real positive definite matrix M and a symmetric matrix N , denote Z by $M + jN$. Also, denote the real part of Z^{-1} by P and the imaginary part by Q . From the complement 1.1, $M + NM^{-1}N$ is positive definite and therefore Z is regular. Therefore

$$(M + jN)(P + jQ) = I$$

The equations for the real and imaginary parts of L are equivalent to the equations in equation 47. This means that the diagonal and off-diagonal blocks of the inverse of L are P and Q . From the properties of the inverse of the block matrix

$$L^{-1} = \begin{bmatrix} (M + NM^{-1}N)^{-1} & M^{-1}N(M + NM^{-1}N)^{-1} \\ -(M + NM^{-1}N)^{-1}NM^{-1} & (M + NM^{-1}N)^{-1} \end{bmatrix}$$

Therefore,

$$P = (M + NM^{-1}N)^{-1}, \quad Q = -M^{-1}N(M + NM^{-1}N)^{-1}$$

From the assumption that N is symmetric and M is positive definite, P is positive definite. Also, using the positive definite matrix $\sqrt{M^{-1}}$ such that $M^{-1} = \sqrt{M^{-1}}\sqrt{M^{-1}}$, Q is

$$Q = -\underbrace{\sqrt{M^{-1}}\sqrt{M^{-1}}N\sqrt{M^{-1}}\left(I + (\sqrt{M^{-1}}N\sqrt{M^{-1}})^2\right)^{-1}}_X \sqrt{M^{-1}}$$

where $\sqrt{M^{-1}}N\sqrt{M^{-1}}$ is symmetric, so it can be diagonalized by the orthogonal matrix V and

$$X = V\Lambda\left(I + \Lambda^2\right)^{-1}V^T$$

However, Λ is a real diagonal matrix of eigenvalues of $\sqrt{M^{-1}}N\sqrt{M^{-1}}$. From this, since X is symmetric, Q is also symmetric. Furthermore, if N is semi-definite, then Λ is also semi-definite, and if N is positive, then Λ is also positive. Therefore, if N is semi-positive definite, then Q is semi-negative definite, and if N is positive definite, then Q is negative definite. From the above, the subject follows. \square

Lemma 1.3 *Translated with DeepL* Consider symmetric running matrices M and N . They are partitioned into block matrices

$$\begin{bmatrix} \mathbf{Z}_{11} & \mathbf{Z}_{12} \\ \mathbf{Z}_{21} & \mathbf{Z}_{22} \end{bmatrix} := \underbrace{\begin{bmatrix} M_{11} & M_{12} \\ M_{12}^T & M_{22} \end{bmatrix}}_M + j \underbrace{\begin{bmatrix} N_{11} & N_{12} \\ N_{12}^T & N_{22} \end{bmatrix}}_N \quad (48)$$

For $\mathbf{Z}_{11} - \mathbf{Z}_{12}\mathbf{Z}_{22}^{-1}\mathbf{Z}_{21}$ denote \mathbf{Z}_S . Also assume that M is semi-definite and that M_{22} is positive definite. In this case, the real part of \mathbf{Z}_S is semipositive definite and the imaginary part is symmetric. In particular, if N is semipositive definite, then the imaginary part of \mathbf{Z}_S is semipositive definite. Also, if N is positive definite, then the imaginary part of \mathbf{Z}_S is positive definite. Furthermore, if M is positive definite, then the real part of \mathbf{Z}_S is positive definite.

Proof *Translated with DeepL* Denote by \mathbf{Z} the matrix on the left-hand side of the Equation 48. First, if M is positive definite, then the real part of \mathbf{Z}_S is positive definite and the imaginary part is symmetric. Now, from the positive definiteness of M_{22} , \mathbf{Z}_{22} is regular from the complement 1.1. Therefore, by the inverse property of the block matrix, \mathbf{Z}_S^{-1} coincides with the upper left block of \mathbf{Z}^{-1} . Here, from the complementation 1.2, the real part of \mathbf{Z}^{-1} is positive definite and the imaginary part is symmetric. This means that the real part of \mathbf{Z}_S^{-1} is positive definite and the imaginary part is symmetric. Therefore, applying the complementation 1.2 to \mathbf{Z}_S^{-1} shows that the real part of \mathbf{Z}_S is positive definite and the imaginary part is symmetric. Similarly, if N is semipositive definite, then from the complementation 1.2, the imaginary part of \mathbf{Z}^{-1} is semidefinite, which means that the imaginary part of \mathbf{Z}_S^{-1} is semidefinite.

Therefore, by applying the complementation 1.2 again to \mathbf{Z}_S^{-1} , it can be shown that the imaginary part of \mathbf{Z}_S is semipositive definite.

Next, consider the case where M is semidefinite and N is symmetric. First, show that both the real and imaginary parts of \mathbf{Z}_S are symmetric. Now, since the real part M_{22} of \mathbf{Z}_{22} is positive definite and the imaginary part N_{22} is symmetric, both real and imaginary parts of \mathbf{Z}_{22}^{-1} are symmetric. Therefore,

$$\begin{aligned} \operatorname{Re}[\mathbf{Z}_S] &= \operatorname{Re}[\mathbf{Z}_{11}] - \operatorname{Re}[\mathbf{Z}_{12}] \operatorname{Re}[\mathbf{Z}_{22}^{-1}] \operatorname{Re}[\mathbf{Z}_{21}] \\ &\quad + i[\mathbf{Z}_{12}]i[\mathbf{Z}_{22}^{-1}] \operatorname{Re}[\mathbf{Z}_{21}] + i[\mathbf{Z}_{12}] \operatorname{Re}[\mathbf{Z}_{22}^{-1}]i[\mathbf{Z}_{21}] \\ &\quad + \operatorname{Re}[\mathbf{Z}_{12}]i[\mathbf{Z}_{22}^{-1}]i[\mathbf{Z}_{21}] \\ &= M_{11} - M_{12} \operatorname{Re}[\mathbf{Z}_{22}^{-1}]M_{12}^T + N_{12}i[\mathbf{Z}_{22}^{-1}]M_{12}^T + N_{12} \operatorname{Re}[\mathbf{Z}_{22}^{-1}]N_{12}^T \\ &\quad + M_{12}i[\mathbf{Z}_{22}^{-1}]N_{12}^T \end{aligned}$$

From this we see that the real part of \mathbf{Z}_S is symmetric. Similarly,

$$\begin{aligned} i[\mathbf{Z}_S] &= N_{11} + N_{12}i[\mathbf{Z}_{22}^{-1}]N_{12}^T - N_{12} \operatorname{Re}[\mathbf{Z}_{22}^{-1}]M_{12}^T \\ &\quad - M_{12}i[\mathbf{Z}_{22}^{-1}]M_{12}^T - M_{12} \operatorname{Re}[\mathbf{Z}_{22}^{-1}]N_{12}^T \end{aligned}$$

From this we see that the imaginary part of \mathbf{Z}_S is also symmetric.

When M in the expression 48 is semi-definite, \mathbf{Z} is not necessarily regular, since \mathbf{Z}^{-1} is not necessarily regular. In contrast, in what follows, for any $\epsilon > 0$:

$$\mathbf{Z}^+ := \begin{bmatrix} \mathbf{Z}_{11} + \epsilon I & \mathbf{Z}_{12} \\ \mathbf{Z}_{21} & \mathbf{Z}_{22} + \epsilon I \end{bmatrix}$$

The real part of N , $M + \epsilon I$, is positive definite. Now, when N is semi-definite, for any $\epsilon > 0$ we have

$$\mathbf{Z}_S^+ := \mathbf{Z}_{11} + \epsilon I - \mathbf{Z}_{12}(\mathbf{Z}_{22} + \epsilon I)^{-1}\mathbf{Z}_{21}$$

The real part of $(\mathbf{Z}_{22} + \epsilon I)^{-1}$ is positive definite, and the imaginary part is semi-positive definite. Also, by expanding $(\mathbf{Z}_{22} + \epsilon I)^{-1}$ using the auxiliary theorem of the inverse matrix the following is obtained.

$$\mathbf{Z}_S^+ = \mathbf{Z}_S + \epsilon \underbrace{\{I + \mathbf{Z}_{12}\mathbf{Z}_{22}^{-1}(I + \epsilon\mathbf{Z}_{22}^{-1})^{-1}\mathbf{Z}_{22}^{-1}\mathbf{Z}_{21}\}}_{\Delta(\epsilon)}$$

As mentioned above, since the real and imaginary parts of \mathbf{Z}_S^+ and \mathbf{Z}_S are symmetric, the real and imaginary parts of $\Delta(\epsilon)$ are also symmetric.

Next, we show that the imaginary part of \mathbf{Z}_S^+ is semipositive definite if and only if \mathbf{Z}_S is semipositive definite. Note that the same argument can be used to show the semi-positive definiteness of the real part. For the following discussion

$$\mathcal{X} := \{x : x^T i[\Delta(\epsilon)]x > 0, \quad \forall \epsilon > 0\}$$

is defined as follows. From this definition of \mathcal{X} , for arbitrarily chosen $x \notin \mathcal{X}$, there exists some $\epsilon_0 > 0$ such that

$$x^T \mathbf{i}[\Delta(\epsilon_0)]x \leq 0$$

Therefore, the imaginary part of \mathbf{Z}_S^+ is semi-positive definite,

$$x^T \mathbf{i}[\mathbf{Z}_S]x + x^T \mathbf{i}[\Delta(\epsilon_0)]x \geq 0$$

is derived. This leads to the following for all $x \notin \mathcal{X}$,

$$x^T \mathbf{i}[\mathbf{Z}_S]x \geq 0 \quad (49)$$

Furthermore, if the imaginary part of \mathbf{Z}_S^+ is semi-positive definite, we show by contraposition that the expression 49 holds for all $x \in \mathcal{X}$. That is, for some $x \in \mathcal{X}$, we have

$$x^T \mathbf{i}[\mathbf{Z}_S]x < 0 \quad (50)$$

then the imaginary part of \mathbf{Z}_S^+ is not semidefinite. Now, noting that the imaginary part of $\Delta(\epsilon)$ asymptotes to 0 in the limit of $\epsilon \rightarrow 0$, if for some $x \in \mathcal{X}$ the expression 50

$$x^T \mathbf{i}[\mathbf{Z}_S]x + x^T \mathbf{i}[\Delta(\epsilon_0)]x < 0$$

This means that the imaginary part of \mathbf{Z}_S^+ is not semi-positive definite. The above facts show that the imaginary part of \mathbf{Z}_S is semi-positive definite.

Finally, we show that if N is positive definite, then the imaginary part of \mathbf{Z}_S is positive definite. For this purpose,

$$-j\mathbf{Z} = N - jM$$

is positive definite and the imaginary part is symmetric. Applying the results for the case where the real part is positive definite to this $-j\mathbf{Z}_S$, it can be shown that the real part of $-j\mathbf{Z}_S$ is positive definite. This implies that the imaginary part of \mathbf{Z}_S is positive definite. \square