

Central Ground Water Authority, Government of India

**CENTRAL GROUND WATER AUTHORITY**

(Constituted under sub-section (3) of section 3 of the Environment (Protection) Act, 1986)



# **Estimation of water requirement for drinking and domestic use**

**(Source: NBC 2016, BIS)**

**Central Ground Water Authority  
Jam Nagar House, New Delhi**

**Estimation of Water Requirements for drinking and domestic use**  
**(Source: National Building Code 2016, BIS)**

a) Residential Buildings:

Accommodations	Population
1 Bedroom dwelling unit	4
2 Bedroom dwelling unit	5
3 Bedroom dwelling unit	6
4 Bedroom dwelling unit and above	7

Notes:

- 1) The above figures consider a domestic household including support personnel, wherever applicable.
- 2) For plotted development, the population may be arrived at after due consideration of the expected number and type of domestic household units.
- 3) Dwelling unit under EWS category shall have population requirement of 4 and studio apartment shall have population requirement of 2.

As a general rule the following rates per capita per day may be considered for domestic and non-domestic needs:

a) For communities with populations up to 20,000:

1)	Water supply through stand post :	40 lphd (Min)
2)	Water supply through house service: connection	70 to 100 lphd

b) For communities with : 100 to 135 lphd  
population 20,000 to 100,00 together with  
full flushing system

c) For communities with population: 150 to 200 lphd  
above 100,000 together with  
full flushing system

Note—The value of water supply given as 150 to 200 litre per head per day may be reduced to 135 litre per head per day for houses for Medium Income Group (MIG) and Low Income Groups (LIG) and Economically Weaker Section of Society (EWS), depending upon prevailing conditions and availability of water.

Out of the 150 to 200 litre per head per day, 45 litre per head per day may be taken for flushing requirements and the remaining quantity for other domestic purposes.

**Water Requirements for Buildings Other than Residences**

Sl No.	Type of Building	Domestic litres per head/ day	Flushing Litres per head/ day	Total Consumption Litres per head/ day
1.	Factories including canteen where bath rooms are required to be provided	30	15	45
2.	Factories including canteen where no bath rooms are required to be provided	20	10	30
3.	Hospital (excluding laundry and kitchen):			
	a) Number of beds not exceeding 100	230	110	340
	b) Number of beds exceeding 100	300	150	450
	c) Out Patient Department (OPD)	10	5	15
4.	Nurses' homes and medical quarters	90	45	135
5.	Hostels	90	45	135
6.	Hotels (up to 3 star) excluding laundry, kitchen, staff and water bodies	120	60	180
7.	Hotels (4 star and above) excluding laundry, kitchen, staff and water bodies	260	60	320
8.	Offices (including canteen)	25	20	45
9.	Restaurants and food court including water requirement for kitchen:			
	a) Restaurants	55 per seat	15 per seat	70 per seat
	b) Food Court	25 per seat	10 per seat	35 per seat
10.	Clubhouse	25	20	45
11.	Stadiums	4	6	10
12.	Cinemas, concert halls and theatres and multiplex	5 per seat	10 per seat	15 per seat
13.	Schools/Educational institutions:			
	a) Without boarding facilities	25	20	45
	b) With boarding facilities	90	45	135

Sl No.	Type of Building	Domestic Per Day	Flushing Per Day	Total Consumption Per Day
14.	Shopping and retail (mall)			
	a) Staff	25	20	45
	b) Visitors	5	10	15
15.	Traffic Terminal stations			
	a) Airports	40	30	70
	b) Railway stations (Junction) with bathing facility	40	30	70
	c) Railway stations (Junction) without bathing facility	30	15	45
	d) Railway stations (Intermediate) with bathing facility	25	20	45
	e) Railway stations (Intermediate) without bathing facility	15	10	25
	f) Interstate bus terminals	25	20	45
	g) Intrastate Bus Terminals/Metro Stations	10	5	15

#### Notes

1. For calculating water demand for visitors, consumption of 15 litre per head per day may be taken.
2. The water demand includes requirement of patients, attendants, visitors and staff. Additional water demand for kitchen, laundry and clinical water shall be computed as per actual requirements.
3. The number of persons shall be determined by average number of passengers handled by stations, with due considerations given to the staff and vendors who are using these facilities.
4. Consideration should be given for seasonal average peak requirements.
5. The hospitals may be categorised as Category A (25 to 50 beds), Category B (51 to 100 beds), Category C (101 to 300 beds), Category D (301 to 500) and Category E (501 to 750 beds).