



PTT PHENOL COMPANY
LIMITED

PROCESS SPECIFICATION

DECANTER (D-2205)

Docu. No. : 14780-8120-PS-D2205
Project No. : 120117
Rev. No. : Z1
Date : MAY 10, 2016
Page : 1 / 4

TITLE :

DECANTER

(D-2205)

DISCIPLINE : **PROCESS**
DOCUMENT NO. : **14780-8120-PS-D2205**
PROJECT NAME : **PTT Phenol Train II Project**
PROJECT NO. : **120117**
OWNER : **PTT Phenol Company Limited (PPCL)**

Z1	MAY 10, 2016	AS BUILT	S.W.Park	J.S.Chung	-	S.W.Lee
F1	MAY 22, 2014	FINAL ISSUE	S.W.Park	J.S.Chung	-	S.W.Lee
A3	APR 18, 2014	APPROVED FOR DESIGN	S.W.Park	J.S.Chung	-	S.W.Lee
A2	DEC 11, 2013	APPROVED FOR DESIGN	S.W.Park	J.S.Chung	-	S.W.Lee
A1	OCT 2, 2013	APPROVED FOR DESIGN	S.W.Park	J.S.Chung	-	S.W.Lee
O1	JUN 27, 2013	COMMENT ISSUE	S.W.Park	J.S.Chung	-	S.W.Lee
REV. NO.	DATE	DESCRIPTION	PREP'N	REVIEW	QA REVIEW	APPROVAL
REV. NO.	PREPARATION DEPT.	PREPARATION	REVIEW	QA REVIEW	APPROVAL	
Z1	PROCESS	S.W.Park	J.S.Chung	-	S.W.Lee	
		MAY 10, 2016	MAY 10, 2016	-	MAY 10, 2016	

This Document is the property of POSCO Engineering Co., Ltd. Therefore, it shall not be released to Any third party without permission of an authorized personnel of the POSCO Engineering Co., Ltd.

[illegible]



Note: The information in this document is confidential and the property of UOP LLC and must not be disclosed to others or reproduced in any manner or used for any purpose whatsoever without its written permission.



VESSELS

PROJECT SPECIFICATION

963765 — 301

SHEET 3 / 4

REV	DATE	BY	APVD	REV	DATE	BY	APVD
0	27APR12	TS	HDT				

General Notes

- A. Vessels shall be constructed in accordance with the following unless otherwise specified on the individual vessel specification sheet.

Standards:

UOP Standard Specification 3-11

- B. Although the resulting inside diameter may be slightly different than specified, vessels without trays or packing, may be fabricated from pipe.
- C. The dimensioned location of some of the vessel level nozzles may be noted as min (minimum) or max (maximum). It is the responsibility of the contractor to adjust these dimensions to suit the specific level requirements specified on the UOP Piping and Instrument Diagram(s) and on UOP Standard Drawing 8-121. When additional nozzles are required for level instrumentation, the contractor shall specify them consistent with the size, class and facing requirements specified in the UOP Project Specification 301-Vessels and on the UOP Piping and Instrument Diagram(s).
- D. When system of measurement is metric, all dimensions are in millimeters unless noted otherwise.
- E. Contractor shall not locate TI thermowells in a downcomer. Contractor shall also ensure that TI thermowells are located to avoid interference with downcomers, weirs, distributors, collectors, baffles, chimneys, traps and all other vessel internals.
- F. Suppliers (or equal):

Spray Nozzle:

BETE Fog Nozzle Inc.
www.bete.com

Profile Wire Screens:

Johnson Screens
www.johnsonscreens.com

Nagaoka International Corporation
www.nagaokajapan.co.jp

Other specifications
referenced in this
specification:

UOP Standard Specification: 3-11, 3-15, 3-35, 9-11

UOP Standard Drawing: 3-115, 3-116, 3-122, 3-123, 3-144, 3-183, 3-190, 3-264, 3-266, 3-313, 3-322, 8-121

UOP Project Specification: 963765-106, 963765-307

REV	UOP			PTT PHENOL			BECHTEL			NOTES:			PROJECT SPECIFICATION		
	A Honeywell Company									1. VESSEL TO BE FABRICATED IN ACCORDANCE WITH UOP STANDARD SPECIFICATION 3-15.			963765 - 301		
										2. SPECIFIC GRAVITY = HCBN: 0.85 AND WATER: 0.99.			SHEET 4 / 4		
										3. PROVIDE 10 MM MIN THICK TYPE 304L BAFFLE WITH STIFFENERS AS REQUIRED. MANWAY IS NOT ALLOWED IN THE BAFFLE. BAFFLE TO BE SEAL WELDED AND LEAK TESTED WITH WATER.			REV DATE BY APP'D		
													0 27APR12 TS HDT		
													1 03JUL12 JG HDT		
													2 07SEP12 JG HDT		
													3 21JAN14 TS MEH		

VESSELS	
SERVICE	DECANTER
ITEM NO	D-2205

Design	INT 3.5 kg/cm2(g)	205° C	
Conditions	EXT FULL VACUUM	250° C	
at Top	Metal Temperature(Min)	15° C	
Operating	0.06 kg/cm2(g)	37° C	
Conditions		° C	
Radiograph	MR		
Postweld Heat Treat	MR		
Material	Corrosion Allowance mm (Min)		
SA240 TYPE 304L (NOTE 1)	1.5		
This Vessel is in the Following Service(s):			
Hydrogen	NO		
Hydrofluoric (HF) Acid	NO		
Hydrofluoric (HF) Acid (with Resid. Elem. Control)	NO		
Wet Hydrogen Sulfide (H2S)	NO		
Severe Cyclic	NO		
Caustic	NO		
Carbonate	NO		
Note:			
Vessel Heads			
Vessel	2:1 ELLIPTICAL		
Accessories Applied by Fabricator			
Ladder & Platform Clips	AS REQUIRED		
Insulation Clips & Rings	NO		
Vessel Support	YES		
Nozzles and Manways			
Mark	No	Size Inches	Service
AK	2	2	LT (2)
AL	2	2	LG (2)
AM	1	24 ID	MANWAY
AN	1	4	WATER TO DECANTER WATER PUMP
AR	1	4	AQUEOUS BALANCE
AS	1	2	STEAMOUT (2)
AX	1	2	WATER INLET (2)
BC	1	2	FLASH COL OVHD CHILLER
BI	1	6	AQUEOUS HEADER
BJ	2	2	FROM CDN VAC PROD EQUIP
BK	2	2	LG (2)
BM	1	24 ID	MANWAY
BO	1	6	VAPOR OUTLET
BR	1	4	AQUEOUS BALANCE
BX	1	2	PI (2)
BZ	1	3	VAPOR INLET
CB	1	6	VENTILATION
CD	1	2	DRAIN
CJ	1	6	HCBN INLET
CK	2	2	LG (2)
CL	2	2	LT (2)
CM	1	24 ID	MANWAY
CN	1	6	HCBN OUTLET
CR	2	2	LT (2)
CV	1	2	VENT
VT	1	2	FLARE

Class	- ASME CL150
(2)	- ASME CL300
Facing	- RAISED FACE
Normal Liquid Level	= VESSEL CENTERLINE
Specific Gravity	= NOTE 2

3-122	3-123	3-183	3-190	3-266
-------	-------	-------	-------	-------

Drawings Referred to in this Specification									
3-122	3-123	3-183	3-190	3-266					