ITEM No. : D-2303
SERVICE : DECOMPOSER FEED FLUSH DRUM
SIZE DIAMETER X LENGTH(T/T) : 24"OD PIPE mm x 1800 mm
DESIGN PRESS. AND TEMP. : 10 kg/cm2g / 120°C
OPERATING PRESS. AND TEMP. : 0.7 kg/cm2g / 38 °C
INSULATION : NI
MISC CONNS : PL-23-012007-B1A1-NI

(FL-1205)
23-0012

LOCATE ON PLATFORM AT DECOMPOSER

2" BLANKOFF

PIC 1202 — SPLIT RANGE

PI 1203

PT 1202 FF

LOW PRESSURE SIGNAL OPENS VALVE
1"-N-53-051248-B1A1-NI

HIGH PRESSURE SIGNAL OPENS VALVE

PY 1202A

PV 1202A FF — FREE DRAINING

PY 1202B

PV 1202B FF

N 53-0051

2"-F-92-056016-B1A1-NI

F 92-0056A

NORMALLY NO FLOW

D-2303 BI

AM 2" BP1 BP2 B0 BK1 BK3 BK4 VB BK2 CW

HLL 1480mm
NLL 850 mm
LLL 290 mm
LLLL 290 mm

LG-R 1202

LXT 1201 — 1400 — DP 850 — COR

NOTE 5

LSL — UC 2302 — LSLL — LI

LAH LAL LXI 1201 SE

LXL 1201A

LXL 1201B

LXALL 1201

FLUSH RESERVOIR FULL (START-UP ENABLE)

SEE STD DWGS 8-121 AND 8-141 (CONNECT TO ACID AROMATICS SUMP)

FREE DRAINING

4"-CUL-23-012004-B1A1-NI

18300

FROM FLASH COLUMN BOTTOMS PUMPS
23-0012

UC 2302

UXY 1206 S

UXV 1206 FO

INSTRUMENT AIR

VENT DE

MINIMUM DISTANCE TO SHUT-OFF VALVE UV-1205

NOTE 3

L1A1 B1A1 MIN

FREE DRAINING

6"-CHP-23-009002-L1A1-NI

1½"

1½" 1" FC HIC 1201 HV 1201 FF

SEE STD DWG 8-138 TYPE I (CONNECT TO ACID AROMATICS SUMP)

NORMALLY NO FLOW

DECOMPOSER WATER ADDITION/FEED RATIO

XI 1201

XAH

RATIO

XY 1201

FREE DRAINING

NORMALLY NO FLOW

HIGH POINT

FREE DRAINING

1"-PRW-23-012005-B1A1-NI

MAKE CONNECTION ON TOP OF PIPE

FREE DRAINING

FAL 1207 / FSL 1207

THERMAL MASS

5000 MIN

NOTE 4

L1A1 B1A1

¾"P

MIN

TO DECOMPOSER DRUM
23-0013

6"-CHP-23-009002-L1A1-NI

UC 2302

UXY 1207 S

UXV 1207 FC 1"

INSTRUMENT AIR

VENT DE

UC 2302

FV 1201 FC 1"

DE S VENT

FXY 1201

MIN

RO 1203 — 7 mm

FE 1201

FIC 1201 FAL — FT 1201 FF

CRIT PXALL 1201 — SEE DETAIL "XX" NOTE 2

PXI 1201 PAL — UC 2302 PXSLL — PXT 1201

PI 1204

1"-PRW-25-014007-B1A1-NI

24-0028B

PROCESS WATER FROM PROCESS WATER PUMPS AT PHENOL RECOVERY SECTION

FREE DRAINING

NORMALLY NO FLOW

1"-PRW-23-012005-B1A1-NI

FREE DRAINING

TO ACID AROMATICS KNOCKOUT DRUM
23-0020

FROM FRESH FEED PUMPS
23-0011

1½"-CUL-23-011001-B1A1-NI

GENERAL NOTES

1. FOR ABBREVIATIONS, SYMBOLS & GENERAL NOTES, REFER TO LEGEND SHEETS 14780-8120-25-00-0001A THRU 0004
2. ALL INSTRUMENTS AND PIPING SPECIALTY ITEMS ON THIS DRAWING WILL BE PREFIXED BY UNIT NO. 2300.
3. FOR UNIT SPECIFIC DETAILS AND NOTES, REFER TO DWG. 14780-8120-25-23-0001.
4. FOR DETAILS OF CONTROL VALVE VENT & DRAIN, REFER TO DWG. 14780-8120-25-23-0001A.
5. FOR DETAILS OF LEVEL INSTRUMENT VENT & DRAIN, REFER TO DWG. 14780-8120-25-23-0001B.
6. FOR DETAILS OF PUMP VENT & DRAIN, REFER TO DWG. 14780-8120-25-23-0001C.
7. FOR DETAILS OF SAMPLING SYSTEM, REFER TO DWG. 14780-8120-25-23-0001D THRU 0001E.
8. FOR DETAILS OF PUMP AUXILIARY LINE, MOTOR CONTROL AND SEAL PLAN, REFER TO DWG. 14780-8120-25-23-0001F THRU 0001K.

NOTES

1. INSULATION FOR PIPING CONTAINING MORE THAN 5 WT% CHP MUST MEET SPECIAL REQUIREMENTS. SEE PROJECT SPECIFICATION 907 FOR DETAILS.
2. FOR DETAIL "XX" SEE DWG NO. 14780-8120-25-23-0001.
3. FOR DETAIL OF VALVE SEE DWG NO. 14780-8120-25-23-0001. DETAIL "UP"
4. DISSIMILAR CHECK VALVE.
5. WHEN THE LEVEL IN THE DECOMPOSER FEED FLUSH DRUM IS HIGHER THEN LSL(85% OF SPAN), START-UP WILL BE ENABLE.

REV.	DESCRIPTION	BY	CHK.	APPR.	PROJ. APPR.	DATE
Z1	AS BUILT	HSO	SWP	JSC	SWL	4/25/16
FS4-2	ISSUED FOR CONSTRUCTION NO HOLDS	HSO	SWP	JSC	SWL	5/20/15
FS4-1	ISSUED FOR CONSTRUCTION NO HOLDS	HSO	SWP	JSC	SWL	5/2/15
S4	ISSUED FOR CONSTRUCTION NO HOLDS	HSO	SWP	JSC	SWL	10/15/14
S3	ISSUED FOR CONSTRUCTION NO HOLDS	HSO	SWP	JSC	SWL	10/8/14
S2	ISSUED FOR CONSTRUCTION NO HOLDS	HSO	SWP	JSC	SWL	9/16/14
S1	ISSUED FOR CONSTRUCTION NO HOLDS	HSO	SWP	JSC	SWL	8/20/14
R2	ISSUED FOR CONSTRUCTION WITH HOLDS	HSO	SWP	JSC	SWL	4/4/14

THESE P AND I DIAGRAM IS DIAGRAMATIC ONLY. DESIGN OF PIPE LINES MUST BE INVESTIGATED FOR VENTING OF GAS AND VAPOR POCKETS IN PIPING AND EQUIPMENT. LOW POINTS IN PIPING, PUMPS AND EQUIPMENT FOR FREEZING AND DRAINING, AND ACCESSIBILITY OF ALL VALVES, FLANGES, INSTRUMENTS INCLUDING THERMOCOUPLES, ETC.

NOTE: THE INFORMATION IN THIS DOCUMENT IS CONFIDENTIAL AND THE PROPERTY OF UOP LLC AND MUST NOT BE DISCLOSED TO OTHERS OR REPRODUCED IN ANY MANNER OR USED FOR ANY PURPOSE WHATSOEVER WITHOUT ITS WRITTEN PERMISSION.

PTT PHENOL — POSCO ENGINEERING

THIS DRAWING IS CONFIDENTIAL PROPERTY OF
PTT PHENOL COMPANY LIMITED

AND IS LENT WITHOUT CONSIDERATION OTHER THAN THE BORROWER'S AGREEMENT THAT IT SHALL NOT BE RE-PRODUCED, COPIED, LENT, OR DISPOSED OF DIRECTLY OR INDIRECTLY NOR USED FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY FURNISHED. THE APPARATUS SHOWN IN THE DRAWING MAY BE COVERED BY PATENTS AND/OR MAY BE PROPRIETARY

UOP — BASED ON 963766-120-12A-A1

PIPING AND INSTRUMENT DIAGRAM

DECOMPOSER FEED FLUSH DRUM CONCENTRATION, DECOMPOSITION, AND NEUTRALIZATION SECTION
UOP PHENOL PROCESS UNIT

CERTIFIED FOR CONSTRUCTION
BY _____
DATE _____

	DWG.	DSGN.	CHK.	APPR.
BY				
DATE				

PROJ. NO.	DWG. NO.	REV.
PEN 120117		Z1
PPCL	14780-8120-25-23-0012A	

SCALE