

Cymbal Copper Pty Ltd (fictional) Ridgeback Concentrator Project RB-4410	Analyser, Density & Level Instrument Data Sheet Equipment tag: Various	Doc No. RB-4410-PS-0033	Rev B
		Sheet 1 of 1	

Instrument schedule

Tag	Service	Range	Alarm / trip / set point	SIS function
DT-3201	Cyclone feed density (nuclear)	1.0-2.0 SG	-	-
AIC-4101	Rougher feed pH	0-14 pH	AL 10.0 / AH 11.2	-
LT-6101	Tailings thickener bed level	0-10 m	LAH 6.5 m	-

Set points on this data sheet are the design basis. The SIS cause & effect matrix (RB-4410-STD-CE-001) must match.