

Cymbal Copper Pty Ltd (fictional) Ridgeback Concentrator Project RB-4410	Temperature Instrument Process Data Sheet Equipment tag: Various	Doc No. RB-4410-PS-0034	Rev B
		Sheet 1 of 1	

Instrument schedule

Tag	Service	Range	Alarm / trip / set point	SIS function
TT-3101	SAG mill drive-end trunnion bearing temperature	0-150 degC	TAH 70 degC / TAHH 75 degC	SIF-3101 (SIL 1) stop SAG mill
TT-3102	SAG mill non-drive-end trunnion bearing temperature	0-150 degC	TAH 70 degC / TAHH 75 degC	SIF-3101 (SIL 1) stop SAG mill

Set points on this data sheet are the design basis. The SIS cause & effect matrix (RB-4410-STD-CE-001) must match.