Fire Extinguisher Inspection Log

Monthly visual inspection - initial each month

Building _____

Year _____

Unit No.	Location	Type / Size	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Service

Monthly check: in its place and visible · access clear · pressure gauge in the green · pin and seal intact · no damage, leaks or corrosion · label readable. Annual maintenance by a qualified technician.