

Section 10 14 00
SIGNAGE

PART 1 - GENERAL

1.1 SUMMARY

- A. Furnish and install the following informational and directional signage:
1. Types 1A and 1B Interior Room Signage:
 - a. Primary signage: Photopolymer AAB-compliant room signage adhered with double sided acrylic foam tape, typical at all permanent spaces (including but not limited to reading rooms, meeting rooms, staff offices, mechanical/electrical rooms and toilet rooms); 0.16 inch thick, with backed acrylic polyurethane enamel paint, and raised Braille cells.
 - b. Mounting: Sixty (60) above finished floor to centerline of sign on latch side of door; no closer the nine (9) inches to centerline of sign from adjacent door swing or obstruction.
 - c. Sizes: Refer to Drawings and Signage Schedule
 2. Types 2A, 2B, 2C and 2D Interior Exit Discharge Signage
 - a. Raised character and braille exit signage: Photopolymer AAB-compliant room signage; adhered with double sided acrylic foam tape, typical at exit discharge, exit stair locations and elevators.
 - b. Mounting: Sixty (60) above finished floor to centerline of sign on latch side of door; no closer the nine (9) inches to centerline of sign from adjacent door swing or obstruction.
 - c. Sizes: Refer to Drawings and Signage Schedule
 3. Type 3A Interior Wayfinding Signage
 - a. Directional signage: Photopolymer AAB-compliant directional signage, adhered with double sided acrylic foam tape; locations to be reviewed and approved by the Architect
 - b. Mounting: Mounting height to be reviewed and approved by the Architect
 - c. Sizes: Refer to Drawings and Signage Schedule
 4. Type 4A, 4B and 4C Interior Informational Signage
 - a. Information Signage: Photopolymer signage with informational text per signage schedule, adhered with double sided acrylic foam tape; locations to be reviewed and approved by the Architect
 - b. Mounting: Mounting height to be reviewed and approved by the Architect
 - c. Sizes: Refer to Drawings and Signage Schedule
 5. Type 4D Interior Machine Room Signage
 - a. Machine Room Warning: Photopolymer signage with safety text compliant with 524 CMR 35.00, adhered with double sided acrylic foam tape, typical at elevator machine room
 - b. Mounting: Mounting height to be reviewed and approved by the Architect
 - c. Sizes: Refer to Drawings and Signage Schedule
 6. Type 5A, 5B and 5C Interior Projecting Safety Specialties Signage

SIGNAGE

-
- a. Fire extinguisher and AED location signage: Projecting V-shaped acrylic signage, mounted directly above fire extinguishers, fire extinguisher cabinets, and AED cabinets
 - b. Sizes: Refer to Drawings and Signage Schedule
 7. Types 6A and 6B Interior Areas of Rescue Assistance Signage
 - a. Raised character and braille signage: Photopolymer AAB-compliant instructional signage, adhered with double sided acrylic foam tape, typical at all areas of rescue assistance
 - b. Mounting: Mounting height to be reviewed and approved by the Architect
 - c. Sizes: Refer to Drawings and Signage Schedule
 8. Type 7A Assistive Listening Signage
 - a. Assistive Listening System: Photopolymer AAB-compliant assistive listening signage, adhered with double sided acrylic foam tape, at assistive listening device storage location.
 - b. Mounting: Sixty (60) inches above finish floor to centerline of signage
 - c. Sizes: Refer to Drawings and Signage Schedule
 9. Type 8A Interior Egress Plan Insert Holder
 - a. Egress Plan Display: Clear acrylic holder with slot for egress plan graphics, adhered with double sided acrylic foam tape, typical at all permanent spaces; plan inserts to be provided by Owner
 - b. Mounting: Mounting height and orientation to be reviewed and approved by the Architect
 - c. Sizes: Refer to Drawings and Signage Schedule
 10. Type 9A Large Informational Signage
 - a. Cast Aluminum Signage: Cast aluminum individual letters at Circulation and Adult Reading rooms (refer to Drawings); finish and font to be selected by the Architect; letters shall be mechanically fastened and flush mounted
 - b. Mounting: Mounting height to be reviewed and approved by the Architect
 - c. Sizes: Refer to Drawings and Signage Schedule
 11. Type 9B Overhead Wayfinding Signage
 - a. Painted Aluminum Signage: Painted aluminum individual letters and mounting tube, suspended from ceiling throughout Children's library (refer to drawings); finish and font to be selected by the Architect; letters shall be mechanically fastened to suspended tube
 - b. Mounting: Mounting height to be reviewed and approved by the Architect
 - c. Sizes: Refer to Drawings and Signage Schedule
 12. Type 20 Exterior Door Identification Signage
 - a. Door Numbers: Die-cut vinyl letters/numbers for identification of all exterior doors
 - b. Mounting: Mounting height to be reviewed and approved by the Architect
 - c. Sizes: Refer to Drawings and Signage Schedule
 13. Type 21 Exterior Accessibility Wayfinding Signage

- a. Directional Signage: Painted aluminum AAB-compliant directional signage, wall- or post-mounted is indicated in the Drawings and Signage Schedule
 - b. Mounting: Mounting height to be reviewed and approved by the Architect
 - c. Sizes: Refer to Drawings and Signage Schedule
14. Type 22 Reflective Signage
- a. Fire Department Identification Signage: Reflective final lettering on stainless steel signage, at exterior fire department connection
 - b. Mounting: To be mounted directly above fire department connection adjacent to Vestibule & Book Drop 102.
 - c. Sizes: Refer to Drawings and Signage Schedule
15. Custom Vinyl Printed Wall Mural at Children's Early Literacy (Room 109)
(Refer to 14/A8.3 and 15/A8.3)

1.2 RELATED SECTIONS

- A. Section 01 74 19 - CONSTRUCTION WASTE MANAGEMENT AND DISPOSAL: Procedural and administrative requirements for construction and demolition recycling.
- B. Section 01 50 00 - TEMPORARY FACILITIES AND CONTROLS: Temporary project sign and safety signage.
- C. Section 03 30 00 – CAST-IN-PLACE CONCRETE: Installation of sign pedestal anchors into concrete.
- D. Section 06 10 00 – ROUGH CARPENTRY: In-wall support blocking
- E. Section 09 29 00 – GYPSUM BOARD: Gypsum board surface conditions.

1.3 SUBMITTALS

- A. Submit the following under provisions of Section 01 33 00 - SUBMITTAL PROCEDURES:
 - 1. Literature: Manufacturer's product data sheets, specifications, physical properties for each item furnished hereunder.
 - 2. Schedule: The Architect will prepare and issue a schedule for all identification devices to be furnished hereunder, including character types, and colors. After receipt of the Architect's schedule, prepare and submit shop drawings and verification schedule.
 - 3. Shop drawings:
 - a. Plan drawing showing location of each interior and exterior sign. Coordinate plan with schedule.
 - b. Elevation drawings showing full size elevations of each sign. Indicate for each sign: sign styles, lettering and locations, and overall dimensions.
 - c. Large scale design details of signs, showing attachment clips and brackets; and complete installation details.
 - 4. Selection samples:

- a. Sample plastic chips indicating Manufacturer's full range of colors available for initial selection by Architect.
- 5. Verification samples:
 - a. Full size sample sign, of type, style and color specified including method of attachment.
 - b. Full size aluminum letter in specified size, finish and typeface, with mounting collar and stud
 - c. Full size sign in specified finish and typeface. Approved sample may be used in finished Project.

1.4 REGULATORY REQUIREMENTS

- A. Comply with all applicable federal, state and municipal codes, laws and regulations regarding signage for exits and handicapped barriers.

1.5 QUALITY ASSURANCE

- A. Sign fabricator specializing in the work of this Section with a minimum of 5 years experience.

1.6 DELIVERY, STORAGE AND HANDLING

- A. Delivered packaged signs, labeled in name groups.
- B. Store all materials in an elevated dry location, protected by waterproof coverings. Store adhesive tape at ambient room temperature.

1.7 ENVIRONMENTAL CONDITIONS

- A. Do not install adhesive applied signs when ambient temperature is below 70 degrees Fahrenheit. Maintain this minimum during and after installation of signs.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturers: Subject to compliance with the requirements specified herein, manufacturers offering products which may be incorporated in the work include the following, or approved equal:
 - 1. Interior plaque signs:
 - a. Basis of Design: Sunshine Sign, North Grafton, MA
 - b. Apco New England, Franklin, MA
 - c. Design Communications, Boston, MA
 - d. General Sign Company, Norwood, MA
 - e. Back Bay Sign Company, Somerville, MA
 - 2. Individual letter signage:
 - a. Basis of Design: Sunshine Sign, North Grafton, MA
 - b. ARK Ramos, Oklahoma City, OK.
 - c. Gemini Inc., Cannon Falls, MN
 - d. Matthews International Corporation, Pittsburgh, PA

- e. Metal Arts, Mandan, ND.

2.2 SIGNAGE - GENERAL

- A. General: Provide sign copy to comply with the requirements indicated in the Drawings, for sizes, styles, spacing, content, positions, materials, finishes and colors of letters.
 - 1. All Signs shall conform to United States "*Americans with Disabilities Act*" and Commonwealth of Massachusetts Regulation 521 CMR: *Architectural Access Board*.
 - 2. Final placing, mounting heights and sizing of lettering shall be done as part of the shop drawing approval process, at which time the manufacturer shall make recommendations for Architect's review. Lettering shall have stroke width to height ratio and width to height ratio in accordance with the "*Americans with Disabilities Act*."
- B. Installation of all signs shall be done by vandal-proof method, fully described on the shop drawings.

2.3 INTERIOR PLAQUE SIGNAGE

- A. Photopolymer plaque signage (general requirements): Identification signs with raised tactile graphics, text, and Grade 2 Braille as indicated in schedule. Signs shall consist of 1/32 inch thick synthetic light sensitive photo emulsion permanently bonded to a rigid phenolic substrate, aluminum or acrylic plaque, in accordance with "*Americans with Disabilities Act*." Photopolymer to be bonded to sign plaque with appropriate laminating film as recommended by the photopolymer manufacturer.
 - 1. Lettering height: To be determined.
 - 2. Lettering font: Arial Regular
 - 3. Screenprinting: All screen printing graphics, including raised areas of tactile plaques except Braille, shall be screen printed in a contrasting color so as to meet the color contrast requirements of Americans with Disabilities Act.
 - a. All non-tactile text shall be screen printed with catalyzed epoxy ink. Applied vinyl lettering and graphics is not acceptable.
 - b. Apply screen printing inks evenly without pinholes, scratches or orange-peeling.
 - 4. Graphics: All text, symbols and graphics shall be reproduced utilizing computer generated digital art. All screen printed graphics shall utilize photographically prepared screens and shall be printed in accordance with industry standards. Hand-cut screens are not acceptable.
 - a. All edges and corners and letter forms shall be true and clean. Letterforms, color areas, or lines with rounded positive or negative corners, built-up edges, bleeding, spattering, etc., shall not be accepted.
 - b. Prepare artwork from typesetters reproduction of the test specified, minimum 1200 dpi resolution, camera ready artwork. All camera ready artwork and typesetting shall be no less than 75 percent of actual finished size.
 - 5. Mounting: Surface applied by means of silastic adhesive mounting.

6. Sign colors: As selected by Architect from manufacturer's standard and standard special colors.
 - a. All signs shall be two color signs.
7. Refer to drawings for designs and signage schedule.

2.4 SAFETY SIGNS

- A. Identification signage at Fire Extinguishers and AED Cabinet
 1. Allow one identification sign for every Fire Extinguisher and AED cabinet on the plans.
 2. Refer to drawings for designs and signage schedule.

2.5 EXTERIOR DOOR IDENTIFICATION SIGNAGE

- A. Signage at exterior doors: Fabricate die-cut copy characters, from opaque non-reflective cast vinyl film, with pressure sensitive adhesive backing, suitable for exterior applications, at interior and exterior sides of all exterior doors
 1. Letterform: 1.5-inch high, upper case, normal spacing with font directed by Architect
 2. Color: As Selected.

2.6 CAST METAL LETTERS

- A. Cast aluminum letters: Projecting individual cast aluminum letters, thickness and finish as indicated on the drawings, in typeface as selected by the Architect.
 1. Cast aluminum shall be solid aluminum, no scrap permitted. Cast aluminum shall be free of all porosity, with sharp corners, flat and accurate profiles. All exposed welds shall be filed smooth with all tool marks removed by fine abrasive grain air blasting or other approved method. All burrs and rough spots shall be removed and faces shall be polished to a uniform high luster finish. Aluminum shall be mechanically sanded and degreased prior to receiving finish. All coatings shall be true to form with no irregularities.

2.7 CUSTOM PRINTED VINYL WALL MURAL

- A. Basis of design: 3M: Envision Print Film 48C
 1. Description: Removable 3 mil thick non-PVC polymer film with a matte finish.
 2. GREENGUARD Gold certified
 3. Full color Digital Print: Eco-solvent Inkjet, Latex Inkjet, Solvent Screenprint or UV Screenprint, Design content to be provided by architect.
 4. Opacity: Opaque
 5. Color: White
 6. Removable with heat
 7. Dimensions: Custom size as indicated on drawings.
 8. Adhesive: Pressure-activated (slide, tack, snap-up, reposition) with air release channels, as recommended by the Manufacturer for the substrate.

2.8 ACCESSORIES

- A. Exposed mounting hardware: Chrome plated brass or bronze screws.

- B. Adhesive tape: Double sided acrylic foam tape, permanent adhesive, equal to 3M, St. Paul, MN, product: "3M VHB".
- C. Fasteners for entrance and exit signs: Concealed metal fasteners, non-corrosive to sign material or mounting surface.
- D. Anchors and inserts for cast aluminum letters:
 - 1. Mounting studs: Threaded type 304 stainless steel studs.
- E. Fasteners for existing interior brass plate signage: N°. 6 brass wood screws, round head.

2.9 FINISHES

- A. Colors and Surface Textures: For exposed sign material that requires selection of materials with integral or applied colors, surface textures or other characteristics related to appearance, provide color matches indicated.
- B. Metal Finishes: Comply with NAAMM "Metal Finishes Manual" for finish designations and application recommendations.
- C. Aluminum Finishes: Finish designations prefixed by AA conform to the system established by the Aluminum Association for designation aluminum finishes
 - 1. Class II Clear Anodized Fine Satin Finish: AA-M31C21 A31 (Mechanical Finish: Fine satin direction textured' Chemical Finish: Fine matte etched finish' Anodic Coating, Class II Architectural, clear film thicker than 0.4 mil.)
- D. Paints: Paint for signs is acrylic polyurethane enamel, eggshell finish. Paint for background of tactile photo-polymer signs is eggshell finish automotive grade lacquer. All surfaces shall be cleaned, primed and pre-treated according to the manufacturer's specifications and noted in Shop Drawings as part of the finished surface work.
- E. Inks:
 - 1. Inks for metal signs, glass and wall surfaces are Alkyd enamel based inks.
 - 2. Inks for plastic signs are lacquer based inks.
 - 3. Inks for tactile graphics on photo-polymer signs are eggshell finish Low Odor Vinyl Ink.
 - 4. Inks for filling acid-etched graphics in metal signs are semi-gloss epoxy ink.
 - 5. All inks and paints are evenly applied without pin-holes, scratches or application marks. Prime coats or other surface pre-treatments, where recommended by the manufacturers are included in the work and noted in the shop drawings as part of the finished surface work.

PART 3 - EXECUTION

3.1 INSTALLATION - GENERAL

- A. Locate sign units and accessories where indicated, locations in accordance with the approved shop drawings. Use mounting methods of the type described and in compliance with manufacturer's instructions.

- B. Install signs plumb, level and true to height indicated, with sign surfaces free from distortion or other defects in appearance.
- C. Shop fabricate signs where practical and deliver to site completely assembled. All joints of such fabricated work are completely smooth without apparent marks showing throughout the finish. All work "broken down" is erected so that all parts fit accurately with hairline joints, with all joints flush. Joints in lighted signs shall be light-proof.
- D. Wall and door mounted signs; All sign plaques mounted at glass door locations shall be backed with plaque of same size, thickness, material and color on opposite side to mask mounting adhesive.
 - 1. Attach to surfaces as follows:
 - a. Vinyl Tape Mounting: Use very high bond, double sided foam tape, of thickness indicated, to mount signs to smooth nonporous surface. Use construction adhesive in conjunction with foam tape.
 - b. Silicone Adhesive Mounting: Use appropriate liquid silicone adhesive to attach sign units to irregular, porous, or vinyl-covered surfaces. Use double-sided vinyl tape to hold the sign in place until the adhesive has fully cured.
- E. Dimensional Letters and Numbers: Mount letters and numbers using threaded studs, foam tape and construction adhesive as indicated in the detail drawings. Provide heavy paper template to establish letter spacing and to locate holes for fasteners.

3.2 INSTALLATION - SIGN POST MOUNTED SIGN (EXTERIOR SIGN TYPE 23)

- A. Do not commence installation of sign post until immediately adjacent surfaces have been completely installed and finished.
- B. Perform installation work in accordance with the approved shop drawings and the manufacturer's installation instructions.
- C. Set sign post absolutely level and in true line in concrete footing.

3.3 CLEANING

- A. Clean and polish installed signs.
- B. Upon completion of the work of this Section in any given area, remove tools and all rubbish and debris from the work area; leave area in broom-clean condition.
- C. Remove all names, stamps and decals of sign manufacturers, and installers. No visible advertising of any kind is permitted.

End of Section