TSIFRA LLC
Journal of Interdisciplinary Research (Demo)
Vol. 1, No. 2 (2025)
pp. 17–19 · ISSN 0000-0000 (online)

SHORT COMMUNICATION

Greywater Reuse in a Multi-Apartment Residential Block: A Pilot Assessment

Roman Dyakonov[1]✉, **Alina Safina**[2]

[1] Polis Graduate School of Urban Studies, Russia

[2] Volga Institute of Applied Analytics, Russia

✉ Corresponding author: Roman Dyakonov, r.dyakonov@example.org

Received: 14 May 2025 **Accepted:** 5 August 2025 **Published:** 25 September 2025

ABSTRACT

The reuse of lightly polluted domestic wastewater, or greywater, is regarded as one way to reduce the load on urban water supply and sewerage systems. This short communication presents the results of a pilot operation of a greywater treatment system in a residential block of three multi-apartment buildings (412 residents). Greywater from showers and washbasins was treated in a compact unit comprising mechanical filtration, a membrane bioreactor and ultraviolet disinfection, and then supplied for toilet flushing and irrigation of the surrounding grounds. Over 12 months, volumes were recorded daily and the quality of treated water was monitored weekly. Reuse reduced potable water consumption by 27% on average and by up to 34% in summer months owing to irrigation. Treated water consistently met the standards for non-potable water supply in terms of turbidity, biochemical oxygen demand and microbiological indicators. Specific operating costs were about 38 roubles per cubic metre, and the payback period at current tariffs is estimated at 9–11 years. A survey of residents showed a high level of acceptance of the technology (82% positive ratings), provided the water had no odour or discolouration. We conclude that greywater reuse systems are worth including in new residential development projects.

Keywords: greywater; water reuse; membrane bioreactor; water saving; residential development

Повторное использование серых вод в многоквартирном жилом квартале: пилотная оценка

Роман Дьяконов[1]✉, *Алина Сафина*[2]

[1] Высшая школа урбанистики «Полис», Россия

[2] Волжский институт прикладной аналитики, Россия

АННОТАЦИЯ

Повторное использование слабозагрязнённых бытовых сточных вод, или серых вод, рассматривается как один из способов снижения нагрузки на системы городского водоснабжения и водоотведения. В кратком сообщении представлены результаты пилотной эксплуатации системы очистки серых вод в жилом квартале из трёх многоквартирных домов (412 жителей). Серые воды от душевых и умывальников очищались на компактной установке, включающей механическую фильтрацию, мембранный биореактор и ультрафиолетовое обеззараживание, после чего подавались на смыв унитазов и полив придомовой территории. В течение 12 месяцев проводился ежедневный учёт объёмов и еженедельный контроль качества очищенной воды. Повторное использование позволило сократить потребление питьевой воды в среднем на 27 %, а в летние месяцы — до 34 % за счёт полива. Очищенная вода стабильно соответствовала нормативам для технического водоснабжения по мутности, биохимическому потреблению кислорода и микробиологическим показателям. Удельные эксплуатационные затраты составили около 38 руб. за кубический метр, срок окупаемости при действующих тарифах оценивается в 9–11 лет. Опрос жителей показал высокий уровень принятия технологии (82 % положительных оценок) при условии отсутствия запаха и окрашивания воды. Сделан вывод о целесообразности включения систем повторного использования серых вод в проекты новой жилой застройки.

Licensed under CC BY 4.0

Ключевые слова: серые воды; повторное использование воды; мембранный биореактор; водосбережение; жилая застройка

For citation: Dyakonov R., Safina A. Greywater Reuse in a Multi-Apartment Residential Block: A Pilot Assessment. *Open Journal Systems demo journal* 2025;1(2):17–19.

1 INTRODUCTION

About a third of the drinking water consumed in residential buildings is used for toilet flushing and irrigation — purposes for which drinking-water quality is not required. Greywater from showers and washbasins accounts for up to 60% of household wastewater and is relatively lightly polluted, which makes it an attractive source for non-potable water supply.

The aim of this communication is to present the results of one year of pilot operation of a greywater reuse system in a multi-apartment residential block and to assess its effectiveness, cost-efficiency and perception by residents.

2 MATERIALS AND METHODS

The pilot block comprises three ten-storey buildings with separate internal sewerage for greywater and blackwater. A treatment unit with a capacity of 25 m³/day is located in the basement. The volumes of incoming greywater, treated water and make-up water from the municipal network were recorded by automatic flow meters; the quality of treated water was monitored weekly by an accredited laboratory. At the end of the period, a questionnaire survey of residents was conducted (n = 163).

3 RESULTS

The mean daily volume of reused water was 14.6 m³. The monthly share of drinking water substitution is shown in Fig. 1: the lowest values were recorded in winter (22–24%) and the highest in July and August (33–34%). Treated water quality indicators are given in Table 1.




Fig. 1. Share of drinking water substituted by treated greywater by month, %

Table 1. Treated water quality (mean over 52 weeks)

Indicator	Greywater	After treatment	Standard
Turbidity, FTU	68	0,9	≤ 2
BOD_5, mg/L	142	4,1	≤ 10
Suspended solids, mg/L	95	< 2	≤ 10
E. coli, CFU/100 mL	10^4–10^5	not det.	absent

Licensed under CC BY 4.0

4 DISCUSSION

The substitution share obtained is close to the theoretical potential for this type of housing. Cost-efficiency depends strongly on water tariffs: as they rise, the payback period shortens to 6–7 years. Importantly, residents perceive the technology positively; however, any deviation in the organoleptic properties of the water quickly undermines trust, so reliable disinfection and monitoring are critical.

5 CONCLUSION

The greywater reuse system made it possible to reduce drinking water consumption by a quarter, with the treated water consistently meeting the standards. The technology can be recommended for new multi-apartment residential developments.

REFERENCES

1. Дьяконов Р. В. Децентрализованные системы водоотведения в жилой застройке: зарубежный опыт // Городское хозяйство и инфраструктура. 2022. № 6. С. 33–47.
2. Eriksson E., Auffarth K., Henze M., Ledin A. Characteristics of grey wastewater // Urban Water. 2002. Vol. 4, no. 1. P. 85–104.
3. Сафина А. Р., Дьяконов Р. В. Экономическая оценка проектов водосбережения в многоквартирных домах // Пространственная экономика и политика. 2023. № 2. С. 58–72.
4. Okoro N., Lindahl S. Membrane bioreactors for decentralised greywater treatment: a performance review // Water Technology Letters. 2021. Vol. 13. P. 140–158.
5. Mendes T., Haas R. Public acceptance of recycled water for domestic uses // Journal of Water and Society. 2020. Vol. 8, no. 2. P. 99–117.
6. Дьяконов Р. В. Водный баланс жилого квартала: методика расчёта. Новобор: Полис, 2021. 92 с.

Licensed under CC BY 4.0