

COMMENTS :

09

AS BUILT

	N.					
	Date					
	N.					
	Date					
	N.					
	Date					
	N.					
	Date					
C	N.	BGA	HAR	DEG	AS BUILT	ASB
	Date	95/03/22	95/03/22	95/03/22		
B	N.	HUE	HAR	DEG	UP DATED ACCORDING TO EM 208	GFE
	Date	93/01/18	93/01/18	93/01/18		
A	N.	HUE	HAR	DEG	ORIGINAL ISSUE	APP
	Date	92/11/13	92/11/13	92/11/13		
REV.		ETABLI ESTABLISHED	VERIFIE CHECKED	APPROUVE APPROVED	MODIFICATIONS	STAT.

VINH-SON HYDRO-POWER STATION

2 x 40 MVA


CONTRACT N° 12-05/CEG-PC3-PET/01-91

SOCIALIST REPUBLIC OF VIET-NAM
MINISTRY OF ENERGYPETECHIM-POWER COMPANY Nr 3
ENGINEER EDF

LEADER

CEGELEC

FRANCE

ALSTHOM - JEUMONT
CEGELECNEYRPIC
SDEMECHELLE
SCALEPOWER HOUSE
48 V DC
LOAD BALANCE
TECHNICAL NOTE

	DATE	NOM NAME	VISA
ETABLI ESTABLISHED	92/11/13	HUE	
VERIFIE CHECKED	92/11/13	HARNAY	
APPROUVE APPROVED	92/11/13	DELAGE	

CEGELEC

Division ERE P : 35, rue d'Alsace F - 92531 Levallois Perret Cedex

CGE VIN20 SLCA-NT001

P2135A40078-c

FOLIO
SHEET
1
F.FIN
SH. END
2

Ce document propriété de CEGELEC ne doit pas être utilisé, copié ou communiqué à des tiers sans son autorisation.

D.C. VOLTAGE : 48 V DC
SWITCHBOARD : 20LCA001TB

PROJECT : VINH-SON
AREA : POWER HOUSE

OUTGOING	NAMES	CONSUMERS REFERENCES			TOTAL ELECTRICAL CONSUMPTION W	PERMANENT CURRENT A	PEAK CURRENT A		
005JD	UNIT 1 CONTROL PANEL	01GTA001TD			540,97	11,27	51,19		
006JD	AUXIL. RELAYING PROTECTION PANEL	00KKL001TD			739,77	15,41	23,86		
007JD	VENTILATION	20DVM001CR			175,00	3,65	4,65		
008JD	AIR CONDITIONING	20DVL001CR			223,00	4,65	5,90		
009JD	SERVICE WATER LOCAL CONTROL BOX	20SEI001CR			22,50	0,47	1,06		
010JD	TRANSFO. FIRE PROTECTION LOCAL CONTROL BOX	20JPT001CR			33,00	0,69	1,56		
011JD	HYDRAULIC MEASURES PANEL	00KMH001TD			230,00	4,79	6,83		
012JD	UNIT 2 CONTROL PANEL	02GTA001TD			540,97	11,27	51,19		
013JD	SWITCHYARD CONTROL PANEL COUPLING	60LRC001TD			45,00	0,94	8,14		
014JD	SWITCHYARD CONTROL PANEL LINE 1	61LRL001TD			70,00	1,46	8,66		
015JD	SWITCHYARD CONTROL PANEL LINE 2	62LRL001TD			70,00	1,46	8,66		
016JD	SWITCHYARD CONTROL PANEL BUS BARS	60LRC001TD			154,00	3,21	3,21		
017JD	FIRE PROTECTION CONTROL PANEL TR UNIT 1	01JPT001CR			50,00	1,04	1,04		
018JD	FIRE PROTECTION CONTROL PANEL TR UNIT 2	02JPT001CR			50,00	1,04	1,04		
019JD	AUXIL. RELAYING PROTECTION PANEL	00KKL001TD			29,76	0,62	0,62		
020JD	EQUIPPED SPARE				0,00	0,00	0,00		
021JD	EQUIPPED SPARE				0,00	0,00	0,00		
					0,00	0,00	0,00		
TOTAL					2944,21	61,34			

P2135A4007E FOLIO N°

2