

IEEE 14 Bus Simulation

Simulations Done by: Vraj Prajapati

LinkedIn : www.linkedin.com/in/vip95

Github Profile : <https://github.com/vrajprajapati95>

Github Repository :

Contact info : vrajprajapati23042001@gmail.com

Useful Links for Downloading Additional Power System Analysis Resources:

(All necessary data for completing this simulation was obtained from the resources listed below. Full credit goes to the original creators, and special thanks to the open-source communities and contributors, without whom this project would not have been possible.)

1. https://tweckesser.wordpress.com/power-system-data-and-test-cases/?utm_source=chatgpt.com

2. <https://icseg.iti.illinois.edu/power-cases/>

3. <https://www.kios.ucy.ac.cy/testsystems/>

4. <https://webhomes.maths.ed.ac.uk/OptEnergy/NetworkData/>

5. <https://labs.ece.uw.edu/pstca/>


This project was undertaken to gain a deeper understanding of power system modeling and simulation. For the sake of simplicity and clarity, the IEEE 14-bus system was used as the test case.

The following studies were conducted on this system :

1. Loadflow
2. Short Circuit Analysis
3. Motor Starting
4. Harmonic Analysis
5. Dynamic/Transient Analysis

IEEE 14 Bus Simulation

Loadflow Study:



IEEE 14 Bus Simulation

Loadflow Results:


From Area/Zone	To Area/Zone	P Loss (MW)	Q Loss (MVar)	P Imp (MW)	Q Imp (MVar)	P Gen (MW)	Q Gen (MVar)	P Load (MW)	Q Load (MVar)	Gen. Cost (Curr. Units)	Qc Shunt (MVar)	Ql Shunt (MVar)	Q Comp (MVar)	Iron Losses (MW)
Network		13.501	27.972	232.501	-15.762	272.501	33.032	259	5.06	0	0	0	0	0
Area 1		13.501	27.972	0	0	272.501	33.032	259	5.06	0	0	0	0	0
Zone 1		13.501	27.972	0	0	272.501	33.032	259	5.06	0	0	0	0	0

Voltage (kV)	P Loss Li (MW)	Q Loss Li (MVar)	P Loss L (MW)	Q Loss L (MVar)	P Loss T (MW)	Q Loss T (MVar)
7.8	0.588	2.721	0	0	0	0
13.8	0	0	0	0	0	0
18	0	0	0	0	0.89	0
69	12.913	16.727	0	0	7.635	0

ID	Name	U (kV)	u (%)	U ang (°)	P Load (MW)	Q Load (MVar)	P Gen (MW)	Q Gen (MVar)
174092	BUS-1	73.14	106	0	15.762	0	232.501	0
174077	BUS-10	13.767	99.76	-15.5	5.9	5.8	0	0
174074	BUS-11	13.857	100.41	-15.3	5.3	1.8	0	0
174075	BUS-12	13.833	100.24	-15.7	5.7	1.6	0	0
174061	BUS-13	13.764	99.96	-15.7	13.5	5.8	0	0
174063	BUS-14	13.545	98.14	-16.6	14.9	5	0	0
174062	BUS-15	72.105	104.5	-12.7	12.7	4	0	48.794
174096	BUS-3	69.696	101.12	-12.8	94.2	19	0	28.34
174095	BUS-4	69.715	101.04	-12.1	0	0	0	0
174090	BUS-5	70.222	101.77	-8.7	2.6	1.6	0	24
174093	BUS-6	45.01	101.1	-14.7	1.2	0.5	0	0
174082	BUS-7	14.192	102.84	-13.4	3.5	0	0	0
174081	BUS-8	13.804	100.6	-15.3	2	0	0	0
174071	BUS-9	13.837	100.26	-15.3	29.5	16.6	0	0

IEEE 14 Bus Simulation

Short Circuit Analysis :



IEEE 14 Bus Simulation

Short Circuit Analysis Results:


Fault Current																				
ID	Fault Location From	To Node	Distance from fault	Element Name	Type	Un (kV)	UL-E (kV)	AU L-E (°)	Ik'' (kA)	Alk'' (°)	Fault Type	Method	Maximum	Network Type	CB Delay Time (s)	SC Duration (s)	SC Duration (s)	Zone	Area	Partial Network
174086	BUS-4	Faulted	0	—	—	69	43.82	180	12.717	-81.38	3phase	IEC6090	<input checked="" type="checkbox"/>	MESHED	0.02	1	0.02	Zone 1	Area 1	1
174351	BUS-4	BUS-3	—	TL_3-4	Line	—	2.828	103.55	—	—	—	—	<input type="checkbox"/>	—	—	—	—	Zone 1	Area 1	1
174366	BUS-4	BUS-5	—	TL_5-4	Line	—	4.573	97.52	—	—	—	—	<input type="checkbox"/>	—	—	—	—	Zone 1	Area 1	1
174371	BUS-4	BUS-2	—	TL_2-4	Line	—	2.563	100.69	—	—	—	—	<input type="checkbox"/>	—	—	—	—	Zone 1	Area 1	1
174230	BUS-4	BUS-9	—	TRF_4-9	2W Transfo	—	0.808	95.12	—	—	—	—	<input type="checkbox"/>	—	—	—	—	Zone 1	Area 1	1
174271	BUS-4	BUS-7	—	TRF_4-7	2W Transfo	—	1.97	92.84	—	—	—	—	<input type="checkbox"/>	—	—	—	—	Zone 1	Area 1	1

Current at fault locations																
	ID	Fault Location	Un (kV)	Ik''(kA)	Alk'' (°)	Fault Type	Method	Maximu m	Network Type	CB Delay Time (s)	SC Duration (s)	SC Duration (s)	Descripti on	Zone	Area	Partial Network
	174086	BUS-4	69	12.71	-81.38	3phase fault	IEC60909	☑	MESHED	0.02	1	0.02	—	Zone 1	Area 1	1

Node Voltages																		
ID	Name	Faulted	Un (kV)	U L-E (kV)	AU L-E (°)	U L-L (kV)	AU L-L (°)	U (012) (kV)	AU (012) (°)	U0 (kV)	AU0 (°)	Fault Type	Method	Maximum	Description	Zone	Area	Partial Network
174086	BUS-4	<input checked="" type="checkbox"/>	69	43.821	180	75.9	330	43.821	180	0	-90	3phase fault	IEC60909	<input checked="" type="checkbox"/>	—	Zone 1	Area 1	1

IEEE 14 Bus Simulation

Motor Starting Analysis:



IEEE 14 Bus Simulation

		t (s)	U (kV)	I (kA)	P (MW)	Q (Mvar)	Me (Nm)	MI (Nm)	s	n/nr
174648	Motor_load	0	14.012	0.032	0.537	0.556	3391.549	3354.714	0.0024	1.0077

174141	GEN_bus_2	0		0.448	-39.998	-39.114				
		0.01		0.448	-39.998	-39.114				

174486	SL_GEN_1	0			1.712	-216.281	15.657			
		0.01			1.712	-216.281	15.657			

174175	SYN_CON_ bus_3	0			0.203	0.001	-24.54			
		0.01			0.203	0.001	-24.54			

174185	SYN_CON_ bus_8	0			0.714	0.002	-24.018			
		0.01			0.714	0.002	-24.017			

174151	SYN_CON D_bus_6	0			0.974	0.003	-24.003			
		0.01			0.974	0.004	-24.003			

174336	TL_1-2	0			1.164	146.373	-17.914			
		0.01			1.164	146.373	-17.914			

174361	TL_1-5	0			0.552	-67.546	2.151			
		0.01			0.552	-67.546	2.151			

174308	TL_11-10	0			0.137	-2.646	-1.98			
		0.01			0.137	-2.646	-1.98			

174293	TL_12-13	0			0.029	-0.319	-0.636			
		0.01			0.029	-0.319	-0.636			

174323	TL_14-13	0			0.025	-0.502	0.352			
		0.01			0.025	-0.503	0.351			

IEEE 14 Bus Simulation

174371	TL_2-4	0		0.415	51.885	-0.298
		0.01		0.415	51.885	-0.298

174283	TL_2-5	0		0.303	37.79	-0.511
		0.01		0.303	37.79	-0.511

174346	TL_3-2	0		0.571	71.262	3.758
		0.01		0.571	71.262	3.758

174351	TL_3-4	0		0.218	25.583	-7.074
		0.01		0.218	25.583	-7.074

174366	TL_5-4	0		0.493	60.309	-1.643
		0.01		0.493	60.308	-1.643

174303	TL_6-11	0		0.297	-6.154	-3.8
		0.01		0.297	-6.154	-3.8

174288	TL_6-12	0		0.279	-6.42	-2.237
		0.01		0.279	-6.42	-2.237

174298	TL_6-13	0		0.57	-12.68	-5.516
		0.01		0.57	-12.679	-5.515

174331	TL_7-9	0		1.31	23.775	22.272
		0.01		1.31	23.774	22.271

174313	TL_9-10	0		0.307	-6.354	-3.82
		0.01		0.307	-6.354	-3.82

174318	TL_9-14	0		0.044	-1.039	-0.206
		0.01		0.044	-1.038	-0.205

174271	TRF_4-7	0		0.957	-23.777	0.874
		0.01		0.957	-23.777	0.874

174230	TRF_4-9	0		0.541	-13.137	0.519
		0.01		0.541	-13.137	0.519

IEEE 14 Bus Simulation

174257	TRF_7-8	0		0.931	0.002	-23.146
		0.01		0.931	0.002	-23.146

174216	Xmer_5-6	0		1.5	-36.682	4.495
		0.01		1.499	-36.682	4.495

174092	BUS-1	0	73.14			
		0.01	73.14			

174077	BUS-10	0	13.966
		0.01	13.966

174074	BUS-11	0	14.047
		0.01	14.047

174065	BUS-12	0	14.043
		0.01	14.043

174062	BUS-13	0	14.017
		0.01	14.017

174068	BUS-14	0	14.012
		0.01	14.012

174095	BUS-2	0	72.105
		0.01	72.105

174098	BUS-3	0	69.69
		0.01	69.69

174086	BUS-4	0	70.166
		0.01	70.166

174089	BUS-5	0	70.659
		0.01	70.66

174080	BUS-6	0	14.229
		0.01	14.229

IEEE 14 Bus Simulation


174101	BUS-7	0	14.358
		0.01	14.358

174083	BUS-8	0	19.433
		0.01	19.433

174071	BUS-9	0	14.037
		0.01	14.037

IEEE 14 Bus Simulation

Harmonic Analysis:



IEEE 14 Bus Simulation


ID	Name	THD (%)	f (Hz)	U (V)	U (%)	U ang	Descripti	Zone	Area	Network
174092	BUS-1	5.12	150	3200.753	4.64	269.89		Zone 1	Area 1	1
			250	0.1741	0	-20.49				
			350	544.599	0.79	71.8				
			550	0.1605	0	-15.86				
			650	480.416	0.7	-82.55				
			850	0.339	0	-20.43				
			950	304.556	0.44	265.91				
			1050	1268.149	1.84	265.16				
174077	BUS-10	5.55	150	566.906	4.11	-89.76		Zone 1	Area 1	1
			250	25.23	0.18	82.34				
			350	239.452	1.74	82.66				
			550	35.36	0.26	85.98				
			650	103.853	0.75	87.3				
			850	37.932	0.27	86.02				
			950	174.849	1.27	88.7				
			1050	403.884	2.93	85.33				
174074	BUS-11	5.88	150	540.383	3.92	-89.6		Zone 1	Area 1	1
			250	12.978	0.09	76.62				
			350	279.974	2.03	84.32				
			550	17.918	0.13	83.3				
			650	143.165	1.04	87.84				
			850	19.181	0.14	84.33				
			950	219.688	1.59	88.95				
			1050	468.015	3.39	85.88				
174065	BUS-12	8.4	150	445.977	3.23	-88.4		Zone 1	Area 1	1
			250	112.433	0.81	84.88				
			350	528.434	3.83	85.72				
			550	157.73	1.14	87.53				
			650	334.772	2.43	88				
			850	162.365	1.18	88.35				
			950	459.19	3.33	88.83				
			1050	690.991	5.01	86.95				
174062	BUS-13	10.62	150	393.834	2.85	-85.83		Zone 1	Area 1	1
			250	205.633	1.49	82.94				
			350	709.02	5.14	85.23				
			550	288.565	2.09	86.73				
			650	466.671	3.38	87.65				
			850	297.178	2.15	87.85				
			950	629.405	4.56	88.56				
			1050	813.543	5.9	87.03				
174068	BUS-14	7.25	150	497.518	3.61	-88.47		Zone 1	Area 1	1
			250	105.734	0.77	83.22				
			350	430.159	3.12	84.35				
			550	148.435	1.08	86.78				
			650	249.881	1.81	87.58				
			850	153.909	1.12	87.65				
			950	358.623	2.6	88.61				
			1050	567.042	4.11	86.29				

IEEE 14 Bus Simulation



174095	BUS-2	5	150	3186.101	4.62	269.89		Zone 1	Area 1	1
			250	0.3064	0	-13.95				
			350	527.853	0.77	71.18				
			550	0.2506	0	-12.93				
			650	428.265	0.62	-82.99				
			850	0.39	0	-18.81				
			950	236.465	0.34	266.27				
			1050	1103.431	1.6	265.1				
174098	BUS-3	4.78	150	3180.275	4.61	269.84		Zone 1	Area 1	1
			250	0.1897	0	-12.47				
			350	350.622	0.51	65.18				
			550	0.149	0	-12.02				
			650	236.122	0.34	-87.78				
			850	0.206	0	-18.02				
			950	75.259	0.11	265.77				
			1050	774.837	1.12	266.12				
174086	BUS-4	5.04	150	2983.885	4.32	-89.73		Zone 1	Area 1	1
			250	24.52	0.04	72.85				
			350	716.16	1.04	70.11				
			550	38.229	0.06	76.15				
			650	212.179	0.31	-82.01				
			850	68.084	0.1	71.27				
			950	151.402	0.22	81.53				
			1050	1606.727	2.33	84.18				
174089	BUS-5	5.16	150	2931.281	4.25	-89.57		Zone 1	Area 1	1
			250	15.998	0.02	68.08				
			350	800.623	1.16	73.12				
			550	27.107	0.04	73.85				
			650	230.12	0.33	-77.74				
			850	61.362	0.09	69.82				
			950	173.895	0.25	84.8				
			1050	1827.706	2.65	84.61				
174080	BUS-6	6.33	150	512.886	3.72	-89.37		Zone 1	Area 1	1
			250	2.495	0.02	0.17				
			350	326.737	2.37	85.69				
			550	1.602	0.01	-0.06				
			650	186.301	1.35	88.18				
			850	1.079	0.01	-0.36				
			950	269.861	1.96	89.16				
			1050	534.472	3.87	86.29				
174101	BUS-7	5.2	150	597.896	4.33	-89.76		Zone 1	Area 1	1
			250	15.64	0.11	82.7				
			350	158.85	1.15	78.86				
			550	22.167	0.16	85.64				
			650	34.794	0.25	83.16				
			850	25.072	0.18	84.34				
			950	91.808	0.67	87.92				
			1050	346.887	2.51	84.53				
174083	BUS-8	5.04	150	779.865	4.33	-89.76		Zone 1	Area 1	1
			250	0.139	0	-6.91				
			350	83.957	0.47	78.62				
			550	0.0895	0	-4.18				
			650	18.389	0.1	83.03				
			850	0.0655	0	-5.54				
			950	48.523	0.27	87.83				
			1050	452.461	2.51	84.53				
174071	BUS-9	5.44	150	578.559	4.19	-89.81		Zone 1	Area 1	1
			250	31.04	0.22	83.66				
			350	225.588	1.63	81.88				
			550	43.623	0.32	86.59				
			650	88.283	0.64	86.97				
			850	46.815	0.34	86.41				
			950	158.032	1.15	88.59				
			1050	375.691	2.72	85.02				

IEEE 14 Bus Simulation



Dynamic/Transient Simulation



IEEE 14 Bus Simulation



IEEE 14 Bus Simulation



IEEE 14 Bus Simulation

