



ABSOLUTE ENERGY

LOW POWER FACTOR (< 0.95) INCIDENT ANALYSIS REPORT

PF Meter Name : AMPL_Main_Inc/Power_Factor_Total_2
Activity : Energy Monitoring
Address : Absolute Motion Private Limited

Period Analyzed : 2026-08-01 to 2026-08-07
PF Threshold : 0.95
Generated On : 07/08/2026, 05:17:48 pm

POWER FACTOR ANALYSIS & METRICS

LOW PF INCIDENTS

9

MINIMUM RECORDED PF

-0.9600

AVG LOW PF (DURING INCIDENTS)

0.7130

INCIDENT RATIO

86.53%

LOG OF POWER FACTOR DROPS (< 0.95) — GROUPED INCIDENT EPISODES

#	Episode Start Time (IST)	Episode End Time (IST)	Duration	Min PF	Avg PF	Max Deficit
1	01/08/2026, 12:00:13 am	01/08/2026, 09:21:26 am	9h 21m	-0.9600	0.5203	-1.9100
2	01/08/2026, 09:36:27 am	02/08/2026, 12:22:49 am	14h 46m	0.5000	0.8283	-0.4500
3	02/08/2026, 12:58:19 am	02/08/2026, 01:55:22 am	57m	0.6100	0.6928	-0.3400
4	02/08/2026, 02:13:33 am	02/08/2026, 02:33:35 am	20m	0.6000	0.6767	-0.3500
5	02/08/2026, 03:14:03 am	03/08/2026, 02:02:00 pm	34h 47m	-0.8800	0.6950	-1.8300
6	03/08/2026, 02:21:06 pm	05/08/2026, 02:15:30 am	35h 54m	-0.9500	0.6989	-1.9000
7	05/08/2026, 02:35:35 am	05/08/2026, 09:20:34 am	6h 44m	-0.8100	0.6717	-1.7600
8	05/08/2026, 09:39:34 am	07/08/2026, 04:40:15 pm	55h 0m	-0.9600	0.7416	-1.9100
9	07/08/2026, 05:01:18 pm	07/08/2026, 05:16:19 pm	15m	0.7500	0.7838	-0.2000



Export CSV



Download PDF



Save Report