

Solar Panel I-V Test Curve Report


Test Equipment: Kunkin KP184

Date: 08/09/2022

DUT Brand: Proton

DUT Model: P-M100-36P

DUT ID/#SN:



Test Results:

Open circuit voltage Voc: 20.678 V

Short circuit current Isc: 3.376 A

Maximum power MPP: 53.88 W

Maximum power point voltage Vmp: 16.91 V

Maximum power point current Imp: 3.186 A