


Liquid-Cooled Engines



DESCRIPTION

Scheduled maintenance is a necessity for all standby generators. The Liquid-Cooled Scheduled Maintenance Kits offer all the components necessary to perform a complete maintenance on Generac liquid-cooled generators. Oil and coolant will need to be purchased separately based upon manufacturer recommendations listed below. Maintenance is recommended at every 200 hours or 2 years. If running in a dusty environment, more frequent maintenance may be required. Further maintenance details can be found in the generator owner's manual.

KIT CONTENTS

Kit Model	6176	5656	5984	6172	6205	6171	5985	5660
kW Output	25/30	22/27	36	45	48	60	80	70/100/130/150
Engine Size	1.5L	2.4L	2.4L	2.4L	5.4L	2.4L	4.6L	6.8L
Air Filter	•	•	•	•	•	•	•	•
Pre-Cleaner					•		•	•
Oil Filter	•	•	•	•	•	•	•	•
Spark Plug(s)	4	4	4	4	8	4	8	10
Oil Funnel	•	•	•	•	•	•	•	•
Chamois	•	•	•	•	•	•	•	•
Reminder Sticker	•	•	•	•	•	•	•	•

*Contents of kits may vary. For specific oil recommendations, refer to the owner's manual. For non-current production product maintenance kits, contact a service dealer.