


Maintenance Kits

GENERAC®

GENERAC® ACCESSORIES

Air-Cooled Engines


Model 5661
Model 5662
Model 5663
Model 5664
Model 5665
Model 6003
Model 6004



DESCRIPTION

Scheduled maintenance is a necessity for all standby generators. The Air Cooled Scheduled Maintenance kits offer all the components necessary to perform a complete maintenance on Generac air-cooled generators. Oil will need to be purchased separately based upon the recommendations listed. Maintenance is recommended at every 200 hours or 2 years. If running in a dusty environment, more frequent maintenance may be required. Maintenance intervals may differ per model. Refer to the generator owner's manual for more information.

OIL RECOMMENDATIONS



KIT CONTENTS

Kit Model	5661	5662	5663	5664						5665	6003	6004
Unit Size	7kW (410cc)	8kW (410cc)	10kW (530cc)	12kW (760cc)	13kW (992cc)	14kW (992cc)	16kW (992cc)	17kW (992cc)	18kW (992cc)	20kW (999cc)	7kW (432cc)	6kW (530cc)
Air Filter	•	•	•	•	•	•	•	•	•	•	•	•
Oil Filter	•	•	•	•	•	•	•	•	•	•	•	•
Spark Plug(s)	1	1	2	2	2	2	2	2	2	2	1	2
Oil Funnel	•	•	•	•	•	•	•	•	•	•	•	•
Chamois	•	•	•	•	•	•	•	•	•	•	•	•
Reminder Sticker	•	•	•	•	•	•	•	•	•	•	•	•

*Contents of kits may vary

GENERAC®

Generac Power Systems, Inc. • S45 W29290 HWY. 59, Waukesha, WI 53189 • generac.com

©2012 Generac Power Systems, Inc. All rights reserved. All specifications are subject to change without notice. Bulletin 0181730SBY-G Printed in U.S.A. 11/14/12