



CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Pipe and Duct Insulation

(Details as per the attached Scope of Certification)

manufactured by:

RUBBER WORLD INDUSTRY LLC

2435 New Industrial Area. Ajman, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2023 AL SA'FAT DUBAI GREEN BUILDING SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).

For/ ENG. MAJED AL SHAMSI

Certification and Quality Control of Products Section's Manager
Dubai Central Laboratory Department-Dubai Municipality



Certificate No: CL18020532
Valid Until: 08/01/2027



Current Issue Date: 09/01/2026
Original Issue Date: 09/01/2018



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT

DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL18020532

Certificate Issued To:

RUBBER WORLD INDUSTRY LLC

2435 New Industrial Area, Ajman, UAE

Applicable Standard Specification:

2023 Al Sa'fat Dubai Green Building System-2nd Edition

Clauses [502.11] & [701.01]. **Dubai Building Code clauses** K10.1.5.4; K.10.2.11; H.4.8.4. **2023 Al Sa'fat Dubai Green Building System-2nd Edition** (Clauses (403.01, 403.02, 403.03, 701.01). **Dubai Building Code:**(H.4.5, H5.7, H10.4 and H.5.11, H10.3-H.10.3.1 General/H.10.3.2 Building services noise/ H.10.3.3 Sound insulationK.10.1.2, K10.2.7, K.10.2.11, K10.6, H.4.5

Applicable Specific Rules:

DM-DLCD-RD-DP21-2185-(IC): Certification of Pipe and Duct Insulation & Acoustic Insulation as per Al Sa'fat – Dubai Green Building System.

S/N	Product Description	Brand Name	Product Details
1.	NBR Elastomeric Foam for Pipe & Duct Insulation Materials CFC & HCFC Free (See Note 4)	GULF-O-FLEX GULF-O-FLEX Ultra WORLD-FLEX for plain tube insulation	NBR Elastomeric Foam for Pipe and Duct Insulation Materials manufactured with Plain (Unfaced), Alu-Glass Facing, Aluminum foil facing on one side and with or without self-adhesive on the other side Density: 50 - 80 kg/m ³ Thermal Conductivity (max): $k = 0.037 \text{ W/(m}^\circ\text{K)}$ @35 °C & 60±5% RH Water Vapor Permeance of 0.00 g/Pa-s-m ² is meeting the requirements of Table 1 of BS 5422: 2009 NBR Sheet in Rolls Thickness range: 6mm to 50mm Length: 4 meters to 30 meters Width: 1meter to 1.2 meter NBR Pipes Internal Diameter: 6mm to 114mm Pipe Wall Thickness Range: 6 mm to 50 mm Pipe Length: 1.8 meters to 2 meters

DUBAI CENTRAL LABORATORY DEPARTMENT

DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020532

2.	XLPE Foam for Pipe and Duct Insulation Materials (See Note 5) CFC Free (See Note 4)	GULF O FLEX XLPE	XLPE Foam manufactured with Reinforced Aluminum foil on one side and with or without self-adhesive on the other side Declared Density: 22 – 45 kg/m³ Thermal conductivity (max): 0.045 W/(m-°K) @ 35 °C & 60±5% RH (Water Vapor Permeance = 0.00 g/Pa-s-m²) is meeting the requirements of Table 1 of BS 5422:2009 XLPE Sheets in Rolls Width: 800 - 1500 mm Length: Various Length Nominal Thickness: 3 - 25 mm XLPE Tube Inside diameter: 6 - 450 mm Length: Various Length Nominal Thickness: 3 - 25 mm
----	---	------------------	--

- NOTE 1: This document forms an integral part of the Certificate of Product Conformity bearing the same certificate number.
- NOTE 2: The above product shall bear the DCLD Conformity Mark.
- NOTE 3: As applicable, other properties in the product standard specification which were excluded in the specific rules as approved by the certification body authorized personnel are to be verified by the end user of the product (if needed).
- NOTE 4: CFC & HCFC Free as per declaration from the company, in accordance with the 2023 Al Sa'fat Dubai Green Building System.
- NOTE 5: These products are manufactured by RUBBER WORLD INDUSTRY LLC's outsourced manufacturing facility, CF-540.
- NOTE 6: In accordance with Dubai Municipality requirements, any mandatory product manufactured in a certified factory and not covered under the approved scope of certification shall not be distributed, sold, or used within the Emirate of Dubai.

Original Issue Date : 09-01-2018
Current Issue Date : 09-01-2026
Valid Until : 08-01-2027

For/ **ENG. MAJED AL SHAMSI**

CERTIFICATION AND QUALITY CONTROL OF PRODUCTS SECTION'S MANAGER