

REPORT ON DETERMINATION OF WATER ABSORPTION OF INSULATION SHEET

Page 1 of 1

Co Sponsor : RWI INDUSTRIES (PVT) LTD, SRI-LANKA Report No. : **POLR-2204/4589**
Client : Rubber World Industry LLC Lab. Project No : **OG-1069**
Address : PO BOX 2435, AJMAN, UAE. Lab Ref. No. : POLQ-2204/2443
Contractor : NP Date sample received : 20/04/2022
Consultant : NP Date test Started : 20/04/2022
Project Name : NP Date Test Completed : 20/04/2022
Project No. : NP Report Date : 27/04/2022
Sample Description : **GULF.O.FLEX THERMAL INSULATION** Testing Temperature : 24 °C
Sample Name : **INSULATION SHEET** Relative Humidity : 50%
Source : Client Duration of Immersion : 2 Hours
Sampled by : Client Tested by : AJI
Sample brought by : Client
Water Temperature : 20°C
Size of Sample : 2m in length

Test Data

Lab Ref. No.	Test Parameter	Result
POLQ-2204/2443/1-3	Water Absorption by Volume (%)	0.16

Test method : **ASTM C534/C534M-20/ ASTM C 209-2015**
Test method variation : None
Remarks : None


Authorized Signatory

ساقب حسين فضل كريم
Saqib Hussain Fazal Karim

Results relate only to the item tested.

This report shall not be reproduced except in full, without the written approval of the laboratory



المكاتب: Offices:

دبي : متریال لاب - القوز | متریال لاب لخدمات
الفحص ذ.م.م - مجمع دبي للاستثمار
ابوظبي : متریال لاب لخدمات الفحص ذ.م.م - مصفح
L.L.C., Mussafah: +971 2 550 3040

Dubai: Material Lab, Al Quoz: +971 4 340 5678

Material Lab Testing Services L.L.C., Dubai Investment Park:

+971 4 333 9562, Abu Dhabi: Material Lab Testing Services

L.L.C., Mussafah: +971 2 550 3040



Dubai: +971 4 340 5677

Abu Dhabi: +971 2 550 3041



www.mlab.ae



Dubai: 114717

Abu Dhabi: 61831



mld@eim.ae

mlab@mlab.ae