

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

Analytical Report

Dan Cooper
Chicago Park District
541 N Fairbanks Ct
Chicago, IL 60641

July 01, 2016

Work Order: 16F1132

RE: CPD Drinking Water
Humboldt Park

Dear Dan Cooper:

Enclosed are the analytical reports for the EMT Work Order listed. Also included with this analytical report is a copy of the chain of custody associated with these samples. If you have any questions, please contact me.

Sincerely,



Tim Witrzek
Project Manager
847.967.6666

Approved by,



Matthew Gregory
Technical Manager

Approved for release: 7/1/2016 11:33:15AM

The contents of this report apply to the sample(s) analyzed. No duplication is allowed except in its entirety.
Reporting limits are adjusted for sample size used, dilutions and moisture content, if applicable.

State of Illinois, NELAP Accredited Lab No. 100256, Cert No. 003674



Table of Contents

Cover Letter	1
Case Narrative	3
Client Sample Results	4
Qualifiers and Definitions	4
Certified Analyses	4
List of Certifications	5
Chain of Custody	6

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

Case Narrative

Client: Chicago Park District**Date:** 07/01/2016**Project:** CPD Drinking Water
Humboldt Park**Work Order:** 16F1132

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

Sample Summary

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Humboldt Basement West #1	16F1132-01	Drinking Water	06/30/16 06:39	06/30/16 10:21
Humboldt Basement West #2	16F1132-02	Drinking Water	06/30/16 06:39	06/30/16 10:21
Humboldt Basement West #3	16F1132-03	Drinking Water	06/30/16 06:40	06/30/16 10:21

Narrative

Sample results only relate to the to the sample received at the laboratory and analytes of interest tested.

Work Order: 16F1132

The samples were received on 06/30/16 10:21. The samples arrived in good condition and properly preserved. The temperature of the cooler at receipt was

<u>Cooler</u>	<u>Temp C°</u>
Default Cooler	26.0

Refer to Qualifiers and Definitions for quality and analytical clarifications or deviations.

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

Client Sample Results

Client: Chicago Park District
Project: CPD Drinking Water
 Humboldt Park
Work Order: 16F1132

Report Date: 07/01/2016

Analyses	Result	EMT Reporting Limit	Qual	Units	Reg Limit	MDL	Date/Time Analyzed	Batch	Analyst
Client Sample ID: Humboldt Basement West #1 Collection Date: 06/30/2016 06:39 Metals by ICP-MS Method: E200.8							Matrix: Drinking Water Lab ID: 16F1132-01		
Lead	55.2	31.2		ppb	15	0.750	06/30/16 17:25	B6F1978	CS2
Client Sample ID: Humboldt Basement West #2 Collection Date: 06/30/2016 06:39 Metals by ICP-MS Method: E200.8							Matrix: Drinking Water Lab ID: 16F1132-02		
Lead	6.20	31.2	J	ppb	15	0.750	06/30/16 17:28	B6F1978	CS2
Client Sample ID: Humboldt Basement West #3 Collection Date: 06/30/2016 06:40 Metals by ICP-MS Method: E200.8							Matrix: Drinking Water Lab ID: 16F1132-03		
Lead	1.48	5.00	J	ppb	15	0.120	06/30/16 17:38	B6F1938	CS2

Qualifiers and Definitions

Item	Description
J	Estimated Value
%Rec	Percent Recovery

Certified Analyses included in this Report

Analyte	CAS #	Certifications
E200.8 in Drinking Water		
Lead	7439-92-1	ILEPA

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

List of Certifications

Code	Description	Number	Expires
AKDEC	State of Alaska, Dept. Environmental Conservation	UST-105	07/16/2016
CPSC	US Consumer Product Safety Commission, Accredited by PJLA Lab No. 1050	L14-56	04/30/2016
DoD	Department of Defense, Accredited by PJLA	L14-55	04/30/2018
ILEPA	State of Illinois, NELAP Accredited Lab No. 100256	003674	07/27/2016
ISO	ISO/IEC 17025, Accredited by PJLA	L14-56	04/30/2018
LELAP	State of Louisiana, NELAP Accredited Lab No. 171344	05015	06/30/2016
WDNR	State of Wisconsin Dept of Natural Resources	999888890	08/31/2016

Sample Receipt Checklist

Work Order: 16F1132

Printed: 6/30/2016 10:39:49AM

Client: Chicago Park District
Project: CPD Drinking Water

Date Due: 07/08/16 17:00 (5 day TAT)

Received By: Tim Witrzek
Logged In By: Tim Witrzek

Date Received: 06/30/16 10:21
Date Logged In: 06/30/16 10:34

Samples Received at:	26°C
How were samples received?	Client
Custody Seals Present	No
Custody Seals Intact	NA
Sample Cont/Cooler Intact	Yes
COC Present/Complete	Yes
COC/Labels Agree	Yes
Proper Cont/Preservation	Yes
Sufficient Sample Volume	Yes
Samples Within Holdtime	Yes
Cooler Temp Within Limits	Yes
VOA Water Vials Received	No
VOA Water Vials/Zero Headspace	NA
PM or Client Contacted	No

COMMENTS


 6/30/16