CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. 96-288

WASTE DISCHARGE REQUIREMENTS
FOR
BIOLA COMMUNITY SERVICES DISTRICT
WASTEWATER TREATMENT FACILITY
FRESNO COUNTY

The California Regional Water Quality Control Board, Central Valley Region, (hereafter Board) finds that:

1. Biola Community Services District (hereafter Discharger) submitted a Report of Waste Discharge dated 8 February 1996, a site evaluation/geotechnical report dated 17 November 1995, and a supplemental technical report dated 21 May 1996 in support of a proposed change in the method of treatment and an increase in the volume of waste discharged from its wastewater treatment facility (WWTF). The WWTF serves the unincorporated community of Biola and is on property (Assessor's Parcel Nos. 160-320-16, 160-020-13, 160-020-15, and 160-020-16) owned by the Discharger.

2. Waste Discharge Requirements Order No. 85-224, adopted by the Board on 23 August 1995, prescribes requirements for a design average dry weather discharge flow of 0.100 million gallons per day (mgd) from an extended aeration treatment plant to evaporation/percolation ponds.

3. Order No. 85-224 is neither adequate to describe proposed operations nor consistent with current plans and policies of the Board.

4. The existing WWTF includes a comminutor, two extended aeration tanks, two secondary clarifiers, two sludge drying beds, and five evaporation/percolation ponds. Sludge from this WWTF has been disposed of by landspreading on nearby privately owned farmlands without Board requirements or a waiver thereof.

5. Self-monitoring reports submitted by the Discharger show that average dry weather flows (ADWFs) at the WWTF are as high as 0.12 mgd. The flows are estimated based on pumping records from two sewage lift stations, but nevertheless indicate that the WWTF has reached its design capacity.

6. The Discharger proposes to abandon the aeration tanks, clarifiers, and three of its disposal ponds. It proposes to replace the abandoned units with four on-site aerated ponds and four new on-site disposal ponds to handle current and projected flows of up to 0.200 mgd.
Three of the proposed treatment ponds will be partially mixed, and the other pond will be fully mixed. The Discharger also reports that it will dispose of sludge pursuant to state and federal requirements.

7. The Discharger is receiving a grant from the United States Department of Housing and Urban Development via Fresno County to finance the entire project. The project has six major phases as follows:

	Phase	Completion date
1.	Replacement of lift station pumps and controls	Completed
2.	Abandon aeration tanks and clarifiers and construct first partially mixed pond	1996
3.	Construct additional percolation ponds	1996
4.	Construct second partially mixed pond	1997
5.	Construct fully mixed pond	1997
6.	Construct third partially mixed pond	1999

8. The WWTF is about one mile south of the San Joaquin River in Section 17, T13S, R18E, MDB&M, with surface water drainage to the San Joaquin River, as shown in Attachment A, which is attached hereto and part of this Order by reference. The site lies within the Fresno Hydrologic Area (No. 551.30), as depicted on interagency hydrologic maps prepared by the Department of Water Resources in August 1986.

9. The Board adopted a *Water Quality Control Plan for the Tulare Lake Basin, Second Edition* (hereafter Basin Plan) which designates beneficial uses and contains water quality objectives for all waters of the Basin. These requirements implement the Basin Plan.

10. The beneficial uses of underlying groundwater are domestic, industrial, and agricultural supply.

11. The Basin Plan requires that each Report of Waste Discharge for a land disposal operation justify why reclamation is not practiced or proposed. The Discharger reviewed opportunities for reclamation. It reports that farmlands in the area of the WWTF are predominantly planted with crops for human consumption which would require a highly treated and disinfected effluent, which, considering the relatively low volume of wastewater discharged, makes reclamation economically unfeasible.

12. The Discharger proposes to build the treatment ponds in the area currently occupied by the three disposal ponds it proposes to abandon. The new disposal ponds are to be located immediately southwest of the remaining existing disposal ponds. The 15 November 1995 geotechnical report indicates that soils in the area of the proposed treatment and disposal ponds generally consist of sands, silty sands, and sandy silts. The report also states that these soils have infiltration rates of 2.2 to 3.2 feet per day. Accordingly, it recommends that the proposed treatment ponds be built with an engineered liner that has a maximum permeability of 1.0×10^{-5} cm/sec.

13. Groundwater in the area of the WWTF occurs in an unconfined aquifer, is about 50 to 70 feet below ground surface (bgs), and is of good quality with an EC of 370 µmhos/cm. Groundwater beneath the WWTF was found at 50 feet bgs in October 1995.

14. The permitted discharge is consistent with the antidegradation provisions of State Water Resources Control Board Resolution 68-16. This Order provides for an increase in the volume of pollutants discharged. The project's increased discharge to disposal ponds will not cause significant impacts on groundwater and surface waters or depletion of limited ground water resources. The increase in the discharge allows wastewater utility service necessary to accommodate housing and economic expansion in the area, and is considered to be a benefit to the people of the State.

15. Fresno County adopted a Negative Declaration for the project on 25 July 1996 in accordance with the California Environmental Quality Act (CEQA) (Public Resources Code, Section 21000, et seq.), and the State CEQA Guidelines. The Board considered the document and compliance with these requirements will prevent adverse impacts on water quality.

16. The Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge and has provided them with an opportunity for a public hearing and an opportunity to submit their written views and recommendations.

17. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that Order No. 85-224 is rescinded and that Biola Community Services District, its agents, successors, and assigns, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, shall comply with the following:

B. Discharge Prohibitions

1. Discharge of wastes to surface waters or surface water drainage courses is prohibited.

2. Bypass or overflow of untreated or partially treated waste is prohibited.

3. Discharge of waste classified as 'hazardous' or 'designated', as defined in Sections 2521(a) and 2522(a) of Title 23, California Code of Regulations, Section 2510, et seq. (hereafter Chapter 15) is prohibited.

C. Discharge Specifications

1. **Until Provision No. E.5 is satisfied**, the monthly average dry weather (May through October) discharge shall not exceed 0.100 mgd.

2. **After Provision No. E.5 is satisfied**, the monthly average dry weather (May through October) discharge shall not exceed 0.200 mgd.

3. Objectionable odors originating at this facility shall not be perceivable beyond the limits of the wastewater treatment and disposal areas.

4. As a means of discerning compliance with Discharge Specification No. B.3, the dissolved oxygen content in the upper zone (1 foot) of wastewater in ponds shall not be less than 1.0 mg/l.

5. The treatment and disposal facilities shall be designed, constructed, operated, and maintained to prevent inundation or washout due to floods with a 100-year return frequency.

6. The discharge to the disposal ponds shall not exceed the following limits:

Constituent	Units	Monthly Average	Daily Maximum
20°C BOD_5	mg/l	40	80
Total Suspended Solids	mg/l	40	80
Settleable Solids	ml/l	0.2	0.5

7. Ponds shall not have a pH less than 6.5 or greater than 9.5.
8. Ponds shall be managed to prevent breeding of mosquitos. In particular:

   a. An erosion control program should assure that small coves and irregularities are not created around the perimeter of the water surface.

   b. Weeds shall be minimized through control of water depth, harvesting, or herbicides.

   c. Dead algae, vegetation, and debris shall not accumulate on the water surface.

9. Public contact with wastewater shall be precluded through such means as fences, signs, and other acceptable alternatives.

10. Ponds shall have sufficient capacity to accommodate allowable wastewater flow and design seasonal precipitation and ancillary inflow and infiltration throughout the year. Design seasonal precipitation shall be based on total annual precipitation using a return period of 100 years, distributed monthly in accordance with historical rainfall patterns. Freeboard shall never be less than two feet (measured vertically).

11. On or about 1 October of each year, available pond storage capacity shall at least equal the volume necessary to comply with Discharge Specification No. B.10.

D. Sludge Disposal Specifications

1. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of in a manner that is consistent with Chapter 15 and approved by the Executive Officer.

2. Any proposed change in sludge use or disposal practice shall be reported to the Executive Officer **at least 90 days in advance** of the change.

3. Use and disposal of sewage sludge shall comply with existing federal and state laws and regulations, including permitting requirements and technical standards included in 40 CFR 503.

   If the State Water Resources Control Board and the regional water quality control boards accept primacy to implement regulations contained in 40 CFR 503, this Order may be reopened to incorporate appropriate time schedules and technical standards. The Discharger must comply with the standards and time schedules contained in 40 CFR 503 whether or not they have been incorporated into this Order.

E. Groundwater Limitations

The discharge, in combination with other sources, shall not cause underlying groundwater to contain waste constituents in concentrations statistically greater than background water quality, except for specific electrical conductivity (EC). For EC, the incremental increase over the most recent five-year period shall not exceed 20 µmhos/cm. (For purposes of comparison, background water quality shall be determined when background monitoring provides sufficient data. Quality determined in this manner establishes "water quality protection standards.")

F. Provisions

1. The Discharger shall not allow pollutant-free wastewater to be discharged into the WWTF collection, treatment, and disposal systems in amounts that significantly diminish the systems' capability to comply with this Order.

Pollutant-free wastewater means stormwater (i.e., inflow), ground water (i.e., infiltration), cooling waters, and condensates that without treatment are essentially free of pollutants.

2. The Discharger shall comply with Monitoring and Reporting Program No. 96-288, which is part of this Order, and any revisions thereto as ordered by the Executive Officer.

3. The Discharger shall comply with the "Standard Provisions and Reporting Requirements for Waste Discharge Requirements," dated 1 March 1991, which are attached hereto and by reference a part of this Order. This attachment and its individual paragraphs are commonly referenced as "Standard Provision(s)."

4. **By 15 February 1997,** the Discharger shall submit a technical report in the form of a work plan to install and develop a comprehensive groundwater monitoring network to monitor at the earliest practicable date the effects of its disposal operations on the uppermost groundwater aquifer. The proposed program shall include, but not be limited to: (1) a sufficient number of upgradient and downgradient ground water monitoring wells for WWTF, (2) a map showing the proposed location of the wells, and (3) the proposed well specifications. The monitoring network shall be installed and developed **by 15 December 1997**.

5. For an increase in the volume of wastes discharged from 0.100 to 0.200 mgd, the Discharger shall comply with the following tasks and time schedule:

Task	Compliance Date	Report Due
a. Complete Plans and Specifications for expanded WWTF	**15 Jan 97**	**30 Jan 97**
b. Secure funding for expanded WWTF	**15 Mar 97**	**30 Mar 97**
c. Begin Construction	**15 Apr 97**	**30 Apr 97**
d. Complete construction of expanded WWTF and submit its Operation and Maintenance manual	**15 Dec 99**	**30 Dec 99**
e. Submit engineering report certifying that expanded WWTF is completed as designed for ADWF of 0.200 mgd and a hydrologic balance report substantiating that the expanded		**30 Dec 99**

WWTF complies with Discharge
Specification No. B.10

If the reports required by Item "e," above, meet with the satisfaction of the Executive Officer, he shall notify the Discharger that this Provision is satisfied and Discharge Specification B.2 is in effect.

6. **By 15 February 1997,** the Discharger shall submit an engineering report describing contingency plans and measures it proposes to take to ensure adequate treatment and disposal of on-site wastes and comply with Sludge Disposal Specification Nos. C.1 and C.3 during: (1) construction of the expanded WWTF; and (2) transition from the existing to the expanded WWTF for every phase of the expansion, beginning with Phase 2.

   Excepting the report required by Provision No. E.5, all technical reports shall be prepared by a California registered civil engineer experienced in the design of wastewater treatment and disposal facilities. The report required by Provision No. E.5 may be prepared by either a California certified engineering geologist or registered civil engineer with experience in these types of investigations. All reports, however, shall be subject to the review and approval of the Executive Officer.

7. In the event of any change in control or ownership of land or waste discharge facilities described herein, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to this office.

   To assume operation under this Order, the succeeding owner or operator must apply in writing to the Executive Officer requesting transfer of the Order. The request must contain the requesting entity's full legal name, the State of incorporation if a corporation, the name and address and telephone number of the persons responsible for contact with the Board, and a statement. The statement shall comply with the signatory paragraph of Standard Provision B.3 and state that the new owner or operator assumes full responsibility for compliance with this Order. Failure to submit the request shall be considered a discharge without requirements, a violation of the California Water Code. Transfer shall be approved or disapproved by the Executive Officer.

8. The Discharger shall use the best practicable control technique currently available to comply with the limits specified in this Order.

9. The Discharger must comply with all conditions of this Order, including timely submittal of technical and monitoring reports as directed by the Executive Officer. Violations may result in enforcement action, including Regional Board or court orders requiring corrective action or imposing civil monetary liability, or in revision or rescission of this Order.

10. The Discharger shall submit to the Board on or before each report due date the specified document or, if an action is specified, a written report detailing evidence of compliance with the date and task. If noncompliance is being reported, the reasons for such noncompliance shall be stated, plus an estimate of the date when the Discharger will be in compliance. The Discharger shall notify the Board by letter when it returns to compliance with the time schedule.

11. A copy of this Order shall be kept at the WWTF for reference by operating personnel. Key operating personnel shall be familiar with its contents.

12. If reclaimed water is used for construction purposes, it shall comply with the most current edition of "Guidelines for Use of Reclaimed Water for Construction Purposes". Other uses of reclaimed water not specifically authorized herein shall be subject to revision of this Order and compliance with 22 CCR, Division 4.

13. The Board will review this Order periodically and will revise requirements when necessary.

I, JAMES R. BENNETT, Interim Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 6 December 1996.

JAMES R. BENNETT, Interim Executive Officer

JLA:jla/fmc:12/6/96

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM NO. 96-288

FOR
BIOLA COMMUNITY SERVICES DISTRICT
WASTEWATER TREATMENT FACILITY
FRESNO COUNTY

Specific sample station locations shall be established under direction of the Board's staff and a description of the stations shall be submitted to the Board and attached to this Order.

INFLUENT MONITORING

Influent samples shall be collected at the inlet of the headworks and at approximately the same time as effluent samples. Influent monitoring shall include at least the following:

Sampling

Constituents	Units	Type of Sample	Frequency
Settleable Solids	ml/l	Grab	Monthly
20°C BOD_5	mg/l	Grab	Monthly
Total Suspended Solids	mg/l	Grab	Monthly

EFFLUENT MONITORING

Except for flow, which may also be measured at the headworks, effluent samples shall be collected downstream of the last treatment unit but prior to discharge to the disposal ponds. Time of collection of a grab sample shall be recorded. Effluent monitoring shall include at least the following:

Constituents	Units	Type of Sample	Sampling Frequency[1]
Total Daily Flow	gpd	Continuous	Daily
Settleable Solids	ml/l	Grab	Weekly
20°C BOD_5	mg/l	Grab	Weekly
Total Suspended Solids	mg/l	Grab	Weekly
Electrical Conductivity @ 25°C	µmhos/cm	Grab	Weekly

* See footnote next page

[1] If results of monitoring a pollutant appear to violate effluent limitations, but monitoring frequency is not sufficient to validate violation (e.g., the monthly average for BOD), or indicate a violation and potential upset of the treatment process (e.g., less than minimum D.O.), the frequency of sampling shall be increased to confirm the magnitude and duration of violation, if any, and aid in identification and resolution of the problem.

POND MONITORING

The freeboard shall be monitored on the storage pond to the nearest tenth foot. Pond water monitoring shall include the following :

Constituent	Unit	Measurement	Frequency
Freeboard	feet	Observation	Weekly
pH	pH units	Grab	Daily
Dissolved Oxygen[1]	mg/l	Grab	Daily

[1] Samples shall be collected at a depth of one foot from each pond, opposite the inlet, and analyzed for dissolved oxygen. Samples shall be collected between 0800 and 0900 hours.

Permanent markers (e.g., staff gages) shall be placed in the disposal ponds with calibration indicating the water level at design capacity and available operational freeboard. In addition, the Discharger shall inspect the conditions of all ponds once per week and write visual observation in a bound log book. Notations shall include observations of whether weeds are developing in the water or along the bank, and their locations; whether dead algae, vegetation, scum, or debris are accumulating on the pond surface and their location; whether burrowing animals or insects are present; and the color of the pond (e.g., dark sparking green, dull green, yellow, grey, tan, brown, etc.) A copy of the entries made in the log during each month shall be submitted along with the monitoring report the following month. Where the O&M manual indicates remedial action is necessary, the Discharger shall briefly explain in the transmittal what action has been taken or is scheduled to be taken.

SLUDGE MONITORING

A composite sample of sludge shall be collected prior to sludge disposal in accordance with EPA's POTW Sludge Sampling and Analysis Guidance Document, August 1989, and tested for the following metals:

Cadmium	Lead
Chromium	Nickel
Copper	Zinc

Sampling records shall be retained for a minimum of five years. A log shall be kept of sludge quantities generated and of handling and disposal activities. The frequency of entries is discretionary; however, the log should be complete enough to serve as a basis for part of the annual report.

WATER SUPPLY MONITORING

A sampling station shall be established where a representative sample of the water supply can be obtained. Water supply monitoring shall include at least the following:

Constituents	Units	Sampling Frequency
Electrical Conductivity @ 25°C	μmhos/cm	Monthly[1]

[1] Since the water supply is from more than one well, the EC shall be reported as a weighted average and include copies of supporting calculations.

GROUND WATER MONITORING

Pursuant to Provision No. E.4, and beginning in **January 1998**, the Discharger shall sample the approved ground water monitoring wells monthly for one year, and analyze them for the parameters specified below. **Within 30 days after one year of sampling the wells**, data from these analyses shall be reported to the Board, along with recommendations, for use in establishing water quality protection standards. If subsequent sampling of background monitoring wells indicates significant water quality changes due to either seasonal fluctuations or other reasons unrelated to waste disposal activities, the Discharger may request modification of the water quality protection standards.

The downgradient wells near the facility property boundaries shall constitute "points of compliance (POCs)". In conjunction with background monitoring, monitoring of POCs will enable one to determine compliance with water quality protection standards. The ground water

surface elevation (in feet and hundredths, M.S.L.) and depth to ground water (in feet and hundredths below ground surface) in all wells shall be measured on a quarterly basis and used to determine the gradient and direction of ground water flow. Water samples shall be collected from the wells and analyzed as follows:

Constituent	Units	Type of Sample	Sampling Frequency

Specific Conductivity @ 25°C	μmhos/cm	Grab	Quarterly
Total Dissolved Solids	mg/l	Grab	Quarterly
Standard Minerals[1]	mg/l	Grab	Quarterly

[1] Standard minerals as used in this program shall include all major cations and anions and include a verification that the analysis is complete (i.e., cation/anion balance).

Following each sampling event, the discharger shall determine whether there is a statistically significant increase over water quality protection standards for each parameter and constituent analyzed. If the Discharger or the Board finds there is a statistically significant increase in indicator parameters or waste constituents over the water quality protection standards at the POC's, the Discharger shall notify the Board immediately and increase the monitoring frequency to monthly, pending additional directions from Board staff.

REPORTING

Daily, monthly, and quarterly sampling results shall be submitted to the Board by the **20th of the month** following the period the samples are collected. Noncompliance with waste discharge requirements shall be reported as soon as discovered.

In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner that illustrates clearly whether the Discharger complies with waste discharge requirements, including calculation of all averages, etc.

If the Discharger monitors any pollutant at the locations designated herein more frequently that is required by this Order, the results of such monitoring shall be included in the discharge monitoring report.

The Discharger may also be requested to submit an annual report to the Board with tabular and graphical summaries of the monitoring data obtained during the previous year. Any such request shall be made in writing. The report shall discuss the corrective actions taken and planned to bring the discharge into full compliance with the waste discharge requirements.

By **31 January of each year**, the Discharger shall submit a written report to the Executive Officer containing the following:

a. The names, titles, certificate grade and general responsibilities of persons operating and maintaining the wastewater treatment facility.

b. The names and telephone numbers of persons to contact regarding the plant for emergency and routine situations.

c. A certified statement of when the flow meter and other monitoring instruments and devices were last calibrated, including identification of who did the calibration (Standard Provision C.4).

d. A statement whether the current operation and maintenance manual, and contingency plan, reflect the wastewater treatment plant as currently constructed and operated, and the dates when these documents were last reviewed for adequacy.

e. The total quantity of sludge disposed of during the previous year and ultimate disposal site(s).

All reports submitted in response to this Order shall comply with the signatory requirements in Standard Provision B.3.

The Discharger shall implement the above monitoring program on the first day of the month following effective date of this Order.

Ordered by: ______________

JAMES R. BENNETT, Interim Executive Officer

6 December 1996

(Date)

JLA:jla/fmc:12/6/96

INFORMATION SHEET

BIOLA COMMUNITY SERVICES DISTRICT
WASTEWATER TREATMENT FACILITY
FRESNO COUNTY

Biola Community Services District (hereafter Discharger) submitted a Report of Waste Discharge and applied for revised requirements for a proposed change in the method of treatment and an increase in the volume of waste discharged from its wastewater treatment facility (WWTF). The WWTF is about one mile south of the San Joaquin River, serves the unincorporated community of Biola, and has a rated capacity of 0.100 million gallons per day (mgd).

Currently, the WWTF includes a comminutor, two extended aeration tanks, two secondary clarifiers, two sludge drying beds, and five evaporation/percolation ponds. Sludge from this WWTF has been disposed of by landspreading on nearby farmlands without Board requirements or a waiver thereof. The discharge from the WWTF is currently governed by Waste Discharge Requirements Order No. 85-224.

Monitoring data submitted by the Discharger show average dry weather flows (ADWFs) at the WWTF as high as 0.12 mgd. Even though the flows are estimated based on pumping records from the two sewage lift station, they indicate that the WWTF is running at least at 90% of its design capacity based on an estimated ±10% metering inaccuracy. The Discharger proposes to abandon the aeration tanks, the clarifiers, and three of the disposal ponds to expand its WWTF. It proposes to replace these units with four aerated ponds and four new disposal ponds to handle current and projected flows of up to 0.200 mgd. The Discharger is receiving a grant from the United States Department of Housing and Urban Development via Fresno County to finance the expansion of the WWTF. The expansion has six major phases as follows:

Phase	Completion date
1. Replacement of lift station pumps and controls	Completed
2. Abandon aeration tanks and clarifiers and construct first partially mixed pond	1996
3. Construct additional percolation ponds	1996
4. Construct second partially mixed pond	1997
5. Construct fully mixed pond	1997
6. Construct third partially mixed pond	1999

The proposed treatment ponds will be in the area currently occupied by the three disposal ponds that are to be abandoned. The new disposal ponds will be immediately southwest of the remaining existing disposal ponds. The Discharger submitted a geotechnical report dated 15 November 1995 that indicates that soils in the area of the proposed treatment and disposal ponds generally consist of sands, silty sands, and sandy silts with infiltration rates of 2.2 to 3.2 feet per day. Accordingly, the report recommends that the proposed treatment ponds be built with an engineered liner that has a maximum permeability of 1.0×10^{-5} cm/sec to ensure adequate detention time.

INFORMATION SHEET

BIOLA COMMUNITY SERVICES DISTRICT
WASTEWATER TREATMENT FACILITY
FRESNO COUNTY

Surface water drainage is to the San Joaquin River. Average total annual precipitation and pan evaporation for the area are 12 and 60 inches, respectively. Groundwater in the area of the WWTF occurs in an unconfined aquifer, is about 50 to 70 feet below ground surface, and is of good quality with an EC of 370 μmhos/cm.

This proposed Order implements the water quality objectives (WQOs) of the *Water Quality Control Plan for the Tulare Lake Basin, Second Edition*. The Order provides for a increase in flow from 0.100 to 0.200 mgd provided the Discharger submits engineering certification that the proposed expanded WWTF has been completed as designed to handle the latter flow. It prescribes groundwater monitoring to verify compliance with WQOs.

Fresno County adopted a Negative Declaration for the project on 25 July 1996 in accordance with the California Environmental Quality Act (CEQA) (Public Resources Code, Section 21000, et seq.), and the State CEQA Guidelines. The Board reviewed the Negative Declaration, and compliance with these requirements will prevent adverse impacts on water quality.

JLA:jla/fmc:12/6/96