CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LAHONTAN REGION

BOARD ORDER NO. 6-93-19
WDID NO. 6B260101002

REVISED WASTE DISCHARGE REQUIREMENTS

FOR

JUNE LAKE PUBLIC UTILITY DISTRICT
Mono County

The California Regional Water Quality Control Board, (Regional Board) Lahontan Region, finds:

1. Mr. Leonard D. Ainsworth on behalf of the June Lake Public Utility District submitted information dated December 17, 1992 to constitute a complete revised report of waste discharge for the June Lake domestic wastewater treatment plant. For the purposes of this order the June Lake Public Utility District is referred to as the "Discharger".

2. The Board previously established waste discharge requirements for the Discharger under Board Order No. 6-83-106, which was adopted on September 8, 1983.

3. The Board is updating waste discharge requirements as part of a statewide program to periodically review and revise all outdated requirements and to modify the current monitoring and reporting program.

4. The June Lake treatment plant, which is located approximately 5 miles north of the community of June Lake, collects, treats and disposes of an average of 0.28 mgd of domestic wastewater. The treatment and disposal facilities are located in the Mono Hydrologic Unit within Section 10, T1S, R26S, MDB&M as shown on Attachment "A", which is made a part of this order.

5. Wastewater generated within the June Lake Loop area is conveyed to the district's treatment plant by an eleven mile long interceptor sewer. Wastewater treatment is provided by an oxidation ditch. Three surface aerators have been added to augment the original brush aerator. The design capacity of the treatment facility is 1.0 mgd.

6. Waste sludge from the secondary clarifier is discharged to sludge drying beds. Dried sludge is buried north of the treatment plant within the fenced treatment plant area. Secondary effluent from the treatment plant is currently discharged to one of four (4) existing percolation ponds for disposal.

7. The percolation ponds are the only designated disposal sites for the treated effluent.

8. The disposal site is underlain by holocene alluvial deposits that are covered by a thin veneer of holocene pumice ash derived from the Inyo and Mono craters eruptions. Groundwater in well 1S/26E-3C1, which is 1.5 miles north of the site, has a total dissolved solids concentration of less than 100 mg/l and is of excellent quality for all beneficial uses. Depth to groundwater at the disposal site is estimated to be 50 feet.

9. The designated disposal site is located on land owned by the City of Los Angeles, Department of Water and Power and leased to the Discharger.

10. The Board adopted the Water Quality Control Plan for the South Lahontan Basin on May 8, 1975, and this order implements that plan, as amended.

11. The beneficial uses of groundwaters of the Mono Hydrologic Unit as set forth and defined in the plan are:

    a. municipal and domestic supply
    b. agricultural supply
    c. industrial service
    d. freshwater replenishment

12. The Board has notified the Discharger and interested agencies and persons of its intent to update waste discharge requirements for this discharge.

13. These updated waste discharge requirements apply to an existing discharge resulting from an existing facility and are therefore exempt from the provisions of the California Environmental Quality Act (Public Resources Code, Section 21000 et seq.) in accordance with Title 14, Section 15301, of the California Code of Regulations.

14. The Board in a public meeting heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that the Discharger shall comply with the following:

I. DISCHARGE SPECIFICATIONS

A. Effluent Limitations

1. The total flow of wastewater to the treatment and disposal facilities during a 24-hour period shall not exceed 1.0 million gallons.

2. All wastewater made available for percolation shall not contain concentrations of parameters in excess of the following limits:

Parameter	Units	Mean[1/]	Maximum
BOD[2/]	mg/l	30	45

3. All wastewater made available for percolation shall have a pH of not less than 6.0 pH units nor more than 9.0 pH units.[3/]

4. All wastewater made available for percolation shall have a dissolved oxygen concentration of not less than 1.0 mg/l.

B. Receiving Water Limitations

1. The waste discharge shall not result in any perceptible color, odor, taste or foaming in or groundwaters of the Mono Hydrologic Unit.

1/ The arithmetic mean of lab results for effluent samples collected over the past four quarters.
2/ Biochemical Oxygen Demand (5 day, 20°C) of an unfiltered sample.
3/ Because the effluent from an extended aeration activated sludge treatment plant may normally have a low pH during certain climatic conditions, a pH as low as 4.5 will be allowed if it results from natural conditions and not from a discharge of acid wastes to the system.

2. The discharge shall not result in coliform organisms attributable to human wastes being present in the groundwaters of the Mono Hydrologic Unit.

3. The discharge shall not cause there to be in any groundwater of the Mono Hydrologic Unit toxic substances that individually, collectively or cumulatively cause detrimental physiological responses in human, plant, animal, or aquatic life.

C. General Requirements and Prohibitions

1. There shall be no discharge, bypass or diversion of raw or partially treated sewage, sewage sludge, grease or oils from the collection, transport, treatment or disposal facilities to adjacent land areas or surface waters.

2. Surface flow or visible discharge of sewage or sewage effluent from the designated disposal site to adjacent land areas or surface waters is prohibited.

3. All facilities used for collection, transport, treatment or disposal of wastes shall be adequately protected against either structural damage or a significant reduction in efficiency resulting from a storm or flood having a recurrence interval of once in 100 years.

4. The vertical distance between the water surface elevation and the lowest point of a pond dike or the invert of an overflow structure shall not be less than 2 feet.

5. The discharge of wastewater except to the designated disposal site is prohibited.

6. The discharge to waters of the State shall contain no trace elements, pollutants or contaminants, or combinations thereof, in concentrations which are toxic or harmful to humans or to aquatic or terrestrial plant or animal life.

7. The discharge shall not cause a pollution, as defined in Section 13050 of the California Water Code, or a threatened pollution.

8. Neither the treatment nor the discharge shall cause a nuisance as defined in Sectin 13050 of the California Water Code.

9. There shall be no discharge to surface water.

II. PROVISIONS

1. Board Order No. 6-83-106 is hereby rescinded.

2. Pursuant to Section 13267 of the California Water Code, the Discharger shall comply with Monitoring and Reporting Program No. 6-93-19 and the "Standard Provisions" (Attachment "B").

3. Pursuant to California Water Code 13267(b), the Discharger shall notify the Board by telephone within 24 hours whenever an adverse condition occurs as a result of this discharge; written confirmation shall follow within ten working days. An adverse condition includes, but is not limited to, discharges exceeding the discharge specifications, equipment failure or shutdown, discharge to other than the authorized disposal site(s), or any condition causing a threatened pollution, pollution or a nuisance.

4. The Discharger's wastewater treatment plant shall be supervised by persons possessing a wastewater treatment plant operator certificate of appropriate grade pursuant to Chapter 3, Subchapter 14, Title 23, California Code of Regulations.

5. "Surface waters" as used in this order include, but are not limited to, live streams, either perennial or ephemeral, which flow in a natural or artificial watercourse or natural lakes and artificial impoundments of waters within the State of California.

6. "Ground Waters" as used in this Order, include, but are not limited to, all subsurface waters being above atmospheric pressure and the capillary fringe of these waters.

I, Harold J. Singer, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of any Order adopted by the California Regional Water Quality Control Board, Lahontan Region, on March 11, 1993.

Harold J. Singer

HAROLD J. SINGER
EXECUTIVE OFFICER

Attachments:
A. Location Map
B. Standard Provisions

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LAHONTAN REGION

MONITORING AND REPORTING PROGRAM NO. 93-19
WDID NO. 6B260101002

REVISED WASTE DISCHARGE REQUIREMENTS

FOR

JUNE LAKE PUBLIC UTILITY DISTRICT
Mono County

I. MONITORING

A. Flow Monitoring

The following shall be recorded in a permanent log book and reported quarterly:

1. The average flow rate, in million gallons per day (mgd), of wastewater to the treatment facility calculated for each month.

2. The freeboard (distance from the top of the lowest part of the dike to the wastewater surface in the pond) measured each month in each pond. If a pond does not contain wastewater, indicate that it is empty.

B. Plant Influent Monitoring

Influent to the treatment plant shall be sampled quarterly and analyzed to determine the magnitude of the following parameters and the results of the analyses shall be reported quarterly:

Parameter	Type of Units	Sample
Oil & Grease	mg/l	grab
BOD_5[1/]	mg/l	8 hour composite
Suspended Solids	mg/l	8 hour composite
Temperature	°C or °F	grab
pH	pH units	grab

Samples shall be collected at a turbulent, well mixed point.

1/ Biochemical Oxygen Demand (5 day, 20°C) of a unfiltered sample.

C. Plant Effluent Monitoring

Effluent discharged to the evaporation/percolation ponds shall be sampled quarterly and analyzed to determine the magnitude of the following parameters and the results of the analyses shall be reported quarterly:

Parameter	Type of Units	Sample
BOD_5[1/]	mg/l	8 hour composite
Oil & Grease	mg/l	grab
Total Dissolved Solids (TDS)	mg/l	grab
Chloride	mg/l	grab
Dissolved Oxygen	mg/l	grab
Temperature	°C or °F	grab
pH	pH units	grab
TKN[2/]	mg/l	grab
Nitrate Nitrogen	mg/l as N	grab
Ammonia Nitrogen	mg/l as N	grab

Samples shall be collected at a well mixed point in the effluent. If no discharge to the percolation pond has occurred during the monitoring period then the monitoring report shall reflect "no discharge".

D. Ground Water Monitoring

1. The discharger shall drill at least one (1) ground water monitoring well to demonstrate ground water level. The well shall be drilled and logged by a licensed well driller utilizing a method that will detect zones with signficant increases in soil moisture. If ground water is encountered at a depth of less than five-hundred (500) feet below ground surface, the discharger shall submit a ground water monitoring system plan and a time schedule for installation of ground water monitoring wells described below. If groundwater is not found to a depth of five-hundred (500) feet, groundwater monitoring will not be required.

2. If groundwater is present at a depth of less than five-hundred (500) feet the discharger shall submit a report describing a ground water monitoring system and a time schedule for installation of ground water monitoring wells by June 11, 1993. The monitoring system, at a minimum shall include:

    a. A minimum of three monitoring wells shall be proposed to determine the gradient of the ground water.

2/ Total Kjeldahl Nitrogen

The proposal may include the use of existing wells if the design, location, and construction of the existing wells can be documented as appropriate for the purposes of monitoring the effects of the disposal ponds on the local ground water aquifer.

b. Additional well(s) shall be installed, if necessary, to insure that at least one (1) well is upgradient and two (2) wells are down gradient of the wastewater treatment facilities. The Discharger shall demonstrate that at least one of the downgradient wells are located such that ground water potentially impacted by the discharge will be monitored.

c. The specific design and location of the wells shall be reviewed and approved by the Executive Officer.

d. An as-built design report for all ground water monitoring features shall be submitted within 60 days after the ground water monitoring system is installed. This report shall include a statement of certification signed by a registered civil engineer, geologist, or certified engineering geologist regarding the placement, lithology and construction of the wells.

3. Prior to August 11, 1993 the ground water monitoring wells shall be installed at the disposal site in accordance with the submitted report.

After well completion and development, and prior to September 11, 1993 an analysis of the water in the monitoring wells for the parameters listed in item 3 of this section shall be provided.

4. Grab samples from the entire thickness or the upper 20 feet, whichever is less, of the uppermost ground water bearing zone shall be collected, beginning on or before September 11, 1993 and annually thereafter, from the monitoring wells and analyzed to determine the magnitude of the following parameters:

Parameter	Units
MBAS[3/]	mg/l
Total Dissolved Solids	mg/l
pH	pH units
Temperature	^{o}C or ^{o}F
Chloride	mg/l
Nitrate Nitrogen	mg/l as N

3/ Methylene Blue Active Substances

Parameter	Units
Purgeable Halocarbons[4/5/]	mg/l
Base/Neutral/Acid Extractable Organics[4/6/]	mg/l
Purgeable Aromatic[4/7/]	mg/l

The results of these analysis shall be reported in the annual report.

E. Offsite Disposal

The Discharger shall include in each monitoring report the volume and type of all waste hauled off site for disposal. The person or company doing the hauling and the legal point of disposal shall also be recorded.

F. Sampling and Analysis Methods

1. Sampling analysis methods shall be in accordance with the current editions of one of the following documents:

   a. Methods for Chemical Analysis of Water and Wastes, Environmental Protection Agency
   b. Standard Methods for the Examination of Water and Wastewater

   Any modifications to the above methods to eliminate known interferences shall be reported with the sample results. The method used shall also be reported.

2. The Discharger shall calibrate and perform maintenance procedures on all monitoring equipment to ensure accuracy of measurements, or shall insure that both activities will be conducted. The calibration of any wastewater flow measuring device shall be recorded and maintained in the permanent log book.

G. Operation and Maintenance

1. A brief summary of any operational problems and maintenance activities shall be submitted to the Board with each monitoring report. This summary shall discuss:

   a. Any modifications or additions to, or any major maintenance conducted on, or any major problems occurring to the wastewater conveyance system, treatment facilities, or disposal facilities.

4/ Analysis shall be conducted for those substances included on the EPA list of priority pollutants and all other substances known to be discharged to the June Lake Area sewer system.

5/ Purgeable organics analysis shall be conducted in accordance with EPA method 601, 40 CFR part 136, Appendix A.

6/ Base/neutral/acid extractable organics analysis shall be conducted in accordance with EPA method 625, 40 CFR, part 136, Appendix A.

7/ Purgeable Aromatics analysis shall be conducted in accordance with EPA method 602, 40 CFR part 136, Appendix A.

b. Evidence that the Discharger has a wastewater treatment plant operator/supervisor of the appropriate grade pursuant to Chapter 3, Subchapter 14, Title 23, California Code of Regulations.

II. REPORTING

A. Submittal Periods

Beginning on the 15th of the month following the first quarter after the adoption of this permit, a monitoring report including the preceding information shall be submitted to the Board. Subsequent monitoring reports shall be submitted to the Board by the 15th day month following each quarter.

B. Authorization

Monitoring reports shall be signed by the Public Utilities Director or another duly authorized employee.

C. Information

Monitoring reports are to include the following:

1. Name and telephone number of an individual who can answer questions about the report;
2. Monitoring and Reporting Program No. 6-93-19; and
3. WDID No. 6B260101002

D. Noncompliance

For every item where the requirements are not met, the Discharger shall submit a statement of the actions undertaken or proposed which will bring the discharge into compliance with requirements at the earliest time and submit a timetable for correction.

E. Analysis Retention

The Discharger shall maintain all sampling and analytical results, including strip charts; date, exact place, and time of sampling; date analysis were performed; sample collector's name; analyst's name; analytical techniques used; and results of all analysis. Such records shall be retained for a minimum of three years. This period of retention shall be extended during the course of any unresolved litigation regarding this discharge or when requested by the Board.

F. Annual Report

By January 30 of each year, the Discharger shall submit an annual report to the Board with the following information:

1. The compliance record and corrective actions taken or planned which may be needed to bring the discharge into full compliance with the discharge requirements.

2. Graphical and tabular data for the monitoring data obtained for the previous year.

G. Failure to Furnish Reports

Any person failing or refusing to furnish technical or monitoring reports or falsifying any information provided therein, is guilty of a misdemeanor and may be liable civilly in an amount of up to one thousand dollars ($1000) for each day of violation under Section 13268 of the California Water Code.

H. Provisions

This Monitoring and Reporting Program may be modified at the discretion of the Regional Board Executive Officer.

Ordered By: Harold J Singer Dated: March 11, 1993
HAROLD J. SINGER
EXECUTIVE OFFICER